

May 23, 2023

Mr. Matthew Griffin
Facilities Supervisor
Kyrene School District No. 28
8700 South Kyrene Road
Tempe, AZ 85284-2197

**Subject: 6-Month Surveillance Inspection
Asbestos-Containing Building Materials
Ben Furlong Education Center
8700 South Kyrene Road, Tempe**

Dear Mr. Griffin:

FM GROUP INC has completed the 6-Month Surveillance Inspection of Asbestos-Containing Building Materials (ACBM) at the subject school. The forms detailing the results of this reinspection and reassessment of known ACBM are attached.

The attached tables and forms have been updated to reflect the findings as of the date of this Reinspection and should serve as the Management Plan update.

Items of significance are: None

If you have any questions regarding this correspondence, please contact us immediately.

Sincerely,

FM GROUP INC



Michael Hall
Environmental Division Manager



Zach Ridgeway
AHERA Building Inspector

*Attachments: 6-Month Surveillance Inspection Forms
6-Month Surveillance Inspection Tables*



6-MONTH SURVEILLANCE INSPECTION ASBESTOS-CONTAINING BUILDING MATERIALS

School/Facility: Ben Furlong Education Center

Inspection Date: 05/01/2023

Building: Building A

Inspector: Zach Ridgeway Cert. No.: 4380-15665-030823

Signature: 

Material Description	Material Code	Material Observed		Material Condition Status		Material Condition Description (If Change Noted)	Assessment Classification
				Same	Changed		
Fire Door Insulation, Metal/Wood Cladding	M-FDI-07	Y	N	x			1 2 3 4 5 6 7*
Wallbase (Carpet), 4", Black, Fibrous	M-WAB-08	Y	N	x			1 2 3 4 5 6 7*
Adhesive, Blue, Pliable	M-ADH-09	Y	N	x			1 2 3 4 5 6 7*
Sealant (Doors, Windows, Millwork, Fixtures), White, Pliable	M-SLT-10	Y	N	x			1 2 3 4 5 6 7*
Tackable Wall Panel, Brown, Fibrous, Vinyl Cover, Mechanically Attached	M-TWP-11	Y	N	x			1 2 3 4 5 6 7*
Spray-Applied Texture, White, Chalky	S-SAT-12	Y	N	x			1 2 3 4 5 6 7*
Gypsum Wallboard, White, Chalky	M-GWB-13	Y	N	x			1 2 3 4 5 6 7*
Joint Compound, White, Chalky	S-JTC-14	Y	N	x			1 2 3 4 5 6 7*
Glazed Wall Tile, 2"X2", Tan, Smooth	M-GWT-15	Y	N	x			1 2 3 4 5 6 7*
Glazed Wall Tile (Pattern), 4"X4", Blue, Smooth	M-GWT-16	Y	N	x			1 2 3 4 5 6 7*
Grout, Gray, Cementitious	M-GRT-17	Y	N	x			1 2 3 4 5 6 7*
Ceramic Mosaic Tile, 2"X2", Pink, Smooth	M-CMT-18	Y	N	x			1 2 3 4 5 6 7*
Grout, Gray, Cementitious	M-GRT-19	Y	N	x			1 2 3 4 5 6 7*
Sink Acoustical Coating, White, Rough	M-SAC-20	Y	N	x			1 2 3 4 5 6 7*
Quarry/Paver Tile, 4"X4", Gray, Smooth	M-QPT-24	Y	N	x			1 2 3 4 5 6 7*
Quarry/Paver Tile, 4"X4", Tan, Smooth, Black And White Specks	M-QPT-25	Y	N	x			1 2 3 4 5 6 7*
Grout, Gray, Cementitious	M-GRT-26	Y	N	x			1 2 3 4 5 6 7*
Vinyl Composition Tile, 12"X12", Tan, Smooth, Brown And White Mottles	M-VCT-28	Y	N	x			1 2 3 4 5 6 7*
Vinyl Composition Tile, 12"X12", Tan, Smooth, Black Spots	M-VCT-29	Y	N	x			1 2 3 4 5 6 7*
Mastic, Yellow, Tacky	M-MAS-30	Y	N	x			1 2 3 4 5 6 7*
Sealant (Fire Stop), Red, Pliable	M-SLT-33	Y	N	x			1 2 3 4 5 6 7*
Plaster, Gray, Cementitious	S-PLA-34	Y	N	x			1 2 3 4 5 6 7*
Sealant (Doors, Windows), Black, Gummy	M-SLT-35	Y	N	x			1 2 3 4 5 6 7*
Carpet, Blue, Fibrous, Brown And White Spots	M-CPT-37	Y	N	x			1 2 3 4 5 6 7*
Mastic, Yellow, Tacky	M-MAS-38	Y	N	x			1 2 3 4 5 6 7*
Concrete Masonry Unit, 8"X16", Gray, Cementitious	M-CMU-39	Y	N	x			1 2 3 4 5 6 7*
Mortar, Gray, Cementitious	M-MRT-40	Y	N	x			1 2 3 4 5 6 7*



6-MONTH SURVEILLANCE INSPECTION ASBESTOS-CONTAINING BUILDING MATERIALS

Material Description	Material Code	Material Observed		Material Condition Status		Material Condition Description (If Change Noted)	Assessment Classification
				Same	Changed		
Carpet, Purple, Fibrous, Gray Specks	M-CPT-41	Y	N	x			1 2 3 4 5 6 7*
Mastic, Yellow, Tacky	M-MAS-42	Y	N	x			1 2 3 4 5 6 7*
Vinyl Stair Tread, 12"X48", Blue, Circle Pattern	M-VST-43	Y	N	x			1 2 3 4 5 6 7*
Vinyl Composition Tile, 18"X18", Blue, Circle Pattern	M-VCT-44	Y	N	x			1 2 3 4 5 6 7*
Mastic, Yellow, Tacky	M-MAS-45	Y	N	x			1 2 3 4 5 6 7*
Wallbase (Coved), 4", Gray, Vinyl-Like	M-WAB-46	Y	N	x			1 2 3 4 5 6 7*
Adhesive, Cream, Pliable	M-ADH-47	Y	N	x			1 2 3 4 5 6 7*
Built-Up Roofing, Black, Asphaltic, Gravel Cap	M-BUR-48	Y	N	x			1 2 3 4 5 6 7*
Mastic, (Penetrations And Flashings), Black, Tar-Like	M-MAS-49	Y	N	x			1 2 3 4 5 6 7*
Sealant (Flashings), Black, Pliable	M-SLT-50	Y	N	x			1 2 3 4 5 6 7*
Concrete (Entries), Gray, Cementitious	M-CON-54	Y	N	x			1 2 3 4 5 6 7*
Sealant (Doors, Windows), Gray, Pliable	M-SLT-55	Y	N	x			1 2 3 4 5 6 7*
Gaskets, 1"-3", Black/Green, Paper-Like	M-GAS-56	Y	N	x			1 2 3 4 5 6 7*

*Assessment Classifications

1. Damaged or significantly damaged thermal system insulation ACBM.
2. Damaged friable surfacing ACBM.
3. Significantly damaged friable surfacing ACBM.
4. Damaged or significantly damaged friable miscellaneous ACBM.
5. ACBM with potential for damage.
6. ACBM with potential for significant damage.
7. Any remaining friable ACBM or friable suspected ACBM.




6-MONTH SURVEILLANCE INSPECTION ASBESTOS-CONTAINING BUILDING MATERIALS

School/Facility: Ben Furlong Education Center

Inspection Date: 05/01/2023

Building: Building B

Inspector: Zach Ridgeway Cert. No.: 4380-12501-123169 Signature: 

Material Description	Material Code	Material Observed		Material Condition Status		Material Condition Description (If Change Noted)	Assessment Classification
				Same	Changed		
Carpet, Gray, Fibrous	M-CPT-05	Y	N	x			1 2 3 4 5 6 7*
Mastic, Yellow, Tacky	M-MAS-06	Y	N	x			1 2 3 4 5 6 7*
Wallbase (Coved), 4", Blue, Vinyl-Like	M-WAB-07	Y	N	x			1 2 3 4 5 6 7*
Adhesive, Cream, Pliable	M-ADH-08	Y	N	x			1 2 3 4 5 6 7*
Fire Door Insulation, Metal/Wood Cladding	M-FDI-09	Y	N	x			1 2 3 4 5 6 7*
Concrete (Foundation), Gray, Cementitious	M-CON-10	Y	N	x			1 2 3 4 5 6 7*
Concrete (Entries), Gray, Cementitious	M-CON-11	Y	N	x			1 2 3 4 5 6 7*
Sealant (Doors, Fixtures), White, Pliable	M-SLT-15	Y	N	x			1 2 3 4 5 6 7*
Sink Acoustical Coating, White, Rough	M-SAC-16	Y	N	x			1 2 3 4 5 6 7*
Glazed Wall Tile, 4"x4", White, Smooth	M-GWT-20	Y	N	x			1 2 3 4 5 6 7*
Grout, Gray, Cementitious	M-GRT-22	Y	N	x			1 2 3 4 5 6 7*
Sealant (Duct), Gray, Pliable	M-SLT-27	Y	N	x			1 2 3 4 5 6 7*
Gypsum Wallboard, White, Chalky	M-GWB-28	Y	N	x			1 2 3 4 5 6 7*
Joint Compound, White, Chalky	S-JTC-29	Y	N	x			1 2 3 4 5 6 7*
Carpet (Self-Stick Squares), 2'x2', Blue, Fibrous, Multi-Colored Specks	M-CPT-30	Y	N	x			1 2 3 4 5 6 7*
Carpet (Cove), 4", Black, Fibrous	M-CPT-31	Y	N	x			1 2 3 4 5 6 7*
Adhesive, Cream, Pliable	M-ADH-32	Y	N	x			1 2 3 4 5 6 7*
Vinyl Composition Tile, 12"x12", Light Gray, Smooth, Gray Mottles	M-VCT-33	Y	N	x			1 2 3 4 5 6 7*
Mastic, Yellow, Tacky	M-MAS-34	Y	N	x			1 2 3 4 5 6 7*
Wallbase (Coved), 4", Black, Vinyl-Like	M-WAB-35	Y	N	x			1 2 3 4 5 6 7*
Adhesive, Cream, Pliable	M-ADH-36	Y	N	x			1 2 3 4 5 6 7*
Sealant (Windows), Black, Gummy	M-SLT-38	Y	N	x			1 2 3 4 5 6 7*
Brick, 4"x8", Red, Cementitious	M-BRK-41	Y	N	x			1 2 3 4 5 6 7*
Mortar, Gray, Cementitious	M-MRT-42	Y	N	x			1 2 3 4 5 6 7*
Built-Up Roofing, Black, Asphaltic, Gravel Cap	M-BUR-43	Y	N	x			1 2 3 4 5 6 7*
Mastic (Penetrations And Flashings), Black, Tar-Like	M-MAS-44	Y	N	x			1 2 3 4 5 6 7*

***Assessment Classifications**

1. Damaged or significantly damaged thermal system insulation ACBM.



6-MONTH SURVEILLANCE INSPECTION ASBESTOS-CONTAINING BUILDING MATERIALS

2. Damaged friable surfacing ACBM.
3. Significantly damaged friable surfacing ACBM.
4. Damaged or significantly damaged friable miscellaneous ACBM.
5. ACBM with potential for damage.
6. ACBM with potential for significant damage.
7. Any remaining friable ACBM or friable suspected ACBM.
- 8.




6-MONTH SURVEILLANCE INSPECTION ASBESTOS-CONTAINING BUILDING MATERIALS

School/Facility: Ben Furlong Education Center

Inspection Date: 05/01/2023

Building: Building C

Inspector: Zach Ridgeway Cert. No.: 4380-15665-030823 Signature: 

Material Description	Material Code	Material Observed		Material Condition Status		Material Condition Description (If Change Noted)	Assessment Classification
				Same	Changed		
Wallbase (Coved), 4", Dark Brown, Vinyl-Like	M-WAB-12	Y	N	x			1 2 3 4 5 6 7*
Adhesive, Cream, Pliable	M-ADH-13	Y	N	x			1 2 3 4 5 6 7*
Fire Door Insulation, Metal/Wood Cladding	M-FDI-14	Y	N	x			1 2 3 4 5 6 7*
Concrete (Foundation), Gray, Cementitious	M-CON-15	Y	N	x			1 2 3 4 5 6 7*
Concrete (Entries), Gray, Cementitious	M-CON-16	Y	N	x			1 2 3 4 5 6 7*
Sealant (Doors), White, Pliable	M-SLT-17	Y	N	x			1 2 3 4 5 6 7*
Tackable Wall Panel, Brown, Fibrous, Vinyl Cover	M-TWP-18	Y	N	x			1 2 3 4 5 6 7*
Window Glazing Putty, White, Brittle	M-WGP-19	Y	N	x			1 2 3 4 5 6 7*
Sealant (Duct), Gray, Pliable	M-SLT-20	Y	N	x			1 2 3 4 5 6 7*
Asphalt Prepared Roofing (Shingles), Black, Asphaltic, Gray Mineral Cap	M-APR-21	Y	N	x			1 2 3 4 5 6 7*
Vapor Barrier Felt, Black, Asphaltic	M-VBF-22	Y	N	x			1 2 3 4 5 6 7*
Mastic (Penetrations), Black, Tar-Like	M-MAS-23	Y	N	x			1 2 3 4 5 6 7*
Gypsum Wallboard, White, Chalky	M-GWB-24	Y	N	x			1 2 3 4 5 6 7*
Joint Compound, White, Chalky	S-JTC-25	Y	N	x			1 2 3 4 5 6 7*

***Assessment Classifications**

1. Damaged or significantly damaged thermal system insulation ACBM.
2. Damaged friable surfacing ACBM.
3. Significantly damaged friable surfacing ACBM.
4. Damaged or significantly damaged friable miscellaneous ACBM.
5. ACBM with potential for damage.
6. ACBM with potential for significant damage.
7. Any remaining friable ACBM or friable suspected ACBM.



6-MONTH SURVEILLANCE INSPECTION ASBESTOS-CONTAINING BUILDING MATERIALS

School/Facility: Ben Furlong Education Center

Inspection Date: 05/01/2023

Building: Building D

Inspector: Zach Ridgeway Cert. No.: 4380-15665-030823

Signature: 

Material Description	Material Code	Material Observed		Material Condition Status		Material Condition Description (If Change Noted)	Assessment Classification
				Same	Changed		
Wallbase (Coved), 4", Black, Vinyl-Like	M-WAB-09	Y	N	x			1 2 3 4 5 6 7*
Adhesive, Cream, Pliable	M-ADH-10	Y	N	x			1 2 3 4 5 6 7*
Sealant (Doors, Millwork), White, Pliable	M-SLT-11	Y	N	x			1 2 3 4 5 6 7*
Gypsum Wallboard, White, Chalky	M-GWB-15	Y	N	x			1 2 3 4 5 6 7*
Joint Compound, White, Chalky	S-JTC-16	Y	N	x			1 2 3 4 5 6 7*
Fire Door Insulation, Metal/Wood Cladding	M-FDI-17	Y	N	x			1 2 3 4 5 6 7*
Window Glazing Putty, Gray, Brittle	M-WGP-22	Y	N	x			1 2 3 4 5 6 7*
Sealant (Duct), Gray, Pliable	M-SLT-23	Y	N	x			1 2 3 4 5 6 7*
Gypsum Wallboard, White, Chalky	M-GWB-24	Y	N	x			1 2 3 4 5 6 7*
Joint Compound, White, Chalky	S-JTC-25	Y	N	x			1 2 3 4 5 6 7*
Concrete (Foundation), Gray, Cementitious	M-CON-26	Y	N	x			1 2 3 4 5 6 7*
Concrete (Entries), Gray, Cementitious	M-CON-27	Y	N	x			1 2 3 4 5 6 7*
Sealant (Fire Stop), Red, Pliable	M-SLT-28	Y	N	x			1 2 3 4 5 6 7*
Asphalt Prepared Roofing (Shingle), Black, Asphaltic, Gray Mineral Cap	M-APR-29	Y	N	x			1 2 3 4 5 6 7*
Vapor Barrier Felt, Black, Asphaltic	M-VBF-30	Y	N	x			1 2 3 4 5 6 7*
Mastic (Penetrations), Black, Tar-Like	M-MAS-31	Y	N	x			1 2 3 4 5 6 7*

*Assessment Classifications

1. Damaged or significantly damaged thermal system insulation ACBM.
2. Damaged friable surfacing ACBM.
3. Significantly damaged friable surfacing ACBM.
4. Damaged or significantly damaged friable miscellaneous ACBM.
5. ACBM with potential for damage.
6. ACBM with potential for significant damage.
7. Any remaining friable ACBM or friable suspected ACBM.




6-MONTH SURVEILLANCE INSPECTION ASBESTOS-CONTAINING BUILDING MATERIALS

School/Facility: Ben Furlong Education Center

Inspection Date: 05/01/2023

Building: Building E

Inspector: Zach Ridgeway Cert. No.: 4380-15665-030823 Signature: 

Material Description	Material Code	Material Observed		Material Condition Status		Material Condition Description (If Change Noted)	Assessment Classification
				Same	Changed		
Adhesive (Frp), Brown, Brittle	M-ADH-05	Y	N	x			1 2 3 4 5 6 7*
Vinyl Composition Tile, 12"X12", Green, Smooth, Dark Green Mottles	M-VCT-06	Y	N	x			1 2 3 4 5 6 7*
Vinyl Composition Tile (Pattern), 12"X12", Blue, Smooth, Black Mottles	M-VCT-07	Y	N	x			1 2 3 4 5 6 7*
Mastic, Yellow, Tacky	M-MAS-08	Y	N	x			1 2 3 4 5 6 7*
Wallbase (Coved), 4", Blue, Vinyl-Like	M-WAB-09	Y	N	x			1 2 3 4 5 6 7*
Adhesive, Cream, Pliable	M-ADH-10	Y	N	x			1 2 3 4 5 6 7*
Fire Door Insulation, Metal/Wood Cladding	M-FDI-11	Y	N	x			1 2 3 4 5 6 7*
Concrete (Foundation), Gray, Cementitious	M-CON-12	Y	N	x			1 2 3 4 5 6 7*
Concrete (Entries), Gray, Cementitious	M-CON-13	Y	N	x			1 2 3 4 5 6 7*
Sealant (Doors, Windows), White, Pliable	M-SLT-14	Y	N	x			1 2 3 4 5 6 7*
Sealant (Duct), Gray, Pliable	M-SLT-25	Y	N	x			1 2 3 4 5 6 7*
Coating, White, Pliable, Associated With Spray-Applied Foam Roofing	M-CTG-26	Y	N	x			1 2 3 4 5 6 7*
Mastic (Penetrations), Black, Tar-Like	M-MAS-27	Y	N	x			1 2 3 4 5 6 7*
Woven Duct Boot, 4", Black, Rubber-Like	M-WDB-28	Y	N	x			1 2 3 4 5 6 7*
Sealant (Windows), Gray, Pliable	M-SLT-29	Y	N	x			1 2 3 4 5 6 7*

***Assessment Classifications**

1. Damaged or significantly damaged thermal system insulation ACBM.
2. Damaged friable surfacing ACBM.
3. Significantly damaged friable surfacing ACBM.
4. Damaged or significantly damaged friable miscellaneous ACBM.
5. ACBM with potential for damage.
6. ACBM with potential for significant damage.
7. Any remaining friable ACBM or friable suspected ACBM.




6-MONTH SURVEILLANCE INSPECTION ASBESTOS-CONTAINING BUILDING MATERIALS

School/Facility: Ben Furlong Education Center

Inspection Date: 05/01/2023

Building: Building F

Inspector: Zach Ridgeway Cert. No.: 4380-15665-030823

Signature: 

Material Description	Material Code	Material Observed		Material Condition Status		Material Condition Description (If Change Noted)	Assessment Classification
				Same	Changed		
Concrete Masonry Unit, 2"X16", Gray, Cementitious	M-CMU-01	Y	N	x			1 2 3 4 5 6 7*
Concrete (Foundation), Gray, Cementitious	M-CON-04	Y	N	x			1 2 3 4 5 6 7*
Sealant (Doors, Windows, Millwork), White, Pliable	M-SLT-05	Y	N	x			1 2 3 4 5 6 7*
Fire Door Insulation, Metal/Wood Cladding	M-FDI-06	Y	N	x			1 2 3 4 5 6 7*
Spray-Applied Texture, White, Chalky	S-SAT-07	Y	N	x			1 2 3 4 5 6 7*
Gypsum Wallboard, White, Chalky	M-GWB-08	Y	N	x			1 2 3 4 5 6 7*
Joint Compound, White, Chalky	S-JTC-09	Y	N	x			1 2 3 4 5 6 7*
Wallbase (Coved), 4", Tan, Vinyl-Like	M-WAB-10	Y	N	x			1 2 3 4 5 6 7*
Adhesive, Cream, Pliable	M-ADH-11	Y	N	x			1 2 3 4 5 6 7*
Expansion Joint, Gray, Pliable	M-EXJ-12	Y	N	x			1 2 3 4 5 6 7*
Tackable Wall Panel, Brown, Fibrous, Vinyl Cover	M-TWP-13	Y	N	x			1 2 3 4 5 6 7*
Built-Up Roofing, Black, Asphaltic, Gray Mineral Cap	M-BUR-15	Y	N	x			1 2 3 4 5 6 7*
Mastic (Penetrations And Flashings), Black, Tar-Like	M-MAS-16	Y	N	x			1 2 3 4 5 6 7*
Sealant (Flashings), White, Pliable	M-SLT-17	Y	N	x			1 2 3 4 5 6 7*

***Assessment Classifications**

1. Damaged or significantly damaged thermal system insulation ACBM.
2. Damaged friable surfacing ACBM.
3. Significantly damaged friable surfacing ACBM.
4. Damaged or significantly damaged friable miscellaneous ACBM.
5. ACBM with potential for damage.
6. ACBM with potential for significant damage.
7. Any remaining friable ACBM or friable suspected ACBM.

D:\Shared\2020 Projects\10 ENV\KSD\20-265 6-Mo Surv Insp\2.0\2.3\2.3.1\Ben Furlong\6-MoSur-F.doc



6-MONTH SURVEILLANCE INSPECTION ASBESTOS-CONTAINING BUILDING MATERIALS

School/Facility: Ben Furlong Education Center

Inspection Date: 05/01/2023

Building: Building G

Inspector: Zach Ridgeway

Cert. No.: 4380-15665-030823

Signature: 

Material Description	Material Code	Material Observed		Material Condition Status		Material Condition Description (If Change Noted)	Assessment Classification
				Same	Changed		
Carpet, Green, Fibrous	M-CPT-04	Y	N	x			1 2 3 4 5 6 7*
Mastic, Yellow, Tacky	M-MAS-05	Y	N	x			1 2 3 4 5 6 7*
Wallbase (Coved), 4", Brown, Vinyl-Like	M-WAB-06	Y	N	x			1 2 3 4 5 6 7*
Adhesive, Cream, Pliable	M-ADH-07	Y	N	x			1 2 3 4 5 6 7*
Sealant (Doors, Windows), White, Pliable	M-SLT-08	Y	N	x			1 2 3 4 5 6 7*
Vinyl Composition Tile, 12"X12", Tan, Smooth, Tan Mottles	M-VCT-09	Y	N	x			1 2 3 4 5 6 7*
Mastic, Yellow, Tacky	M-MAS-10	Y	N	x			1 2 3 4 5 6 7*
Concrete (Foundation), Gray, Cementitious	M-CON-11	Y	N	x			1 2 3 4 5 6 7*
Built-Up Roofing, Black, Asphaltic, Gray Mineral Cap	M-BUR-12	Y	N	x			1 2 3 4 5 6 7*
Mastic (Penetrations), Black, Tar-Like	M-MAS-13	Y	N	x			1 2 3 4 5 6 7*
Cementitious Roof Shingles (S-Pattern), Red, Cementitious	M-CRS-14	Y	N	x			1 2 3 4 5 6 7*
Vapor Barrier Felt, Black, Asphaltic	M-VBF-15	Y	N	x			1 2 3 4 5 6 7*

***Assessment Classifications**

1. Damaged or significantly damaged thermal system insulation ACBM.
2. Damaged friable surfacing ACBM.
3. Significantly damaged friable surfacing ACBM.
4. Damaged or significantly damaged friable miscellaneous ACBM.
5. ACBM with potential for damage.
6. ACBM with potential for significant damage.
7. Any remaining friable ACBM or friable suspected ACBM.



**6-MONTH SURVEILLANCE INSPECTION
ASBESTOS-CONTAINING BUILDING MATERIALS**

School/Facility: Ben Furlong Education Center

Inspection Date: 05/01/2023

Building: Building M

Inspector: Zach Ridgeway Cert. No.: 4380-15665-030823 Signature:

Material Description	Material Code	Material Observed		Material Condition Status		Material Condition Description (If Change Noted)	Assessment Classification
				Same	Changed		
Fire Door Insulation, Metal/Wood Cladding	M-FDI-01	Y	N	x			1 2 3 4 5 6 7*
Concrete (Foundation), Gray, Cementitious	M-CON-02	Y	N	x			1 2 3 4 5 6 7*

***Assessment Classifications**

1. Damaged or significantly damaged thermal system insulation ACBM.
2. Damaged friable surfacing ACBM.
3. Significantly damaged friable surfacing ACBM.
4. Damaged or significantly damaged friable miscellaneous ACBM.
5. ACBM with potential for damage.
6. ACBM with potential for significant damage.
7. Any remaining friable ACBM or friable suspected ACBM.




6-MONTH SURVEILLANCE INSPECTION ASBESTOS-CONTAINING BUILDING MATERIALS

School/Facility: Ben Furlong Education Center

Inspection Date: 05/01/2023

Building: Building R

Inspector: Zach Ridgeway Cert. No.: 4380-15665-030823 Signature: 

Material Description	Material Code	Material Observed		Material Condition Status		Material Condition Description (If Change Noted)	Assessment Classification
				Same	Changed		
Concrete (Foundation), Gray, Cementitious	M·CON·03	Y	N	x			1 2 3 4 5 6 7*
Fire Door Insulation, Metal/Wood Cladding	M·FDI·04	Y	N	x			1 2 3 4 5 6 7*
Pipe End Sealant, White, Pliable	M·PES·05	Y	N	x			1 2 3 4 5 6 7*
Sealant (Equipment), Black, Gummy	M·SLT·06	Y	N	x			1 2 3 4 5 6 7*
Sealant (Doors, Fixtures), Gray, Pliable	M·SLT·07	Y	N	x			1 2 3 4 5 6 7*
Built-Up Roofing, Black, Asphaltic, Gravel Cap	M·BUR·08	Y	N	x			1 2 3 4 5 6 7*
Mastic (Penetrations And Flashings), Black, Tar-Like	M·MAS·09	Y	N	x			1 2 3 4 5 6 7*
Sealant (Duct), Gray, Pliable	M·SLT·10	Y	N	x			1 2 3 4 5 6 7*

***Assessment Classifications**

1. Damaged or significantly damaged thermal system insulation ACBM.
2. Damaged friable surfacing ACBM.
3. Significantly damaged friable surfacing ACBM.
4. Damaged or significantly damaged friable miscellaneous ACBM.
5. ACBM with potential for damage.
6. ACBM with potential for significant damage.
7. Any remaining friable ACBM or friable suspected ACBM.



**6-MONTH SURVEILLANCE INSPECTION
ASBESTOS-CONTAINING BUILDING MATERIALS**

School/Facility: Ben Furlong Education Center

Inspection Date: 05/01/2023

Building: Storage H

Inspector: Zach Ridgeway

Cert. No.: 4380-15665-030823

Signature:

Material Description	Material Code	Material Observed		Material Condition Status		Material Condition Description (If Change Noted)	Assessment Classification
				Same	Changed		
Asphalt Prepared Roofing (Shingles), Black, Asphaltic, Gray Mineral Cap	M-APR-01	Y	N	x			1 2 3 4 5 6 7*
Vapor Barrier Felt, Black, Asphaltic	M-VBF-02	Y	N	x			1 2 3 4 5 6 7*

***Assessment Classifications**

1. Damaged or significantly damaged thermal system insulation ACBM.
2. Damaged friable surfacing ACBM.
3. Significantly damaged friable surfacing ACBM.
4. Damaged or significantly damaged friable miscellaneous ACBM.
5. ACBM with potential for damage.
6. ACBM with potential for significant damage.
7. Any remaining friable ACBM or friable suspected ACBM.



**6-MONTH SURVEILLANCE INSPECTION
ASBESTOS-CONTAINING BUILDING MATERIALS**

School/Facility: Ben Furlong Education Center

Inspection Date: 05/01/2023

Building: Storage J

Inspector: Zach Ridgeway Cert. No.: 4380-15665-030823 Signature:

Material Description	Material Code	Material Observed		Material Condition Status		Material Condition Description (If Change Noted)	Assessment Classification
				Same	Changed		
Asphalt Prepared Roofing (Shingles), Black, Asphaltic, Gray Mineral Cap	M-APR-01	Y	N	x			1 2 3 4 5 6 7*
Vapor Barrier Felt, Black, Asphaltic	M-VBF-02	Y	N	x			1 2 3 4 5 6 7*
Concrete (Foundation), Gray, Cementitious	M-CON-03	Y	N	x			1 2 3 4 5 6 7*

***Assessment Classifications**

1. Damaged or significantly damaged thermal system insulation ACBM.
2. Damaged friable surfacing ACBM.
3. Significantly damaged friable surfacing ACBM.
4. Damaged or significantly damaged friable miscellaneous ACBM.
5. ACBM with potential for damage.
6. ACBM with potential for significant damage.
7. Any remaining friable ACBM or friable suspected ACBM.



**6-MONTH SURVEILLANCE INSPECTION
ASBESTOS-CONTAINING BUILDING MATERIALS**

School/Facility: Ben Furlong Education Center

Inspection Date: 05/01/2023

Building: Storage O

Inspector: Zach Ridgeway Cert. No.: 4380-15665-030823 Signature:

Material Description	Material Code	Material Observed		Material Condition Status		Material Condition Description (If Change Noted)	Assessment Classification
				Same	Changed		
Asphalt Prepared Roofing, Black, Asphaltic, Gray Mineral Cap	M-APR-01	Y	N	x			1 2 3 4 5 6 7*
Vapor Barrier Felt, Black, Asphaltic	M-VBF-02	Y	N	x			1 2 3 4 5 6 7*
Concrete (Foundation), Gray, Cementitious	M-CON-03	Y	N	x			1 2 3 4 5 6 7*

***Assessment Classifications**

1. Damaged or significantly damaged thermal system insulation ACBM.
2. Damaged friable surfacing ACBM.
3. Significantly damaged friable surfacing ACBM.
4. Damaged or significantly damaged friable miscellaneous ACBM.
5. ACBM with potential for damage.
6. ACBM with potential for significant damage.
7. Any remaining friable ACBM or friable suspected ACBM.




6-MONTH SURVEILLANCE INSPECTION ASBESTOS-CONTAINING BUILDING MATERIALS

School/Facility: Ben Furlong Education Center

Inspection Date: 05/01/2023

Building: Building T

Inspector: Zach Ridgeway Cert. No.: 4380-15665-030823 Signature: 

Material Description	Material Code	Material Observed		Material Condition Status		Material Condition Description (If Change Noted)	Assessment Classification
				Same	Changed		
Built-Up Roofing, Black, Asphaltic, Gray Mineral Cap	M·BUR·01	Y	N	x			1 2 3 4 5 6 7*
Mastic (Penetrations And Flashings), Black, Tar-Like	M·MAS·02	Y	N	x			1 2 3 4 5 6 7*
Sealant (Flashings), White, Pliable	M·SLT·03	Y	N	x			1 2 3 4 5 6 7*
Woven Duct Boot, 4", Black, Rubber-Like	M·WDB·04	Y	N	x			1 2 3 4 5 6 7*
Sealant (Duct), Gray, Pliable	M·SLT·05	Y	N	x			1 2 3 4 5 6 7*
Stucco, Gray, Cementitious	S·STU·10	Y	N	x			1 2 3 4 5 6 7*
Stucco, Gray, Cementitious	S·STU·11	Y	N	x			1 2 3 4 5 6 7*
Sealant (Doors, Windows, Expansion), Gray, Pliable	M·SLT·12	Y	N	x			1 2 3 4 5 6 7*
Concrete (Foundation), Gray, Cementitious	M·CON·13	Y	N	x			1 2 3 4 5 6 7*
Concrete, Gray, Cementitious	M·CON·14	Y	N	x			1 2 3 4 5 6 7*
Asphalt (Entries), Black, Asphaltic	M·ASP·15	Y	N	x			1 2 3 4 5 6 7*
Fire Door Insulation, Metal/Wood Cladding	M·FDI·16	Y	N	x			1 2 3 4 5 6 7*
Sealant (Doors, Windows, Fixtures), White, Pliable	M·SLT·20	Y	N	x			1 2 3 4 5 6 7*
Wallbase (Coved), 4", Brown, Vinyl-Like	M·WAB·21	Y	N	x			1 2 3 4 5 6 7*
Adhesive, Cream, Pliable	M·ADH·22	Y	N	x			1 2 3 4 5 6 7*
Vinyl Composition Tile, 12"X12", Tan, Smooth, Gray Mottles	M·VCT·23	Y	N	x			1 2 3 4 5 6 7*
Mastic, Yellow, Pliable	M·MAS·24	Y	N	x			1 2 3 4 5 6 7*
Vinyl Composition Tile, 12"X12", Light Brown, Smooth, Brown Mottles	M·VCT·32	Y	N	x			1 2 3 4 5 6 7*
Mastic, Yellow, Tacky	M·MAS·33	Y	N	x			1 2 3 4 5 6 7*
Carpet, Blue, Fibrous, Multi-Colored Specks	M·CPT·36	Y	N	x			1 2 3 4 5 6 7*
Mastic, Yellow, Tacky	M·MAS·37	Y	N	x			1 2 3 4 5 6 7*
Wallbase (Coved), 4", Blue, Vinyl-Like	M·WAB·38	Y	N	x			1 2 3 4 5 6 7*
Adhesive, Cream, Pliable	M·ADH·39	Y	N	x			1 2 3 4 5 6 7*
Glazed Wall Tile, 4"X4", White, Smooth	M·GWT·43	Y	N	x			1 2 3 4 5 6 7*
Glazed Wall Tile (Pattern), 4"X4", Black, Smooth	M·GWT·44	Y	N	x			1 2 3 4 5 6 7*
Grout, Gray, Cementitious	M·GRT·45	Y	N	x			1 2 3 4 5 6 7*
Quarry/Paver Tile, 8"X8", Black, Smooth, Gray Specks	M·QPT·46	Y	N	x			1 2 3 4 5 6 7*
Grout, Gray, Cementitious	M·GRT·47	Y	N	x			1 2 3 4 5 6 7*



6-MONTH SURVEILLANCE INSPECTION ASBESTOS-CONTAINING BUILDING MATERIALS

Material Description	Material Code	Material Observed		Material Condition Status		Material Condition Description (If Change Noted)	Assessment Classification
				Same	Changed		
Carpet, Gray, Fibrous, Multi-Colored Specks	M-CPT-48	Y	N	x			1 2 3 4 5 6 7*
Mastic, Yellow, Tacky	M-MAS-49	Y	N	x			1 2 3 4 5 6 7*
Vinyl Composition Tile, 12"X12", White, Smooth, Brown Mottles	M-VCT-50	Y	N	x			1 2 3 4 5 6 7*
Mastic, Yellow, Tacky	M-MAS-51	Y	N	x			1 2 3 4 5 6 7*

***Assessment Classifications**

1. Damaged or significantly damaged thermal system insulation ACBM.
2. Damaged friable surfacing ACBM.
3. Significantly damaged friable surfacing ACBM.
4. Damaged or significantly damaged friable miscellaneous ACBM.
5. ACBM with potential for damage.
6. ACBM with potential for significant damage.
7. Any remaining friable ACBM or friable suspected ACBM.




6-MONTH SURVEILLANCE INSPECTION ASBESTOS-CONTAINING BUILDING MATERIALS

School/Facility: Ben Furlong Education Center

Inspection Date: 05/01/2023

Building: Building W

Inspector: Zach Ridgeway Cert. No.: 4380-15665-030823 Signature: 

Material Description	Material Code	Material Observed		Material Condition Status		Material Condition Description (If Change Noted)	Assessment Classification
				Same	Changed		
Built-Up Roofing, Black, Asphaltic, Gray Mineral Cap	M-BUR-01	Y	N	x			1 2 3 4 5 6 7*
Mastic (Penetrations And Flashings), Black, Tar-Like	M-MAS-02	Y	N	x			1 2 3 4 5 6 7*
Coating, White, Pliable, Associated With Spray-Applied Foam Roofing	M-CTG-03	Y	N	x			1 2 3 4 5 6 7*
Mastic (Penetrations And Flashings), Black, Tar-Like	M-MAS-04	Y	N	x			1 2 3 4 5 6 7*
Sealant (Duct), Gray, Pliable	M-SLT-05	Y	N	x			1 2 3 4 5 6 7*
Expansion Joint, White, Pliable	M-EXJ-09	Y	N	x			1 2 3 4 5 6 7*
Stucco, Gray, Cementitious	S-STU-10	Y	N	x			1 2 3 4 5 6 7*
Concrete (Foundation), Gray, Cementitious	M-CON-11	Y	N	x			1 2 3 4 5 6 7*
Concrete (Entries), Gray, Cementitious	M-CON-12	Y	N	x			1 2 3 4 5 6 7*
Sealant (Doors), Gray, Pliable	M-SLT-13	Y	N	x			1 2 3 4 5 6 7*
Sealant (Doors, Windows), Black, Pliable	M-SLT-14	Y	N	x			1 2 3 4 5 6 7*
Fire Door Insulation, Metal/Wood Cladding	M-FDI-15	Y	N	x			1 2 3 4 5 6 7*
Vinyl Composition Tile, 12"X12", White, Smooth, Gray Mottles	M-VCT-22	Y	N	x			1 2 3 4 5 6 7*
Mastic, Yellow, Tacky	M-MAS-23	Y	N	x			1 2 3 4 5 6 7*
Sealant (Doors, Windows, Fixtures), White, Pliable	M-SLT-24	Y	N	x			1 2 3 4 5 6 7*
Wallbase (Coved), 4", Brown, Vinyl-Like	M-WAB-25	Y	N	x			1 2 3 4 5 6 7*
Adhesive, Cream, Pliable	M-ADH-26	Y	N	x			1 2 3 4 5 6 7*
Carpet (Self-Stick), Gray, Fibrous, Multi-Colored Specks	M-CPT-31	Y	N	x			1 2 3 4 5 6 7*
Wallbase (Coved), 4", Gray, Vinyl-Like	M-WAB-32	Y	N	x			1 2 3 4 5 6 7*
Adhesive, Cream, Pliable	M-ADH-33	Y	N	x			1 2 3 4 5 6 7*
Wallbase (Coved), 4", Black, Vinyl-Like	M-WAB-35	Y	N	x			1 2 3 4 5 6 7*
Adhesive, Cream, Pliable	M-ADH-36	Y	N	x			1 2 3 4 5 6 7*
Carpet, Brown, Fibrous, Multi-Colored Specks	M-CPT-41	Y	N	x			1 2 3 4 5 6 7*
Mastic, Yellow, Tacky	M-MAS-42	Y	N	x			1 2 3 4 5 6 7*
Spray-Applied Texture, White, Chalky	S-SAT-44	Y	N	x			1 2 3 4 5 6 7*
Gypsum Wallboard, White, Chalky	M-GWB-45	Y	N	x			1 2 3 4 5 6 7*
Joint Compound, White, Chalky	S-JTC-46	Y	N	x			1 2 3 4 5 6 7*



6-MONTH SURVEILLANCE INSPECTION ASBESTOS-CONTAINING BUILDING MATERIALS

Material Description	Material Code	Material Observed		Material Condition Status		Material Condition Description (If Change Noted)	Assessment Classification
				Same	Changed		
Quarry/Paver Tile, 18"X18", White, Smooth	M-QPT-47	Y	N	x			1 2 3 4 5 6 7*
Grout, Gray, Cementitious	M-GRT-48	Y	N	x			1 2 3 4 5 6 7*
Sealant (Doors, Windows, Millwork, Fixtures), White, Pliable	M-SLT-53	Y	N	x			1 2 3 4 5 6 7*
Sealant (Windows), Black, Pliable	M-SLT-54	Y	N	x			1 2 3 4 5 6 7*
Asbestos Cement Board, Gray, Cementitious, Smooth	M-ACB-58	Y	N	x			1 2 3 4 5 6 7*

*Assessment Classifications

1. Damaged or significantly damaged thermal system insulation ACBM.
2. Damaged friable surfacing ACBM.
3. Significantly damaged friable surfacing ACBM.
4. Damaged or significantly damaged friable miscellaneous ACBM.
5. ACBM with potential for damage.
6. ACBM with potential for significant damage.
7. Any remaining friable ACBM or friable suspected ACBM.

6-MONTH SURVEILLANCE INSPECTION TABLE

IN-PLACE ASBESTOS-CONTAINING MATERIALS

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
M-FDI-07	M	Fire Door Insulation, Metal/Wood Cladding	Lobby	Assumed	NF	G	1,134	SF
			Receiving					
			Open Office 02					
			Vault 02					
			Hall 04					
			Open Court					
			Hall 05					
			Electrical 02					
			Electrical 03					
			Open Office 03					
			Storage 01					
			Hall 03					
			Men's Dress					
			Women's Dress					
			Women's Restroom 02					
			Men's Restroom 02					
			Janitor 02					
			Lounge					
			Hall 02					
			Phone 01					
			Electrical 01					
			Janitor 01					
			Kitchen					
			Vestibule					
			Board Room					
			Corridor 01					
			Open Office 06					
			Storage 03					

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
			Records					
			Electrical 05					
			Open Office 05					
			Hall 08					
			Women's Restroom 04					
			Men's Restroom 04					
			Janitor 03					
			Patio 02					
			Phone 02					
			Electrical 04					
			Choral					
			Conference 04					
			Patio 01					
			Open Office 04					
			Exterior					
M-WAB-08	M	Wallbase (Carpet), 4", Black, Fibrous	Reception	Assumed	NF	G	1,000	SF
			Waiting 01					
			Office					
			Office 02					
			Office 03					
			Office 04					
			Conference 02					
			Open Office 02					
			Office 05					
			Hall 05					
			Open Office 03					
			Office 06					
			Office 07					
			Conference 03					
			Office 08					
			Office 09					

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
			Office 10					
			Hall 01					
			Board Room					
			Corridor 01					
			Waiting 02					
			Storage 04					
			Break-Out 04					
			Break-Out 03					
			Video					
			Break-Out 02					
			Break-Out 01					
			Training Room					
			Open Office 06					
			Office 24					
			Office 23					
			Office 22					
			Storage 03					
			Hall 07					
			Office 21					
			Records					
			Office 20					
			Office 19					
			Office 18					
			Office 17					
			Conference 05					
			Office 16					
			Copy 02					
			Open Office 05					
			Superintendent Vestibule					
			Superintendent					
			Board Office					
			Conference 04					
			Storage 02					

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
			Office 15					
			Office 14					
			Office 11					
			Office 12					
			Office 13					
			Open Office 04					
M-ADH-09	M	Adhesive, Blue, Pliable	Reception	Assumed	NF	G	1,000	SF
			Waiting 01					
			Office					
			Office 02					
			Office 03					
			Office 04					
			Conference 02					
			Open Office 02					
			Office 05					
			Hall 05					
			Open Office 03					
			Office 06					
			Office 07					
			Conference 03					
			Office 08					
			Office 09					
			Office 10					
			Hall 01					
			Board Room					
			Corridor 01					
			Waiting 02					
			Storage 04					
			Break-Out 04					
			Break-Out 03					
			Video					
			Break-Out 02					

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
			Break-Out 01					
			Training Room					
			Open Office 06					
			Office 24					
			Office 23					
			Office 22					
			Storage 03					
			Hall 07					
			Office 21					
			Records					
			Office 20					
			Office 19					
			Office 18					
			Office 17					
			Conference 05					
			Office 16					
			Copy 02					
			Open Office 05					
			Superintendent Vestibule					
			Superintendent					
			Board Office					
			Conference 04					
			Storage 02					
			Office 15					
			Office 14					
			Office 11					
			Office 12					
			Office 13					
			Open Office 04					
M-SLT-10	M	Sealant (Doors, Windows, Millwork, Fixtures), White, Pliable	Receiving	Assumed	NF	G	100	SF
			Waiting 01					

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
			Open Office 01					
			Office					
			Office 02					
			Office 03					
			Office 04					
			Conference 02					
			Hall 06					
			Vault 01					
			Open Office 02					
			Office 05					
			Vault 02					
			Copy 01					
			Hall 04					
			Hall 05					
			Electrical 02					
			Electrical 03					
			Open Office 03					
			Office 06					
			Office 07					
			Conference 03					
			Office 08					
			Office 09					
			Storage 01					
			Hall 03					
			Men's Dress					
			Men's Restroom 03					
			Women's Dress					
			Women's Restroom 03					
			Multi-Use					
			Women's Restroom 02					
			Men's Restroom 02					
			Lounge					
			Hall 02					

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
			Elevator Equipment					
			Phone 01					
			Electrical 01					
			Janitor 01					
			Kitchen					
			Vestibule					
			Men's Restroom 01					
			Women's Restroom 01					
			Hall 01					
			Conference 01					
			Board Room					
			Table Storage					
			Corridor 01					
			Waiting 02					
			Storage 04					
			Break-Out 04					
			Break-Out 03					
			Video					
			Break-Out 02					
			Break-Out 01					
			Training Room					
			Open Office 06					
			Office 24					
			Office 23					
			Office 22					
			Storage 03					
			Hall 07					
			Office 21					
			Records					
			Electrical 05					
			Office 20					
			Office 19					
			Office 18					

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
			Office 17					
			Conference 05					
			Office 16					
			Copy Storage					
			Copy 02					
			Open Office 05					
			Hall 08					
			Women's Restroom 04					
			Men's Restroom 04					
			Choral					
			Superintendent Restroom					
			Superintendent Vestibule					
			Superintendent					
			Board Office					
			Conference 04					
			Office 15					
			Office 14					
			Office 11					
			Office 12					
			Office 13					
			Open Office 04					
M-TWP-11	M	Tackable Wall Panel, Brown, Fibrous, Vinyl Cover, Mechanically Attached	Lounge	Assumed	NF	G	100	SF
S-SAT-12	S	Spray-Applied Texture, White, Chalky	Men's Dress	Assumed	NF	G	3,300	SF
			Men's Restroom 03					
			Women's Dress					
			Women's Restroom 03					
			Women's Restroom 02					
			Men's Restroom 02					
			Janitor 02					

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
			Men's Restroom 01					
			Women's Restroom 01					
			Women's Restroom 04					
			Men's Restroom 04					
			Janitor 03					
			Superintendent Restroom					
M-GWB-13	M	Gypsum Wallboard, White, Chalky	Men's Dress	Assumed	NF	G	3,300	SF
			Men's Restroom 03					
			Women's Dress					
			Women's Restroom 03					
			Women's Restroom 02					
			Men's Restroom 02					
			Janitor 02					
			Men's Restroom 01					
			Women's Restroom 01					
			Women's Restroom 04					
			Men's Restroom 04					
			Janitor 03					
			Superintendent Restroom					
S-JTC-14	S	Joint Compound, White, Chalky	Men's Dress	Assumed	NF	G	330	SF
			Men's Restroom 03					
			Women's Dress					
			Women's Restroom 03					
			Women's Restroom 02					
			Men's Restroom 02					
			Janitor 02					
			Men's Restroom 01					
			Women's Restroom 01					
			Women's Restroom 04					
			Men's Restroom 04					
			Janitor 03					

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
			Superintendent Restroom					
M-GWT-15	M	Glazed Wall Tile, 2"X2", Tan, Smooth	Men's Restroom 03	Assumed	NF	G	4,000	SF
			Women's Restroom 03					
			Women's Restroom 02					
			Men's Restroom 02					
			Janitor 02					
			Men's Restroom 01					
			Women's Restroom 01					
			Women's Restroom 04					
			Men's Restroom 04					
			Janitor 03					
M-GWT-16	M	Glazed Wall Tile (Pattern), 4"X4", Blue, Smooth	Women's Restroom 02	Assumed	NF	G	500	SF
			Men's Restroom 02					
			Janitor 02					
			Men's Restroom 01					
			Women's Restroom 01					
			Women's Restroom 04					
			Men's Restroom 04					
			Janitor 03					
M-GRT-17	M	Grout, Gray, Cementitious	Men's Restroom 03	Assumed	NF	G	450	SF
			Women's Restroom 03					
			Women's Restroom 02					
			Men's Restroom 02					
			Janitor 02					
			Men's Restroom 01					
			Women's Restroom 01					
			Women's Restroom 04					
			Men's Restroom 04					
			Janitor 03					

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
M-CMT-18	M	Ceramic Mosaic Tile, 2"X2", Pink, Smooth	Men's Dress	Assumed	NF	G	2,200	SF
			Men's Restroom 03					
			Women's Dress					
			Women's Restroom 03					
			Women's Restroom 02					
			Men's Restroom 02					
			Janitor 02					
			Men's Restroom 01					
			Women's Restroom 01					
			Women's Restroom 04					
			Men's Restroom 04					
			Janitor 03					
M-GRT-19	M	Grout, Gray, Cementitious	Men's Dress	Assumed	NF	G	220	SF
			Men's Restroom 03					
			Women's Dress					
			Women's Restroom 03					
			Women's Restroom 02					
			Men's Restroom 02					
			Janitor 02					
			Men's Restroom 01					
			Women's Restroom 01					
			Women's Restroom 04					
			Men's Restroom 04					
M-SAC-20	M	Sink Acoustical Coating, White, Rough	Kitchen	Assumed	NF	G	6	SF
			Conference 01					
M-QPT-24	M	Quarry/Paver Tile, 4"X4", Gray, Smooth	Lobby	Assumed	NF	G	1,000	SF

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
			Hall 05					
			Open Office 03					
			Hall 02					
			Vestibule					
			Elevator					
			Landing					
			Hall 08					
M-QPT-25	M	Quarry/Paver Tile, 4"X4", Tan, Smooth, Black And White Specks	Lobby	Assumed	NF	G	1,000	SF
			Hall 05					
			Open Office 03					
			Hall 02					
			Vestibule					
			Elevator					
			Landing					
			Hall 08					
M-GRT-26	M	Grout, Gray, Cementitious	Lobby	Assumed	NF	G	200	SF
			Hall 05					
			Open Office 03					
			Hall 02					
			Vestibule					
			Elevator					
			Landing					
			Hall 08					
M-VCT-28	M	Vinyl Composition Tile, 12"X12", Tan, Smooth, Brown And White Mottles	Vault 01	Assumed	NF	G	3,000	SF
			Vault 02					
			Electrical 02					
			Storage 01					
			Hall 03					

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
			Lounge					
			Elevator Equipment					
			Phone 01					
			Electrical 01					
			Kitchen					
			Phone 02					
			Electrical 04					
			Choral					
M-VCT-29	M	Vinyl Composition Tile, 12"X12", Tan, Smooth, Black Spots	Lounge	Assumed	NF	G	300	SF
			Kitchen					
M-MAS-30	M	Mastic, Yellow, Tacky	Vault 01	Assumed	NF	G	3,300	SF
			Vault 02					
			Electrical 02					
			Storage 01					
			Hall 03					
			Lounge					
			Elevator Equipment					
			Phone 01					
			Electrical 01					
			Kitchen					
			Phone 02					
			Electrical 04					
			Choral					
M-SLT-33	M	Sealant (Fire Stop), Red, Pliable	Electrical 01	Assumed	NF	G	2	SF
S-PLA-34	S	Plaster, Gray, Cementitious	Lobby	Assumed	NF	G	500	SF
			Hall 04					
			Hall 05					
			Open Office 03					

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
			Landing					
			Open Office 06					
			Hall 07					
			Open Office 05					
			Hall 08					
			Open Office 04					
M-SLT-35	M	Sealant (Doors, Windows), Black, Gummy	Receiving	Assumed	NF	G	50	SF
			Exterior					
M-CPT-37	M	Carpet, Blue, Fibrous, Brown And White Spots	Electrical 03	Assumed	NF	G	300	SF
			Copy Storage					
M-MAS-38	M	Mastic, Yellow, Tacky	Electrical 03	Assumed	NF	G	300	SF
			Copy Storage					
M-CMU-39	M	Concrete Masonry Unit, 8"X16", Gray, Cementitious	Electrical 03	Assumed	NF	G	300	SF
			Electrical 05					
M-MRT-40	M	Mortar, Gray, Cementitious	Electrical 03	Assumed	NF	G	30	SF
			Electrical 05					
M-CPT-41	M	Carpet, Purple, Fibrous, Gray Specks	Multi-Use	Assumed	NF	G	600	SF
M-MAS-42	M	Mastic, Yellow, Tacky	Multi-Use	Assumed	NF	G	600	SF
M-VST-43	M	Vinyl Stair Tread, 12"X48", Blue, Circle Pattern	Stair Well	Assumed	NF	G	100	SF
M-VCT-44	M	Vinyl Composition Tile, 18"X18", Blue, Circle Pattern	Stair Well	Assumed	NF	G	80	SF

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
M-MAS-45	M	Mastic, Yellow, Tacky	Stair Well	Assumed	NF	G	180	SF
M-WAB-46	M	Wallbase (Coved), 4", Gray, Vinyl-Like	Stair Well	Assumed	NF	G	30	SF
M-ADH-47	M	Adhesive, Cream, Pliable	Stair Well	Assumed	NF	G	30	SF
M-BUR-48	M	Built-Up Roofing, Black, Asphaltic, Gravel Cap	Roof	Assumed	NF	G	36,000	SF
M-MAS-49	M	Mastic, (Penetrations And Flashings), Black, Tar-Like	Roof	Assumed	NF	G	1,500	SF
M-SLT-50	M	Sealant (Flashings), Black, Pliable	Roof	Assumed	NF	G	50	SF
M-CON-54	M	Concrete (Entries), Gray, Cementitious	Exterior	Assumed	NF	G	700	SF
M-SLT-55	M	Sealant (Doors, Windows), Gray, Pliable	Exterior	Assumed	NF	G	5	SF
M-GAS-56	M	Gaskets, 1"-3", Black/Green, Paper-Like	Lobby	Assumed	NF	G	10	SF
			Reception					
			Receiving					
			Waiting 01					
			Open Office 01					
			Office					
			Office 02					
			Office 03					
			Office 04					
			Conference 02					
			Hall 06					
			Vault 01					
			Open Office 02					
			Office 05					

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
			Vault 02					
			Copy 01					
			Hall 04					
			Open Court					
			Hall 05					
			Stair Well					
			Electrical 02					
			Electrical 03					
			Book					
			Open Office 03					
			Office 06					
			Office 07					
			Conference 03					
			Office 08					
			Office 09					
			Office 10					
			Storage 01					
			Hall 03					
			Men's Dress					
			Men's Restroom 03					
			Women's Dress					
			Women's Restroom 03					
			Multi-Use					
			Women's Restroom 02					
			Men's Restroom 02					
			Janitor 02					
			Lounge					
			Hall 02					
			Elevator Equipment					
			Phone 01					
			Electrical 01					
			Janitor 01					
			Kitchen					

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
			Vestibule					
			Elevator					
			Men's Restroom 01					
			Women's Restroom 01					
			Hall 01					
			Conference 01					
			Board Room					
			Table Storage					
			Corridor 01					
			Landing					
			Waiting 02					
			Storage 04					
			Break-Out 04					
			Break-Out 03					
			Video					
			Break-Out 02					
			Break-Out 01					
			Training Room					
			Open Office 06					
			Office 24					
			Office 23					
			Office 22					
			Storage 03					
			Hall 07					
			Open Court					
			Office 21					
			Records					
			Electrical 05					
			Office 20					
			Office 19					
			Office 18					
			Office 17					
			Conference 05					

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
			Office 16					
			Copy Storage					
			Copy 02					
			Open Office 05					
			Hall 08					
			Women's Restroom 04					
			Men's Restroom 04					
			Janitor 03					
			Patio 02					
			Phone 02					
			Electrical 04					
			Choral					
			Superintendent Restroom					
			Superintendent Vestibule					
			Superintendent					
			Board Office					
			Conference 04					
			Patio 01					
			Storage 02					
			Office 15					
			Office 14					
			Office 11					
			Office 12					
			Office 13					
			Open Office 04					

6-MONTH SURVEILLANCE INSPECTION TABLE

IN-PLACE ASBESTOS-CONTAINING MATERIALS

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
M-CPT-05	M	Carpet, Gray, Fibrous	Instructional Material Center	Assumed	NF	G	1,500	SF
			Hall 1					
			Hall 2					
M-MAS-06	M	Mastic, Yellow, Tacky	Instructional Material Center	Assumed	NF	G	1,500	SF
			Hall 1					
			Hall 2					
M-WAB-07	M	Wallbase (Coved), 4", Blue, Vinyl-Like	Instructional Material Center	Assumed	NF	G	80	SF
			Hall 1					
			Hall 2					
M-ADH-08	M	Adhesive, Cream, Pliable	Instructional Material Center	Assumed	NF	G	80	SF
			Hall 1					
			Hall 2					
M-FDI-09	M	Fire Door Insulation, Metal/Wood Cladding	Server Room	Assumed	NF	G	147	SF
			IT Room					
			Instructional Material Center					
			Hall 1					
			Hall 2					
			Women's Restroom 1					
			Men's Restroom 2					
			Exterior					
M-CON-10	M	Concrete (Foundation), Gray, Cementitious	Server Room	Assumed	NF	G	3,000	SF
			IT Room					

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
			Instructional Material Center					
			Hall 1					
			Hall 2					
			Men's Restroom 1					
			Women's Restroom 1					
			Men's Restroom 2					
			Women's Restroom 2					
			Exterior					
M-CON-11	M	Concrete (Entries), Gray, Cementitious	Exterior	Assumed	NF	G	300	SF
			Women's Restroom 1					
			Men's Restroom 2					
			Women's Restroom 2					
M-SLT-15	M	Sealant (Doors, Fixtures), White, Pliable	Server Room	Assumed	NF	G	14	SF
			IT Room					
			Instructional Material Center					
			Hall 1					
			Hall 2					
			Men's Restroom 1					
			Women's Restroom 1					
			Men's Restroom 2					
			Women's Restroom 2					
M-SAC-16	M	Sink Acoustical Coating, White, Rough	Hall 1	Assumed	NF	G	2	SF
M-GWT-20	M	Glazed Wall Tile, 4"X4", White, Smooth	Men's Restroom 1	Assumed	NF	G	800	SF
			Women's Restroom 1					
			Men's Restroom 2					
			Women's Restroom 2					

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
M-GRT-22	M	Grout, Gray, Cementitious	Men's Restroom 1	Assumed	NF	G	85	SF
			Women's Restroom 1					
			Men's Restroom 2					
			Women's Restroom 2					
M-SLT-27	M	Sealant (Duct), Gray, Pliable	Instructional Material Center	Assumed	NF	G	50	SF
			Hall 1					
			Hall 2					
			Men's Restroom 1					
			Women's Restroom 1					
			Men's Restroom 2					
			Women's Restroom 2					
			Exterior					
M-GWB-28	M	Gypsum Wallboard, White, Chalky	Exterior	Assumed	NF	G	1,300	SF
S-JTC-29	S	Joint Compound, White, Chalky	Exterior	Assumed	NF	G	130	SF
M-CPT-30	M	Carpet (Self-Stick Squares), 2'x2', Blue, Fibrous, Multi-Colored Specks	IT Room	Assumed	NF	G	600	SF
M-CPT-31	M	Carpet (Cove), 4", Black, Fibrous	IT Room	Assumed	NF	G	35	SF
M-ADH-32	M	Adhesive, Cream, Pliable	IT Room	Assumed	NF	G	35	SF
M-VCT-33	M	Vinyl Composition Tile, 12"X12", Light Gray, Smooth, Gray Mottles	Server Room	Assumed	NF	G	375	SF
M-MAS-34	M	Mastic, Yellow, Tacky	Server Room	Assumed	NF	G	375	SF
M-WAB-35	M	Wallbase (Coved), 4", Black, Vinyl- Like	Server Room	Assumed	NF	G	30	SF

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
M-ADH-36	M	Adhesive, Cream, Pliable	Server Room	Assumed	NF	G	30	SF
M-SLT-38	M	Sealant (Windows), Black, Gummy	IT Room	Assumed	NF	G	1	SF
M-BRK-41	M	Brick, 4"X8", Red, Cementitious	Exterior	Assumed	NF	G	1,400	SF
M-MRT-42	M	Mortar, Gray, Cementitious	Exterior	Assumed	NF	G	140	SF
M-BUR-43	M	Built-Up Roofing, Black, Asphaltic, Gravel Cap	Roof	Assumed	NF	G	3,000	SF
M-MAS-44	M	Mastic (Penetrations And Flashings), Black, Tar-Like	Roof	Assumed	NF	G	150	SF

6-MONTH SURVEILLANCE INSPECTION TABLE

IN-PLACE ASBESTOS-CONTAINING MATERIALS

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
M-WAB-12	M	Wallbase (Coved), 4", Dark Brown, Vinyl-Like	Room 01	Assumed	NF	G	75	SF
			Room 02					
M-ADH-13	M	Adhesive, Cream, Pliable	Room 01	Assumed	NF	G	75	SF
			Room 02					
M-FDI-14	M	Fire Door Insulation, Metal/Wood Cladding	Room 01	Assumed	NF	G	63	SF
			Room 02					
			Exterior					
M-CON-15	M	Concrete (Foundation), Gray, Cementitious	Room 01	Assumed	NF	G	2,700	SF
			Room 02					
M-CON-16	M	Concrete (Entries), Gray, Cementitious	Exterior	Assumed	NF	G	600	SF
M-SLT-17	M	Sealant (Doors), White, Pliable	Room 01	Assumed	NF	G	3	SF
			Room 02					
M-TWP-18	M	Tackable Wall Panel, Brown, Fibrous, Vinyl Cover	Room 01	Assumed	NF	G	750	SF
M-WGP-19	M	Window Glazing Putty, White, Brittle	Room 01	Assumed	NF	G	20	SF
			Room 02					
M-SLT-20	M	Sealant (Duct), Gray, Pliable	Room 01	Assumed	NF	G	50	SF
			Room 02					

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
M-APR-21	M	Asphalt Prepared Roofing (Shingles), Black, Asphaltic, Gray Mineral Cap	Roof	Assumed	NF	G	2,700	SF
M-VBF-22	M	Vapor Barrier Felt, Black, Asphaltic	Roof	Assumed	NF	G	2,700	SF
M-MAS-23	M	Mastic (Penetrations), Black, Tar- Like	Roof	Assumed	NF	G	50	SF
M-GWB-24	M	Gypsum Wallboard, White, Chalky	Exterior	Assumed	NF	G	1,200	SF
S-JTC-25	S	Joint Compound, White, Chalky	Exterior	Assumed	NF	G	120	SF

6-MONTH SURVEILLANCE INSPECTION TABLE

IN-PLACE ASBESTOS-CONTAINING MATERIALS

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
M-WAB-09	M	Wallbase (Coved), 4", Black, Vinyl-Like	Room 01	Assumed	NF	G	150	SF
			Room 01A					
			Room 02					
			Room 03					
M-ADH-10	M	Adhesive, Cream, Pliable	Room 01	Assumed	NF	G	150	SF
			Room 01A					
			Room 02					
			Room 03					
M-SLT-11	M	Sealant (Doors, Millwork), White, Pliable	Room 01	Assumed	NF	G	8	SF
			Room 02					
			Room 03					
			Men's Restroom					
			Janitor					
			Women's Restroom					
M-GWB-15	M	Gypsum Wallboard, White, Chalky	Room 01	Assumed	NF	G	300	SF
			Room 01A					
S-JTC-16	S	Joint Compound, White, Chalky	Room 01	Assumed	NF	G	30	SF
			Room 01A					
M-FDI-17	M	Fire Door Insulation, Metal/Wood Cladding	Room 01	Assumed	NF	G	126	SF
			Room 02					
			Room 03					

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
			Men's Restroom					
			Janitor					
			Women's Restroom					
			Exterior					
M-WGP-22	M	Window Glazing Putty, Gray, Brittle	Men's Restroom	Assumed	NF	G	4	SF
			Women's Restroom					
M-SLT-23	M	Sealant (Duct), Gray, Pliable	Room 01	Assumed	NF	G	50	SF
			Room 01A					
			Room 02					
			Room 03					
			Men's Restroom					
			Janitor					
			Women's Restroom					
			Exterior					
M-GWB-24	M	Gypsum Wallboard, White, Chalky	Exterior	Assumed	NF	G	1,000	SF
S-JTC-25	S	Joint Compound, White, Chalky	Exterior	Assumed	NF	G	100	SF
M-CON-26	M	Concrete (Foundation), Gray, Cementitious	Room 01	Assumed	NF	G	2,200	SF
			Room 01A					
			Room 02					
			Room 03					
			Men's Restroom					
			Janitor					
			Women's Restroom					
			Exterior					

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
M·CON·27	M	Concrete (Entries), Gray, Cementitious	Exterior	Assumed	NF	G	700	SF
M·SLT·28	M	Sealant (Fire Stop), Red, Pliable	Janitor	Assumed	NF	G	10	SF
M·APR·29	M	Asphalt Prepared Roofing (Shingle), Black, Asphaltic, Gray Mineral Cap	Roof	Assumed	NF	G	2,200	SF
M·VBF·30	M	Vapor Barrier Felt, Black, Asphaltic	Roof	Assumed	NF	G	2,200	SF
M·MAS·31	M	Mastic (Penetrations), Black, Tar-Like	Roof	Assumed	NF	G	100	SF
M·GWB·32	M	Gypsum Wallboard, White, Chalky	Men's Restroom	Assumed	NF	G	140	SF
			Janitor					
S·JTC·33	S	Joint Compound, White, Chalky	Men's Restroom	Assumed	NF	G	14	SF
			Janitor					

6-MONTH SURVEILLANCE INSPECTION TABLE

IN-PLACE ASBESTOS-CONTAINING MATERIALS

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
M-ADH-05	M	Adhesive (Frp), Brown, Brittle	Storage	Assumed	NF	G	50	SF
M-VCT-06	M	Vinyl Composition Tile, 12"X12", Green, Smooth, Dark Green Mottles	Office	Assumed	NF	G	1,400	SF
			Print Shop					
			Storage					
			Unisex Restroom					
M-VCT-07	M	Vinyl Composition Tile (Pattern), 12"X12", Blue, Smooth, Black Mottles	Print Shop	Assumed	NF	G	300	SF
			Storage					
			Unisex Restroom					
M-MAS-08	M	Mastic, Yellow, Tacky	Print Shop	Assumed	NF	G	2,000	SF
			Storage					
			Unisex Restroom					
M-WAB-09	M	Wallbase (Coved), 4", Blue, Vinyl- Like	Office	Assumed	NF	G	125	SF
			Print Shop					
			Storage					
M-ADH-10	M	Adhesive, Cream, Pliable	Office	Assumed	NF	G	125	SF
			Print Shop					
			Storage					
M-FDI-11	M	Fire Door Insulation, Metal/Wood Cladding	Print Shop	Assumed	NF	G	126	SF
			Storage					

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
			Data Processing					
			Exterior					
M-CON-12	M	Concrete (Foundation), Gray, Cementitious	Office	Assumed	NF	G	2,200	SF
			Print Shop					
			Storage					
			Unisex Restroom					
			Computers					
			Data Processing					
			Exterior					
M-CON-13	M	Concrete (Entries), Gray, Cementitious	Exterior	Assumed	NF	G	750	SF
M-SLT-14	M	Sealant (Doors, Windows), White, Pliable	Office	Assumed	NF	G	10	SF
			Print Shop					
			Storage					
			Unisex Restroom					
			Computers					
			Data Processing					
M-SLT-25		Sealant (Duct), Gray, Pliable	Exterior	Assumed	NF	G	10	SF
M-CTG-26	M	Coating, White, Pliable, Associated With Spray-Applied Foam Roofing	Roof	Assumed	NF	G	2,200	SF
M-MAS-27	M	Mastic (Penetrations), Black, Tar- Like	Roof	Assumed	NF	G	50	SF
M-WDB-28	M	Woven Duct Boot, 4", Black, Rubber-Like	Exterior	Assumed	NF	G	5	SF
M-SLT-29	M	Sealant (Windows), Gray, Pliable	Exterior	Assumed	NF	G	1	SF

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA

6-MONTH SURVEILLANCE INSPECTION TABLE

IN-PLACE ASBESTOS-CONTAINING MATERIALS

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
M-CMU-01	M	Concrete Masonry Unit, 2"X16", Gray, Cementitious	Roof	Assumed	NF	G	700	SF
M-CON-04	M	Concrete (Foundation), Gray, Cementitious	Storage 1	Assumed	NF	G	800	SF
			Storage 2					
			Exterior					
M-SLT-05	M	Sealant (Doors, Windows, Millwork), White, Pliable	Storage 1	Assumed	NF	G	5	SF
			Storage 2					
M-FDI-06	M	Fire Door Insulation, Metal/Wood Cladding	Storage 1	Assumed	NF	G	42	SF
			Storage 2					
			Exterior					
S-SAT-07	S	Spray-Applied Texture, White, Chalky	Storage 1	Assumed	NF	G	400	SF
			Storage 2					
M-GWB-08	M	Gypsum Wallboard, White, Chalky	Storage 1	Assumed	NF	G	400	SF
			Storage 2					
S-JTC-09	S	Joint Compound, White, Chalky	Storage 1	Assumed	NF	G	40	SF
			Storage 2					
M-WAB-10	M	Wallbase (Coved), 4", Tan, Vinyl- Like	Storage 1	Assumed	NF	G	50	SF
			Storage 2					
M-ADH-11	M	Adhesive, Cream, Pliable	Storage 1	Assumed	NF	G	50	SF

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
			Storage 2					
M-EXJ-12	M	Expansion Joint, Gray, Pliable	Exterior	Assumed	NF	G	10	SF
			Roof					
M-TWP-13	M	Tackable Wall Panel, Brown, Fibrous, Vinyl Cover	Storage 2	Assumed	NF	G	100	SF
M-BUR-15	M	Built-Up Roofing, Black, Asphaltic, Gray Mineral Cap	Roof	Assumed	NF	G	800	SF
M-MAS-16	M	Mastic (Penetrations And Flashings), Black, Tar-Like	Roof	Assumed	NF	G	50	SF
M-SLT-17	M	Sealant (Flashings), White, Pliable	Roof	Assumed	NF	G	10	SF

6-MONTH SURVEILLANCE INSPECTION TABLE

IN-PLACE ASBESTOS-CONTAINING MATERIALS

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
M-CPT-04	M	Carpet, Green, Fibrous	Office	Assumed	NF	G	200	SF
M-MAS-05	M	Mastic, Yellow, Tacky	Office	Assumed	NF	G	200	SF
M-WAB-06	M	Wallbase (Coved), 4", Brown, Vinyl-Like	Storage 01	Assumed	NF	G	50	SF
M-ADH-07	M	Adhesive, Cream, Pliable	Storage 01	Assumed	NF	G	50	SF
M-SLT-08	M	Sealant (Doors, Windows), White, Pliable	Storage 01	Assumed	NF	G	2	SF
			Office					
M-VCT-09	M	Vinyl Composition Tile, 12"X12", Tan, Smooth, Tan Mottles	Storage 01	Assumed	NF	G	450	SF
M-MAS-10	M	Mastic, Yellow, Tacky	Storage 01	Assumed	NF	G	450	SF
M-CON-11	M	Concrete (Foundation), Gray, Cementitious	Shop	Assumed	NF	G	1,200	SF
			Storage 01					
			Storage 02					
			Office					
			Exterior					
M-BUR-12	M	Built-Up Roofing, Black, Asphaltic, Gray Mineral Cap	Roof	Assumed	NF	G	1,200	SF
M-MAS-13	M	Mastic (Penetrations), Black, Tar- Like	Roof	Assumed	NF	G	25	SF

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
M-CRS-14	M	Cementitious Roof Shingles (S- Pattern), Red, Cementitious	Exterior	Assumed	NF	G	1,000	SF
M-VBF-15	M	Vapor Barrier Felt, Black, Asphaltic	Exterior	Assumed	NF	G	1,000	SF

6-MONTH SURVEILLANCE INSPECTION TABLE
IN-PLACE ASBESTOS-CONTAINING MATERIALS

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
M-FDI-01	M	Fire Door Insulation, Metal/Wood Cladding	Building M	Assumed	NF	G	54	SF
			Exterior					
M-CON-02	M	Concrete (Foundation), Gray, Cementitious	Building M	Assumed	NF	G	2,800	SF
			Exterior					

6-MONTH SURVEILLANCE INSPECTION TABLE

IN-PLACE ASBESTOS-CONTAINING MATERIALS

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
M-CON-03	M	Concrete (Foundation), Gray, Cementitious	Chillers	Assumed	NF	G	1,500	SF
			Pumps					
			Electrical					
			Exterior					
M-FDI-04	M	Fire Door Insulation, Metal/Wood Cladding	Chillers	Assumed	NF	G	42	SF
			Pumps					
			Exterior					
M-PES-05	M	Pipe End Sealant, White, Pliable	Pumps	Assumed	NF	G	30	SF
M-SLT-06	M	Sealant (Equipment), Black, Gummy	Chillers	Assumed	NF	G	10	SF
M-SLT-07	M	Sealant (Doors, Fixtures), Gray, Pliable	Chillers	Assumed	NF	G	5	SF
			Pumps					
			Exterior					
M-BUR-08	M	Built-Up Roofing, Black, Asphaltic, Gravel Cap	Roof	Assumed	NF	G	1,500	SF
M-MAS-09	M	Mastic (Penetrations And Flashings), Black, Tar-Like	Roof	Assumed	NF	G	30	SF
M-SLT-10	M	Sealant (Duct), Gray, Pliable	Roof	Assumed	NF	G	10	SF

6-MONTH SURVEILLANCE INSPECTION TABLE
IN-PLACE ASBESTOS-CONTAINING MATERIALS

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
M-APR-01	M	Asphalt Prepared Roofing (Shingles), Black, Asphaltic, Gray Mineral Cap	Roof	Assumed	NF	G	400	SF
M-VBF-02	M	Vapor Barrier Felt, Black, Asphaltic	Roof	Assumed	NF	G	400	SF

6-MONTH SURVEILLANCE INSPECTION TABLE
IN-PLACE ASBESTOS-CONTAINING MATERIALS

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
M-APR-01	M	Asphalt Prepared Roofing (Shingles), Black, Asphaltic, Gray Mineral Cap	Roof	Assumed	NF	G	100	SF
M-VBF-02	M	Vapor Barrier Felt, Black, Asphaltic	Roof	Assumed	NF	G	100	SF
M-CON-03	M	Concrete (Foundation), Gray, Cementitious	Storage J	Assumed	NF	G	100	SF
			Exterior					

6-MONTH SURVEILLANCE INSPECTION TABLE
IN-PLACE ASBESTOS-CONTAINING MATERIALS

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
M-APR-01	M	Asphalt Prepared Roofing, Black, Asphaltic, Gray Mineral Cap	Roof	Assumed	NF	G	90	SF
M-VBF-02	M	Vapor Barrier Felt, Black, Asphaltic	Roof	Assumed	NF	G	90	SF
M-CON-03	M	Concrete (Foundation), Gray, Cementitious	Storage O	Assumed	NF	G	90	SF
			Exterior					

6-MONTH SURVEILLANCE INSPECTION TABLE

IN-PLACE ASBESTOS-CONTAINING MATERIALS

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
M-BUR-01	M	Built-Up Roofing, Black, Asphaltic, Gray Mineral Cap	Roof	Assumed	NF	G	35,000	SF
M-MAS-02	M	Mastic (Penetrations And Flashings), Black, Tar-Like	Roof	Assumed	NF	G	700	SF
M-SLT-03	M	Sealant (Flashings), White, Pliable	Roof	Assumed	NF	G	25	SF
M-WDB-04	M	Woven Duct Boot, 4", Black, Rubber-Like	Roof	Assumed	NF	G	20	SF
M-SLT-05	M	Sealant (Duct), Gray, Pliable	Roof	Assumed	NF	G	30	SF
S-STU-10	S	Stucco, Gray, Cementitious	Exterior	Assumed	NF	G	7,000	SF
S-STU-11	S	Stucco, Gray, Cementitious	Exterior	Assumed	NF	G	2,000	SF
M-SLT-12	M	Sealant (Doors, Windows, Expansion), Gray, Pliable	Deliveries	Assumed	NF	G	50	SF
			Patio					
			Vestibule					
			Bus Repair Area					
			Office 02					
			Abyss					
			Bay 03					
			Storage 05					
			Bay 05					
			Bay 06					
			Corridor 02					
			Corridor 03					
			Exterior					

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
M-CON-13	M	Concrete (Foundation), Gray, Cementitious	Wash Bay	Assumed	NF	G	35,000	SF
			Bus Repair					
			Tool Crib 01					
			Office 01					
			Storage 01					
			Storage 02					
			Deliveries					
			Vestibule					
			Office 02					
			Office 03					
			Office 04					
			Office 05					
			Routing					
			Dispatch					
			Reception 01					
			Director					
			Hall 01					
			Lounge					
			Patio					
			Locksmith					
			Janitor					
			Men's Restroom					
			Women's Restroom					
			Tool Crib 02					
			Bench Stock					
			Plan Room					
			Office 06					
			Office 07					
			Office 08					
			Storage 03					
			Reception 02					

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
			Lobby					
			Conference					
			Bay 01					
			Office 09					
			Abyss					
			Bay 02					
			Tool Crib 03					
			Bay 03					
			Tool Crib 04					
			Bay 04					
			Storage 04					
			Storage 05					
			Bay 05					
			Office 10					
			Office 11					
			Bay 06					
			Corridor 01					
			Corridor 02					
			Corridor 03					
			Exterior					
M-CON-14	M	Concrete, Gray, Cementitious	Patio	Assumed	NF	G	2,000	SF
M-ASP-15	M	Asphalt (Entries), Black, Asphaltic	Exterior	Assumed	NF	G	10,000	SF
M-FDI-16	M	Fire Door Insulation, Metal/Wood Cladding	Vestibule	Assumed	NF	G	462	SF
			Office 02					
			Office 03					
			Director					
			Lounge					
			Patio					
			Locksmith					

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
			Men's Restroom					
			Women's Restroom					
			Reception					
			Lobby					
			Bay 01					
			Bay 02					
			Bay 03					
			Bay 04					
			Storage 05					
			Bay 05					
			Bay 06					
			Corridor 01					
			Corridor 02					
			Corridor 03					
			Exterior					
M-SLT-20	M	Sealant (Doors, Windows, Fixtures), White, Pliable	Bus Repair	Assumed	NF	G	30	SF
			Tool Crib 01					
			Office 01					
			Storage 01					
			Storage 02					
			Deliveries					
			Vestibule					
			Office 02					
			Office 03					
			Office 04					
			Office 05					
			Routing					
			Dispatch					
			Reception 01					
			Director					

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
			Hall 01					
			Lounge					
			Locksmith					
			Janitor					
			Men's Restroom					
			Women's Restroom					
			Tool Crib 02					
			Bench Stock					
			Plan Room					
			Office 06					
			Office 07					
			Office 08					
			Storage 03					
			Reception 02					
			Lobby					
			Conference					
			Bay 01					
			Office 09					
			Abyss					
			Bay 02					
			Tool Crib 03					
			Bay 03					
			Bay 04					
			Storage 04					
			Storage 05					
			Bay 05					
			Corridor 01					
			Corridor 02					
			Corridor 03					
M-WAB-21	M	Wallbase (Coved), 4", Brown, Vinyl-Like	Tool Crib 01	Assumed	NF	G	400	SF
			Office 01					

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
			Storage 01					
			Storage 02					
			Deliveries					
			Lounge					
			Janitor					
			Tool Crib 02					
			Lobby					
			Bay 01					
			Abyss					
			Bay 02					
			Tool Crib 03					
			Bay 03					
			Bay 04					
			Storage 04					
			Storage 05					
			Bay 05					
			Bay 06					
			Corridor 01					
			Corridor 02					
M-ADH-22	M	Adhesive, Cream, Pliable	Tool Crib 01	Assumed	NF	G	400	SF
			Office 01					
			Storage 01					
			Storage 02					
			Deliveries					
			Lounge					
			Janitor					
			Tool Crib 02					
			Office 06					
			Office 07					
			Office 08					
			Storage 03					
			Reception 02					

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
			Lobby					
			Bay 01					
			Abyss					
			Bay 02					
			Tool Crib 03					
			Bay 03					
			Bay 04					
			Storage 04					
			Storage 05					
			Bay 05					
			Bay 06					
			Corridor 01					
			Corridor 02					
M-VCT-23	M	Vinyl Composition Tile, 12"X12", Tan, Smooth, Gray Mottles	Office 01	Assumed	NF	G	3,000	SF
			Lounge					
			Office 10					
M-MAS-24	M	Mastic, Yellow, Pliable	Office 01	Assumed	NF	G	3,000	SF
			Lounge					
			Office 10					
M-VCT-32	M	Vinyl Composition Tile, 12"X12", Light Brown, Smooth, Brown Mottles	Reception 01	Assumed	NF	G	4,000	SF
			Locksmith					
			Janitor					
			Bench Stock					
			Reception 02					
			Lobby					
			Corridor 01					
			Corridor 02					
			Corridor 03					

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
M-MAS-33	M	Mastic, Yellow, Tacky	Reception 01	Assumed	NF	G	4,000	SF
			Locksmith					
			Janitor					
			Bench Stock					
			Reception 02					
			Lobby					
			Corridor 01					
			Corridor 02					
			Corridor 03					
M-CPT-36	M	Carpet, Blue, Fibrous, Multi-Colored Specks	Conference	Assumed	NF	G	1,500	SF
			Office 09					
M-MAS-37	M	Mastic, Yellow, Tacky	Conference	Assumed	NF	G	1,500	SF
			Office 09					
M-WAB-38	M	Wallbase (Coved), 4", Blue, Vinyl-Like	Reception 01	Assumed	NF	G	80	SF
			Conference					
			Office 09					
			Corridor 03					
M-ADH-39	M	Adhesive, Cream, Pliable	Reception 01	Assumed	NF	G	80	SF
			Conference					
			Office 09					
			Corridor 03					
M-GWT-43	M	Glazed Wall Tile, 4"X4", White, Smooth	Men's Restroom	Assumed	NF	G	1,200	SF
			Janitor					
			Women's Restroom					

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
M-GWT-44	M	Glazed Wall Tile (Pattern), 4"X4", Black, Smooth	Men's Restroom	Assumed	NF	G	400	SF
			Janitor					
			Women's Restroom					
M-GRT-45	M	Grout, Gray, Cementitious	Men's Restroom	Assumed	NF	G	120	SF
			Janitor					
			Women's Restroom					
M-QPT-46	M	Quarry/Paver Tile, 8"X8", Black, Smooth, Gray Specks	Men's Restroom	Assumed	NF	G	750	SF
			Women's Restroom					
M-GRT-47	M	Grout, Gray, Cementitious	Men's Restroom	Assumed	NF	G	75	SF
			Women's Restroom					
M-CPT-48	M	Carpet, Gray, Fibrous, Multi- Colored Specks	Tool Crib 02	Assumed	NF	G	500	SF
M-MAS-49	M	Mastic, Yellow, Tacky	Tool Crib 02	Assumed	NF	G	500	SF
M-VCT-50	M	Vinyl Composition Tile, 12"X12", White, Smooth, Brown Mottles	Tool Crib 02	Assumed	NF	G	250	SF
M-MAS-51	M	Mastic, Yellow, Tacky	Tool Crib 02	Assumed	NF	G	250	SF

6-MONTH SURVEILLANCE INSPECTION TABLE

IN-PLACE ASBESTOS-CONTAINING MATERIALS

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS	DATE LAST INSPECTED
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA	
		THERE ARE NO IDENTIFIED ASBESTOS-CONTAINING BUILDING							
		MATERIALS IN THIS BUILDING.							

6-MONTH SURVEILLANCE INSPECTION TABLE

IN-PLACE ASBESTOS-CONTAINING MATERIALS

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
M-BUR-01	M	Built-Up Roofing, Black, Asphaltic, Gray Mineral Cap	Roof	Assumed	NF	G	10,000	SF
M-MAS-02	M	Mastic (Penetrations And Flashings), Black, Tar-Like	Roof	Assumed	NF	G	100	SF
M-CTG-03	M	Coating, White, Pliable, Associated With Spray-Applied Foam Roofing	Roof	Assumed	NF	G	5,000	SF
M-MAS-04	M	Mastic (Penetrations And Flashings), Black, Tar-Like	Roof	Assumed	NF	G	50	SF
M-SLT-05	M	Sealant (Duct), Gray, Pliable	Roof	Assumed	NF	G	50	SF
M-EXJ-09	M	Expansion Joint, White, Pliable	Warehouse 01	Assumed	NF	G	30	SF
			Office 01					
			Office 03					
			Storage 01					
			Office 05					
			Storage 02					
			Warehouse 03					
			Exterior					
S-STU-10	S	Stucco, Gray, Cementitious	Exterior	Assumed	NF	G	3,500	SF
M-CON-11	M	Concrete (Foundation), Gray, Cementitious	Lobby	Assumed	NF	G	18,000	SF
			Teller Storage					
			Tellers					
			Warehouse 01					

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
			Office 01					
			Food Storage					
			Freezer					
			Office 02					
			Clerical					
			Warehouse 02					
			Unisex Restroom 01					
			Unisex Restroom 02					
			Office 03					
			Office 04					
			Server Room					
			Storage 01					
			Office 05					
			Storage 02					
			Unisex Restroom 03					
			Storage 03					
			Open Office					
			Storage 04					
			Stair Well					
			Storage 05					
			Exterior					
M-CON-12	M	Concrete (Entries), Gray, Cementitious	Exterior	Assumed	NF	G	1,500	SF
M-SLT-13	M	Sealant (Doors), Gray, Pliable	Exterior	Assumed	NF	G	7	SF
M-SLT-14	M	Sealant (Doors, Windows), Black, Pliable	Exterior	Assumed	NF	G	18	SF
M-FDI-15	M	Fire Door Insulation, Metal/Wood Cladding	Lobby	Assumed	NF	G	420	SF
			Warehouse 01					
			Office 01					

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
			Food Storage					
			Clerical					
			Warehouse 02					
			Unisex Restroom 01					
			Unisex Restroom 02					
			Server Room					
			Office 05					
			Unisex Restroom 03					
			Open Office					
			Storage 04					
			Stair Well					
			Hall 01					
			Office 06					
			Exterior					
M-VCT-22	M	Vinyl Composition Tile, 12"X12", White, Smooth, Gray Mottles	Office 01	Assumed	NF	G	1,000	SF
			Unisex Restroom 01					
			Unisex Restroom 02					
			Office 03					
			Office 04					
			Server Room					
M-MAS-23	M	Mastic, Yellow, Tacky	Office 01	Assumed	NF	G	1,000	SF
			Unisex Restroom 01					
			Unisex Restroom 02					
			Office 03					
			Office 04					
			Server Room					
M-SLT-24	M	Sealant (Doors, Windows, Fixtures), White, Pliable	Warehouse 01	Assumed	NF	G	30	SF
			Office 01					

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
			Food Storage					
			Office 02					
			Warehouse 02					
			Clerical					
			Unisex Restroom 01					
			Unisex Restroom 02					
			Office 03					
			Office 04					
			Office 05					
			Storage 02					
			Stair Well					
			Warehouse 03					
			Hall 01					
			Office 06					
M-WAB-25	M	Wallbase (Coved), 4", Brown, Vinyl-Like	Warehouse 01	Assumed	NF	G	150	SF
			Office 01					
			Office 03					
			Office 04					
			Server Room					
			Storage 01					
			Office 05					
			Stair Well					
			Hall 01					
			Office 06					
M-ADH-26	M	Adhesive, Cream, Pliable	Warehouse 01	Assumed	NF	G	150	SF
			Office 01					
			Food Storage					
			Office 02					
			Office 03					
			Office 04					

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
			Server Room					
			Storage 01					
			Office 05					
			Stair Well					
			Hall 01					
			Office 06					
M-CPT-31	M	Carpet (Self-Stick), Gray, Fibrous, Multi-Colored Specks	Office 02	Assumed	NF	G	30	SF
			Clerical					
			Storage 01					
			Office 05					
M-WAB-32	M	Wallbase (Coved), 4", Gray, Vinyl- Like	Storage 01	Assumed	NF	G	30	SF
			Storage 02					
M-ADH-33	M	Adhesive, Cream, Pliable	Storage 01	Assumed	NF	G	30	SF
			Storage 02					
M-WAB-35	M	Wallbase (Coved), 4", Black, Vinyl- Like	Unisex Restroom 02	Assumed	NF	G	8	SF
M-ADH-36	M	Adhesive, Cream, Pliable	Unisex Restroom 02	Assumed	NF	G	8	SF
M-CPT-41	M	Carpet, Brown, Fibrous, Multi- Colored Specks	Stair Well	Assumed	NF	G	900	SF
			Hall 01					
			Office 06					
M-MAS-42	M	Mastic, Yellow, Tacky	Stair Well	Assumed	NF	G	900	SF
			Hall 01					
			Office 06					

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
S·SAT·44	S	Spray-Applied Texture, White, Chalky	Lobby	Assumed	NF	G	3,000	SF
			Teller Storage					
			Tellers					
			Storage 03					
			Open Office					
			Storage 04					
			Storage 05					
M·GWB·45	M	Gypsum Wallboard, White, Chalky	Lobby	Assumed	NF	G	3,000	SF
			Teller Storage					
			Tellers					
			Storage 03					
			Open Office					
			Storage 04					
			Storage 05					
S·JTC·46	S	Joint Compound, White, Chalky	Lobby	Assumed	NF	G	300	SF
			Teller Storage					
			Tellers					
			Storage 03					
			Open Office					
			Storage 04					
			Storage 05					
M·QPT·47	M	Quarry/Paver Tile, 18"X18", White, Smooth	Lobby	Assumed	NF	G	1,500	SF
M·GRT·48	M	Grout, Gray, Cementitious	Lobby	Assumed	NF	G	150	SF
M·SLT·53	M	Sealant (Doors, Windows, Millwork, Fixtures), White, Pliable	Lobby	Assumed	NF	G	7	SF
			Unisex Restroom 03					
			Open Office					

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
M-SLT-54	M	Sealant (Windows), Black, Pliable	Storage 05	Assumed	NF	G	4	SF
M-ACB-58	M	Asbestos Cement Board, Gray, Cementitious, Smooth	Exterior	Assumed	NF	G	1,500	SF

***Material M-SLT-54 was not found in the Open Office.**

THE ASBESTOS INSTITUTE

Certifies that

Zachary Ridgeway

has attended and received instruction in the EPA approved course

AHERA Building Inspector Initial

on

March 6-8 2023


and successfully completed and passed the competency exam.

Certificate:
4380-15665-030823

Date of Examination:
08-Mar-2023

Date of Expiration:
08-Mar-2024


William T. Caviness
Director


Approved Instructor

THE ASBESTOS INSTITUTE

20033 N. 19th Ave, Building 6, Phoenix, AZ 85027
602-864-6564 – www.theasbestosinstitute.com

This training meets all requirements for asbestos certification under Basic Substance Control Act Title II.