

May 23, 2023

Mr. Matthew Griffin
Facilities Supervisor
Kyrene School District No. 28
8700 South Kyrene Road
Tempe, AZ 85284-2197

**Subject: 6-Month Surveillance Inspection
Asbestos-Containing Building Materials
Kyrene del Cielo Elementary School
1350 North Lakeshore Drive, Chandler**

Dear Mr. Griffin:

FM GROUP INC has completed the 6-Month Surveillance Inspection of Asbestos-Containing Building Materials (ACBM) at the subject school. The forms detailing the results of this reinspection and reassessment of known ACBM are attached.

The attached tables and forms have been updated to reflect the findings as of the date of this Reinspection and should serve as the Management Plan update.

Items of significance are: None.

If you have any questions regarding this correspondence, please contact us immediately.

Sincerely,

FM GROUP INC



Michael Hall
Environmental Division Manager



Zach Ridgeway
AHERA Building Inspector

*Attachments: 6-Month Surveillance Inspection Forms
6-Month Surveillance Inspection Tables*




6-MONTH SURVEILLANCE INSPECTION ASBESTOS-CONTAINING BUILDING MATERIALS

School/Facility: Kyrene del Cielo Elementary School

Inspection Date: 04/07/2023

Building: Cafeteria Building

Inspector: Zach Ridgeway Cert. No.: 4380-15665-030823

Signature: 

Material Description	Material Code	Material Observed		Material Condition Status		Material Condition Description (If Change Noted)	Assessment Classification
				Same	Changed		
Tackable Wall Panel, Brown, Fibrous, Vinyl Cover	M-TWP-05	Y	N	x			1 2 3 4 5 6 7*
Adhesive, Brown, Brittle	M-ADH-06	Y	N	x			1 2 3 4 5 6 7*
Sink Acoustical Coating, Gray, Rough	M-SAC-11	Y	N	x			1 2 3 4 5 6 7*
Fire Door Insulation, Metal Cladding	M-FDI-12	Y	N	x			1 2 3 4 5 6 7*
Sealant, White, Pliable	M-SLT-13	Y	N	x			1 2 3 4 5 6 7*
Mortar (Glass Block), Gray, Cementitious	M-MRT-14	Y	N	x			1 2 3 4 5 6 7*
Fire Door Insulation, Wood Cladding	M-FDI-17	Y	N	x			1 2 3 4 5 6 7*
Vinyl Stair Tread, 36"X12", Brown, Textured, Vinyl-Like, Circle Pattern	M-VST-19	Y	N	x			1 2 3 4 5 6 7*
Mastic, Brown, Brittle	M-MAS-20	Y	N	x			1 2 3 4 5 6 7*
Adhesive (ACT), Brown, Brittle	M-ADH-22	Y	N	x			1 2 3 4 5 6 7*
Concrete Masonry Unit, 8"X16", Gray, Cementitious	M-CON-24	Y	N	x			1 2 3 4 5 6 7*
Glazed Wall Tile, 4"X4", Pink, Smooth	M-GWT-31	Y	N	x			1 2 3 4 5 6 7*
Grout, Gray, Cementitious	M-GRT-32	Y	N	x			1 2 3 4 5 6 7*
Adhesive (FRP), Brown, Brittle	M-ADH-36	Y	N	x			1 2 3 4 5 6 7*
Quarry/Paver Tile, 6"X6", Gray, Smooth, Peppered	M-QPT-37	Y	N	x			1 2 3 4 5 6 7*
Grout, Gray, Cementitious	M-GRT-38	Y	N	x			1 2 3 4 5 6 7*
Ceramic Mosaic Tile, 2"X2", Pink, Smooth, Peppered	M-CMT-39	Y	N	x			1 2 3 4 5 6 7*
Grout, Gray, Cementitious	M-GRT-40	Y	N	x			1 2 3 4 5 6 7*
Sealant, Brown, Pliable	M-SLT-41	Y	N	x			1 2 3 4 5 6 7*
Quarry/Paver Tile (Transition Strip), 2"X36", Gray, Smooth, Marbled	M-QPT-42	Y	N	x			1 2 3 4 5 6 7*
Sealant, Tan, Pliable	M-SLT-43	Y	N	x			1 2 3 4 5 6 7*
Pipe End Sealant, White, Brittle	M-PES-44	Y	N	x			1 2 3 4 5 6 7*
Sealant (Equipment), Black, Tar-Like	M-SLT-45	Y	N	x			1 2 3 4 5 6 7*
Fire Door Insulation, Metal/Wood Cladding	M-FDI-110	Y	N	x			1 2 3 4 5 6 7*



6-MONTH SURVEILLANCE INSPECTION ASBESTOS-CONTAINING BUILDING MATERIALS

***Assessment Classifications**

1. Damaged or significantly damaged thermal system insulation ACBM.
2. Damaged friable surfacing ACBM.
3. Significantly damaged friable surfacing ACBM.
4. Damaged or significantly damaged friable miscellaneous ACBM.
5. ACBM with potential for damage.
6. ACBM with potential for significant damage.
7. Any remaining friable ACBM or friable suspected ACBM.



6-MONTH SURVEILLANCE INSPECTION ASBESTOS-CONTAINING BUILDING MATERIALS

School/Facility: Kyrene del Cielo Elementary School

Inspection Date: 04/07/2023

Building: Main Building

Inspector: Zach Ridgeway Cert. No.: 4380-15665-030823

Signature: 

Material Description	Material Code	Material Observed		Material Condition Status		Material Condition Description (If Change Noted)	Assessment Classification
				Same	Changed		
Glazed Wall Tile, 4"X4", Pink, Smooth	M-GWT-12	Y	N	x			1 2 3 4 5 6 7*
Grout, Gray, Cementitious	M-GRT-13	Y	N	x			1 2 3 4 5 6 7*
Ceramic Mosaic Tile, 2"X2", Pink, Smooth, Multi-Colored Specks	M-CMT-14	Y	N	x			1 2 3 4 5 6 7*
Grout, Gray, Cementitious	M-GRT-15	Y	N	x			1 2 3 4 5 6 7*
Quarry/Paver Tile (Transition Strip), 2"X36", Gray, Smooth, Marbled	M-QPT-16	Y	N	x			1 2 3 4 5 6 7*
Sink Acoustical Coating, Gray, Rough	M-SAC-17	Y	N	x			1 2 3 4 5 6 7*
Sealant, Black, Clay-Like	M-SLT-21	Y	N	x			1 2 3 4 5 6 7*
Fire Door Insulation, Metal Cladding	M-FDI-22	Y	N	x			1 2 3 4 5 6 7*
Sealant (Duct), Tan, Pliable	M-SLT-23	Y	N	x			1 2 3 4 5 6 7*
Mortar (Glass Block), Gray, Cementitious	M-MRT-26	Y	N	x			1 2 3 4 5 6 7*
Tackable Wall Panel, Brown, Fibrous, Vinyl Cover	M-TWP-27	Y	N	x			1 2 3 4 5 6 7*
Adhesive, Brown, Brittle	M-ADH-28	Y	N	x			1 2 3 4 5 6 7*
Fire Door Insulation, Wood Cladding	M-FDI-29	Y	N	x			1 2 3 4 5 6 7*
Sink Acoustical Coating, White, Rough	M-SAC-34	Y	N	x			1 2 3 4 5 6 7*
Adhesive (FRP), Brown, Brittle	M-ADH-37	Y	N	x			1 2 3 4 5 6 7*
Glazed Wall Tile, 4"X4", Tan, Smooth	M-GWT-38	Y	N	x			1 2 3 4 5 6 7*
Grout, Gray, Cementitious	M-GRT-39	Y	N	x			1 2 3 4 5 6 7*
Ceramic Mosaic Tile, 1"X1", White, Smooth, Peppered	M-CMT-40	Y	N	x			1 2 3 4 5 6 7*
Grout, Gray, Cementitious	M-GRT-41	Y	N	x			1 2 3 4 5 6 7*
Sealant, Brown, Pliable	M-SLT-51	Y	N	x			1 2 3 4 5 6 7*
Glazed Wall Tile, 4"X4", Tan, Smooth	M-GWT-52	Y	N	x			1 2 3 4 5 6 7*
Grout, Gray, Cementitious	M-GRT-53	Y	N	x			1 2 3 4 5 6 7*
Glazed Wall Tile, 4"X4", Gray, Smooth	M-GWT-54	Y	N	x			1 2 3 4 5 6 7*
Stucco, Gray, Cementitious	S-STU-61	Y	N	x			1 2 3 4 5 6 7*
Sealant (Equipment), Gray, Brittle	M-SLT-62	Y	N	x			1 2 3 4 5 6 7*
Sealant (Equipment), Yellow, Clay-Like	M-SLT-63	Y	N	x			1 2 3 4 5 6 7*
Concrete Masonry Unit, 3"X16", Gray, Cementitious	M-CON-65	Y	N	x			1 2 3 4 5 6 7*
Expansion Joint, Brown, Brittle	M-EXJ-68	Y	N	x			1 2 3 4 5 6 7*
Fire Door Insulation, Metal/Wood Cladding	M-FDI-131	Y	N	x			1 2 3 4 5 6 7*



6-MONTH SURVEILLANCE INSPECTION ASBESTOS-CONTAINING BUILDING MATERIALS

Material Description	Material Code	Material Observed		Material Condition Status		Material Condition Description (If Change Noted)	Assessment Classification
				Same	Changed		
Built-Up Roofing, Black, Asphaltic, Vinyl Cover	M-BUR-132	Y	N	x			1 2 3 4 5 6 7*
Fire Door Insulation, Metal/Wood Cladding	M-FDI-231	Y	N	x			1 2 3 4 5 6 7*
Built-Up Roofing, Black, Asphaltic, Vinyl Cover	M-BUR-232	Y	N	x			1 2 3 4 5 6 7*

***Assessment Classifications**

1. Damaged or significantly damaged thermal system insulation ACBM.
2. Damaged friable surfacing ACBM.
3. Significantly damaged friable surfacing ACBM.
4. Damaged or significantly damaged friable miscellaneous ACBM.
5. ACBM with potential for damage.
6. ACBM with potential for significant damage.
7. Any remaining friable ACBM or friable suspected ACBM.

6-MONTH SURVEILLANCE INSPECTION TABLE

IN-PLACE ASBESTOS-CONTAINING MATERIALS

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
M-TWP-05	M	Tackable Wall Panel, Brown, Fibrous, Vinyl Cover	P.E. Office	Assumed	NF	G	600	SF
			Room 607					
			Room 608					
M-ADH-06	M	Adhesive (Twp), Brown, Brittle	P.E. Office	Assumed	NF	G	150	SF
			Room 607					
			Room 608					
M-SAC-11	M	Sink Acoustical Coating, Gray, Rough	Stage	Assumed	NF	G	6	SF
			Room 607					
			Room 608					
M-FDI-12	M	Fire Door Insulation, Metal Cladding	Kitchen	Assumed	NF	G	567	SF
			Kitchen Patio					
			Water Heater Closet					
			Corridor					
			Electrical Room					
			Electrical Yard					
			Existing Boy's Restroom					
			Existing Girl's Restroom					
			Exterior Storage					
			Mechanical Room					
			Chiller Room					
			Exterior					
M-SLT-13	M	Sealant, White, Pliable	Cafeteria	Assumed	NF	G	53	SF
			Cafeteria Electrical Room					
			Cafeteria Storage					
			Kitchen					

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
			Water Heater Closet					
			P.E. Storage					
			Corridor					
			Custodial					
			Office					
			Electrical Yard					
			Stage					
			Stage Storage					
			East Wing					
			South Wing					
			Room 607					
			Room 608					
			South Foyer					
			Existing Boy's Restroom					
			Existing Girl's Restroom					
			Exterior Storage					
			Instrument 1					
			Instrument 2					
M-MRT-14	M	Mortar (Glass Block), Gray, Cementitious	Cafeteria	Assumed	NF	G	30	SF
			Room 607					
			Room 608					
			South Foyer					
			Exterior					
M-FDI-17	M	Fire Door Insulation, Wood Cladding	Cafeteria	Assumed	NF	G	378	SF
			Cafeteria Storage					
			Girl's Restroom					
			Boy's Restroom					
			Kitchen					
			P.E. Storage					
			Corridor					
			Custodial					

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
			Office					
			Stage Storage					
			East Wing					
			South Wing					
			West Wing					
			South Foyer					
			Room 607					
			Room 608					
M·VST·19	M	Vinyl Stair Tread, 36"X12", Brown, Textured, Vinyl-Like, Circle Pattern	East Wing	Assumed	NF	G	40	SF
			South Wing					
			West Wing					
M·MAS·20	M	Mastic, Brown, Brittle	East Wing	Assumed	NF	G	40	SF
			South Wing					
			West Wing					
M·ADH·22	M	Adhesive (ACT), Brown, Brittle	Stage	Assumed	NF	G	125	SF
			South Foyer					
M·CMU·24	M	Concrete Masonry Unit, 8"X16", Gray, Cementitious	Cafeteria	Assumed	NF	G	6,000	SF
			Cafeteria Electrical Room					
			Water Heater Closet, North Wall					
			Electrical Room					
			Electrical Yard					
			Exterior Storage					
			Mechanical Room					
			Chiller Room					
M·GWT·31	M	Glazed Wall Tile, 4"X4", Pink, Smooth	Girl's Restroom	Assumed	NF	G	2,500	SF
			Boy's Restroom					
			Kitchen Patio					
			Custodial					

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
			Existing Boy's Restroom					
			Existing Girl's Restroom					
M-GRT-32	M	Grout, Gray, Cementitious	Girl's Restroom	Assumed	NF	G	250	SF
			Boy's Restroom					
			Kitchen Patio					
			Custodial					
			Existing Boy's Restroom					
			Existing Girl's Restroom					
M-ADH-36	M	Adhesive (FRP), Brown, Brittle	Kitchen	Assumed	NF	G	250	SF
M-QPT-37	M	Quarry/Paver Tile, 6"X6", Gray, Smooth, Peppered	Kitchen	Assumed	NF	G	800	SF
M-GRT-38	M	Grout, Gray, Cementitious	Kitchen	Assumed	NF	G	80	SF
M-CMT-39	M	Ceramic Mosaic Tile, 2"X2", Pink, Smooth, Peppered	Girl's Restroom	Assumed	NF	G	900	SF
			Boy's Restroom					
			Existing Boy's Restroom					
			Existing Girl's Restroom					
M-GRT-40	M	Grout, Gray, Cementitious	Girl's Restroom	Assumed	NF	G	90	SF
			Boy's Restroom					
			Existing Boy's Restroom					
			Existing Girl's Restroom					
M-SLT-41	M	Sealant, Brown, Pliable	Existing Boy's Restroom	Assumed	NF	G	2	SF
			Existing Girl's Restroom					
M-QPT-42	M	Quarry/Paver Tile (Transition Strip), 2"X36", Gray, Smooth, Marbled	Boy's Restroom	Assumed	NF	G	4	SF
			Girl's Restroom					
			Existing Boy's Restroom					

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
			Existing Girl's Restroom					
M·SLT·43	M	Sealant, Tan, Pliable	Electrical Room	Assumed	NF	G	32	SF
			Electrical Yard					
			Mechanical Room					
			Chiller Room					
			Exterior					
M·PES·44	M	Pipe End Sealant, White, Brittle	Mechanical Room	Assumed	NF	G	40	SF
M·SLT·45	M	Sealant (Equipment), Black, Tar-Like	Chiller Room	Assumed	NF	G	20	SF
M·FDI·110	M	Fire Door Insulation, Metal/Wood Cladding	North Corridor (Interior Rooms Also)	Assumed	NF	G	123	SF
			Exterior					

6-MONTH SURVEILLANCE INSPECTION TABLE

IN-PLACE ASBESTOS-CONTAINING MATERIALS

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
M-GWT-12	M	Glazed Wall Tile, 4"X4", Pink, Smooth	Nurse Restroom	Assumed	NF	G	1,500	SF
			Staff Men's Restroom					
			Staff Women's Restroom					
			402/403 Restroom					
			404 Restroom					
			A5 Restroom					
			A8 Restroom					
M-GRT-13	M	Grout, Gray, Cementitious	Nurse Restroom	Assumed	NF	G	150	SF
			Staff Men's Restroom					
			Staff Women's Restroom					
			402/403 Restroom					
			404 Restroom					
			A5 Restroom					
			A8 Restroom					
M-CMT-14	M	Ceramic Mosaic Tile, 2"X2", Pink, Smooth, Multi-Colored Specks	Nurse Restroom	Assumed	NF	G	1,800	SF
			Staff Men's Restroom					
			Staff Women's Restroom					
			402/403 Restroom					
			404 Restroom					
			A5 Restroom					
			A8 Restroom					
			C Boy's Restroom					
			C Girl's Restroom					
M-GRT-15	M	Grout, Gray, Cementitious	Nurse Restroom	Assumed	NF	G	180	SF
			Staff Men's Restroom					
			Staff Women's Restroom					

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
			402/403 Restroom					
			404 Restroom					
			A5 Restroom					
			A8 Restroom					
			C Boy's Restroom					
			C Girl's Restroom					
M-QPT-16	M	Quarry/Paver Tile (Transition Strip), 2"X36", Gray, Smooth, Marbled	Nurse Restroom	Assumed	NF	G	4	SF
			Staff Men's Restroom					
			Staff Women's Restroom					
			402/403 Restroom					
			404 Restroom					
			A5 Restroom					
			A8 Restroom					
M-SAC-17	M	Sink Acoustical Coating, Gray, Rough	Hallway 1	Assumed	NF	G	30	SF
			Lounge					
			Workroom 1					
			Resource Room 402					
			Resource Room 403					
			Extended Resource Room 404					
			Gifted Classroom 405					
			Workroom 2					
			C1					
			C2					
			C3					
			C4					
			C Art Room					
M-SLT-21	M	Sealant, Black, Clay-Like	Nurse Office	Assumed	NF	G	20	SF
			Principal					
			Psychologist Office					

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
			Speech Room					
			Computer Room 401					
			Resource Room 402					
			Resource Room 403					
			Extended Resource Room 404					
			Gifted Classroom 405					
			K-3					
			Media Center					
			Conference Room 412					
			Workroom 2					
			Break-Out 1					
			Break-Out 2					
M-FDI-22	M	Fire Door Insulation, Metal Cladding	Reception	Assumed	NF	G	777	SF
			Nurse Office					
			Corridor 1					
			Corridor 3					
			Classroom 2 A12					
			Classroom 4 A11					
			Classroom 6 A10					
			Classroom 8 A9					
			Kindergarten 1 A5					
			Kindergarten 2 A8					
			Classroom 1 B1					
			Classroom 3 B2					
			Classroom 5 B3					
			Classroom 7 B4					
			Art Room B6					
			B Janitor					
			B Electrical Room					
			B Boy's Restroom Vestibule					
			B Girl's Restroom Vestibule					
			C Art Room					
			Kiln Room					

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
			Exterior					
M-SLT-23	M	Sealant (Duct), Tan, Pliable	Reception	Assumed	NF	G	500	SF
			Hallway 1					
			Supplies					
			Nurse Office					
			Nurse Restroom					
			Treatment Room					
			Hallway 2					
			Principal					
			Principal Closet					
			Foyer					
			Psychologist Office					
			Psychologist Office Closet					
			Assistant Principal					
			Assistant Principal Closet					
			Lounge					
			Workroom 1					
			Phone Room					
			Storage 1					
			Staff Men's Restroom					
			Staff Women's Restroom					
			Corridor 1					
			Corridor 2					
			Corridor 3					
			Corridor 4					
			Speech Room					
			Conference Room					
			Computer Room 401					
			Resource Room 402					
			Resource Room 403					
			402/403 Restroom					
			Extended Resource Room 404					
			404 Closet					

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
			404 Restroom					
			Gifted Classroom 405					
			K-3					
			Media Center					
			Conference Room 412					
			Workroom 2					
			Electrical Room					
			Break-Out 1					
			Break-Out 2					
			Storage 2					
			Classroom 1 A1					
			A Electrical Room					
			Classroom 2 A12					
			Classroom 3 A2					
			Classroom 4 A11					
			North A Foyer					
			Classroom 5 A3					
			Classroom 6 A10					
			Classroom 7 A4					
			Classroom 8 A9					
			South A Foyer					
			Kindergarten 1 A5					
			A5 Restroom					
			Kindergarten 2 A8					
			A8 Restroom					
			Classroom 1 B1					
			Classroom 2 B9					
			Classroom 3 B2					
			Classroom 4 B8					
			North B Foyer					
			Classroom 5 B3					
			Classroom 6 B7					
			Classroom 7 B4					
			Art Room B6					

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
			South B Foyer					
			B Janitor					
			B Electrical Room					
			B Boy's Restroom Vestibule					
			B Boy's Restroom					
			B Girl's Restroom Vestibule					
			B Girl's Restroom					
			C1					
			C2					
			C3					
			C4					
			C Foyer					
			C Art Room					
			Kiln Room					
			Storage					
			C Boy's Restroom					
			Fire Riser					
			C Electrical Room					
			C Girl's Restroom					
M-MRT-26	M	Mortar (Glass Block), Gray, Cementitious	Reception	Assumed	NF	G	400	SF
			Corridor 1					
			Corridor 2					
			Corridor 3					
			Exterior					
M-TWP-27	M	Tackable Wall Panel, Brown, Fibrous, Vinyl Cover	Psychologist Office	Assumed	NF	G	5,000	SF
			Lounge					
			Phone Room					
			Speech Room					
			Conference Room					
			Computer Room 401					
			Resource Room 402					

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
			Resource Room 403					
			Extended Resource Room 404					
			Gifted Classroom 405					
			K-3					
			Media Center					
			Conference Room 412					
			C1					
			C2					
			C3					
			C4					
			C Art Room					
M-ADH-28	M	Adhesive, Brown, Brittle	Psychologist Office	Assumed	NF	G	1,250	SF
			Lounge					
			Phone Room					
			Speech Room					
			Conference Room					
			Computer Room 401					
			Resource Room 402					
			Resource Room 403					
			Extended Resource Room 404					
			Gifted Classroom 405					
			K-3					
			Media Center					
			Conference Room 412					
			C1					
			C2					
			C3					
			C4					
			C Art Room					
M-FDI-29	M	Fire Door Insulation, Wood Cladding	Hallway 2	Assumed	NF	G	714	SF
			Foyer					

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
			Assistant Principal					
			Workroom 1					
			Staff Women's Restroom					
			Corridor 1					
			Corridor 2					
			Corridor 3					
			Corridor 4					
			Speech Room					
			Conference Room					
			Computer Room 401					
			Resource Room 402					
			Resource Room 403					
			Extended Resource Room 404					
			Gifted Classroom 405					
			K-3					
			Media Center					
			Conference Room 412					
			Workroom 2					
			Electrical Room					
			Break-Out 1					
			Break-Out 2					
			Storage 2					
			Classroom 1 A1					
			Classroom 3 A2					
			Classroom 5 A3					
			Classroom 7 A4					
			Kindergarten 1 A5					
			Classroom 2 B9					
			Classroom 4 B8					
			Classroom 6 B7					
			Art Room B6					
			C1					
			C2					
			C3					

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
			C4					
			C Foyer					
			C Art Room					
M-SAC-34	M	Sink Acoustical Coating, White, Rough	Classroom 1 A1	Assumed	NF	G	38	SF
			Classroom 2 A12					
			Classroom 3 A2					
			Classroom 4 A11					
			Classroom 5 A3					
			Classroom 6 A10					
			Classroom 7 A4					
			Classroom 8 A9					
			Kindergarten 1 A5					
			Kindergarten 2 A8					
			Classroom 1 B1					
			Classroom 2 B9					
			Classroom 3 B2					
			Classroom 4 B8					
			Classroom 5 B3					
			Classroom 6 B7					
			Classroom 7 B4					
			Art Room B6					
M-ADH-37	M	Adhesive (FRP), Brown, Brittle	Classroom 1 A1	Assumed	NF	G	2,000	SF
			Classroom 2 A12					
			Classroom 3 A2					
			Classroom 4 A11					
			Classroom 5 A3					
			Classroom 6 A10					
			Classroom 7 A4					
			Classroom 8 A9					
			Kindergarten 1 A5					
			Kindergarten 2 A8					
			Classroom 1 B1					

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
			Classroom 2 B9					
			Classroom 3 B2					
			Classroom 4 B8					
			Classroom 5 B3					
			Classroom 6 B7					
			Classroom 7 B4					
			Art Room B6					
			C1					
			C2					
			C3					
			C4					
			C Art Room					
M-GWT-38	M	Glazed Wall Tile, 4"X4", Tan, Smooth	B Boy's Restroom	Assumed	NF	G	800	SF
			B Girl's Restroom					
M-GRT-39	M	Grout, Gray, Cementitious	B Boy's Restroom	Assumed	NF	G	80	SF
			B Girl's Restroom					
M-CMT-40	M	Ceramic Mosaic Tile, 1"X1", White, Smooth, Peppered	B Boy's Restroom	Assumed	NF	G	400	SF
			B Girl's Restroom					
M-GRT-41	M	Grout, Gray, Cementitious	B Boy's Restroom	Assumed	NF	G	40	SF
			B Girl's Restroom					
M-SLT-51	M	Sealant, Brown, Pliable	Kiln	Assumed	NF	G	2	SF
M-GWT-52	M	Glazed Wall Tile, 4"X4", Tan, Smooth	C Boy's Restroom	Assumed	NF	G	1,000	SF
			C Girl's Restroom					
M-GRT-53	M	Grout, Gray, Cementitious	C Boy's Restroom	Assumed	NF	G	100	SF
			C Electrical Room					

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
			C Girl's Restroom					
M-GWT-54	M	Glazed Wall Tile, 4"X4", Gray, Smooth	C Girl's Restroom	Assumed	NF	G	12	SF
S-STU-61	S	Stucco, Gray, Cementitious	Roof	Assumed	NF	G	4,000	SF
M-SLT-62	M	Sealant (Equipment), Gray, Brittle	Roof-Mounted HVAC Equipment	Assumed	NF	G	10	SF
M-SLT-63	M	Sealant (Equipment), Yellow, Clay-Like	Roof-Mounted HVAC Equipment	Assumed	NF	G	5	SF
M-CMU-65	M	Concrete Masonry Unit, 3"X16", Gray, Cementitious	Kinder Play Area	Assumed	NF	G	50	SF
			Exterior					
M-EXJ-68	M	Expansion Joint, Brown, Brittle	Exterior	Assumed	NF	G	500	SF
M-FDI-131	M	Fire Door Insulation, Metal/Wood Cladding	Room D1	Assumed	NF	G	462	SF
			Room D2					
			Room D3					
			A Boy's Restroom					
			A Girl's Restroom					
			Room D4					
			Room D5					
			Room D6					
			Room D7					
			Room D9					
			Room D10					
			Corridor 5					
			Corridor 6					
			Exterior					
M-BUR-132	M	Built-Up Roofing, Black, Asphaltic, Vinyl Cover	Roof	Assumed	NF	G	16,000	SF

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
M-FDI-231	M	Fire Door Insulation, Metal/Wood Cladding	Room E1	Assumed	NF	G	336	SF
			Room E2					
			Room E3					
			Room E4					
			Room E5					
			Room E6					
			E Staff Restroom					
			E Electrical					
			E Storage					
			Corridor 7					
			Corridor 8					
			Corridor 9					
			Corridor 10					
M-BUR-232	M	Built-Up Roofing, Black, Asphaltic, Vinyl Cover	Roof	Assumed	NF	G	13,000	SF

THE ASBESTOS INSTITUTE

Certifies that

Zachary Ridgeway

has attended and received instruction in the EPA approved course

AHERA Building Inspector Initial

on

March 6-8 2023


and successfully completed and passed the competency exam.

Certificate:
4380-15665-030823

Date of Examination:
08-Mar-2023

Date of Expiration:
08-Mar-2024


William T. Caviness
Director


Approved Instructor

THE ASBESTOS INSTITUTE

20033 N. 19th Ave, Building 6, Phoenix, AZ 85027
602-864-6564 – www.theasbestosinstitute.com

This training meets all requirements for asbestos certification under Basic Substance Control Act Title II.