

May 23, 2023

Mr. Matthew Griffin  
Facilities Supervisor  
Kyrene School District No. 28  
8700 South Kyrene Road  
Tempe, AZ 85284-2197

**Subject: 6-Month Surveillance Inspection  
Asbestos-Containing Building Materials  
Kyrene del Sureno Elementary School  
3375 West Galveston Street, Chandler**

Dear Mr. Griffin:

FM GROUP INC has completed the 6-Month Surveillance Inspection of Asbestos-Containing Building Materials (ACBM) at the subject school. The forms detailing the results of this reinspection and reassessment of known ACBM are attached.

The attached tables and forms have been updated to reflect the findings as of the date of this Reinspection and should serve as the Management Plan update.

**Items of significance are: None**

If you have any questions regarding this correspondence, please contact us immediately.

Sincerely,

**FM GROUP INC**



Michael Hall  
Environmental Division Manager



Zach Ridgeway  
AHERA Building Inspector

*Attachments: 6-Month Surveillance Inspection Forms  
6-Month Surveillance Inspection Tables*



## 6-MONTH SURVEILLANCE INSPECTION ASBESTOS-CONTAINING BUILDING MATERIALS

School/Facility: Kyrene del Sureno Elementary School

Inspection Date: 04/07/2023

Building: Main Building

Inspector: Zach Ridgeway Cert. No.: 4380-15665-030823

Signature: 

Material Description	Material Code	Material Observed		Material Condition Status		Material Condition Description (If Change Noted)	Assessment Classification
				Same	Changed		
Adhesive, Brown, Brittle	M-ADH-07	Y	N	x			1 2 3 4 5 6 7*
Mortar (Glass Block), Gray, Cementitious	M-MRT-10	Y	N	x			1 2 3 4 5 6 7*
Fire Door Insulation, Metal Cladding	M-FDI-13	Y	N	x			1 2 3 4 5 6 7*
Fire Door Insulation, Wood Cladding	M-FDI-14	Y	N	x			1 2 3 4 5 6 7*
Glazed Wall Tile, 6"X6", White, Smooth, Various	M-GWT-16	Y	N	x			1 2 3 4 5 6 7*
Grout, Gray, Cementitious	M-GRT-17	Y	N	x			1 2 3 4 5 6 7*
Sink Acoustical Coating, White, Rough	M-SAC-29	Y	N	x			1 2 3 4 5 6 7*
Adhesive (FRP), Brown, Brittle	M-ADH-36	Y	N	x			1 2 3 4 5 6 7*
Sealant, Black, Tar-Like	M-SLT-42	Y	N	x			1 2 3 4 5 6 7*
Glazed Wall Tile, 4"X4", Pink, Smooth, Black And White	M-GWT-43	Y	N	x			1 2 3 4 5 6 7*
Grout, Gray, Cementitious	M-GRT-44	Y	N	x			1 2 3 4 5 6 7*
Ceramic Mosaic Tile, 2"X2", Pink, Smooth	M-CMT-45	Y	N	x			1 2 3 4 5 6 7*
Grout, Gray, Cementitious	M-GRT-46	Y	N	x			1 2 3 4 5 6 7*
Glazed Wall Tile, 4"X4", Blue, Smooth, Black And White	M-GWT-47	Y	N	x			1 2 3 4 5 6 7*
Grout, Gray, Cementitious	M-GRT-48	Y	N	x			1 2 3 4 5 6 7*
Ceramic Mosaic Tile, 2"X2", Blue, Smooth	M-CMT-49	Y	N	x			1 2 3 4 5 6 7*
Grout, Gray, Cementitious	M-GRT-50	Y	N	x			1 2 3 4 5 6 7*
Vinyl Stair Tread, 10"X36", Gray, Vinyl-Like, Circle Pattern	M-VST-56	Y	N	x			1 2 3 4 5 6 7*
Mastic, Yellow, Tacky	M-MAS-57	Y	N	x			1 2 3 4 5 6 7*
Vinyl Composition Tile, 24"X24", Gray, Vinyl-Like, Circle Pattern	M-VCT-59	Y	N	x			1 2 3 4 5 6 7*
Mastic, Yellow, Tacky	M-MAS-60	Y	N	x			1 2 3 4 5 6 7*
Acoustical Ceiling Panel, 2'x4', White, Chalky, Vinyl Cover	M-ACT-62	Y	N	x			1 2 3 4 5 6 7*
Glazed Wall Tile, 4"X6", Pink, Smooth	M-GWT-63	Y	N	x			1 2 3 4 5 6 7*
Grout, Gray, Cementitious	M-GRT-64	Y	N	x			1 2 3 4 5 6 7*
Concrete, Gray, Cementitious	M-CON-65	Y	N	x			1 2 3 4 5 6 7*
Concrete, Gray, Cementitious	M-CON-66	Y	N	x			1 2 3 4 5 6 7*
Stucco, Gray, Cementitious	M-STU-67	Y	N	x			1 2 3 4 5 6 7*
Expansion Joint, Red, Pliable	M-EXJ-68	Y	N	x			1 2 3 4 5 6 7*
Expansion Joint, Brown, Fibrous	*M-EXJ-69	Y	N	x			1 2 3 4 5 6 7*



## 6-MONTH SURVEILLANCE INSPECTION ASBESTOS-CONTAINING BUILDING MATERIALS

Material Description	Material Code	Material Observed		Material Condition Status		Material Condition Description (If Change Noted)	Assessment Classification
				Same	Changed		
Built-Up Roofing, Black, Asphaltic, Gray Mineral Cap	M·BUR·70	Y	N	x			1 2 3 4 5 6 7*
Mastic (Penetrations And Flashings), Black, Brittle	M·MAS·71	Y	N	x			1 2 3 4 5 6 7*
Sealant (Flashing), Gray, Pliable	M·SLT·72	Y	N	x			1 2 3 4 5 6 7*
Gasket, 8", White, Paper-Like	M·GAS·73	Y	N	x			1 2 3 4 5 6 7*
Sealant (Equipment), Black, Tar-Like	M·SLT·74	Y	N	x			1 2 3 4 5 6 7*
Built-Up Roofing, Black, Asphaltic, White Coating	M·BUR·75	Y	N	x			1 2 3 4 5 6 7*
Asphalt Prepared Roofing (Shingles), Black, Asphaltic, Gray Mineral Cap	M·APR·76	Y	N	x			1 2 3 4 5 6 7*
Vapor Barrier Felt, Black, Asphaltic	M·VBF·77	Y	N	x			1 2 3 4 5 6 7*
Built-Up Roofing, Black, Asphaltic, Gray Mineral Cap	M·BUR·122	Y	N	x			1 2 3 4 5 6 7*
Fire Door Insulation, Metal/Wood Cladding	M·FDI·132	Y	N	x			1 2 3 4 5 6 7*
Built-Up Roofing, Back, Asphaltic, Gray Mineral Cap	M·BUR·222	Y	N	x			1 2 3 4 5 6 7*
Fire Door Insulation, Metal/Wood Cladding	M·FDI·232	Y	N	x			1 2 3 4 5 6 7*

**\*Assessment Classifications**

1. Damaged or significantly damaged thermal system insulation ACBM.
2. Damaged friable surfacing ACBM.
3. Significantly damaged friable surfacing ACBM.
4. Damaged or significantly damaged friable miscellaneous ACBM.
5. ACBM with potential for damage.
6. ACBM with potential for significant damage.
7. Any remaining friable ACBM or friable suspected ACBM.

## 6-MONTH SURVEILLANCE INSPECTION TABLE

### IN-PLACE ASBESTOS-CONTAINING MATERIALS

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
M-ADH-07	M	Adhesive, Brown, Brittle	Reception	Assumed	NF	G	3,500	SF
			Hall 1					
			Principal Office					
			Psy/Conf.					
			Faculty Lounge					
			Computer					
			Speech					
			Special Ed. 1					
			Special Ed. 2					
			Special Ed. 3					
			Room 10					
			Room 11					
			Room 12					
			Room 13					
			Room 14					
			Room 15					
			Room 16					
			Room 17					
			Room 18					
			Room 19					
			Room 20					
			Room 21					
			Room 22					
			Room 23					
			Room 24					
			Room 25					
			Room 26					
			Room 27					
			Room 28					
			Room 29					
			Room 30					

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
			Room 31					
			Music					
			Multi-Purpose					
M-MRT-10	M	Mortar (Glass Block), Gray, Cementitious	Reception	Assumed	NF	G	100	SF
			Treatment					
			Nurse's Office					
			Psy/Conf.					
			Faculty Work					
			Computer					
			Special Ed. 1					
			Special Ed. 2					
			Special Ed. 3					
			Room 10					
			Room 11					
			Room 12					
			Room 13					
			Room 14					
			Room 15					
			Room 16					
			Room 17					
			Room 18					
			Room 19					
			Room 20					
			Room 21					
			Room 22					
			Room 23					
			Room 24					
			Room 25					
			Room 26					
			Room 27					
			Room 28					
			Room 29					
			Room 30					

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
			Room 31					
			Multi-Purpose					
			Corridor 3					
			Corridor 4					
			Corridor 5					
			Corridor 6					
			West Foyer					
			Corridor 7					
			Corridor 8					
			Corridor 9					
			Corridor 10					
			East Foyer					
			Corridor 11					
			Corridor 12					
			Corridor 13					
			Exterior					
M-FDI-13	M	Fire Door Insulation, Metal Cladding	Reception	Assumed	NF	G	693	SF
			Treatment					
			West Boy's Restroom					
			West Vestibule					
			Room 10					
			Room 11					
			Multi-Purpose					
			Kitchen					
			Corridor 3					
			Corridor 4					
			Corridor 5					
			Corridor 6					
			Corridor 7					
			Corridor 8					
			Corridor 9					
			Corridor 11					
			Corridor 12					

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
			Corridor 13					
			Exterior					
M-FDI-14	M	Fire Door Insulation, Wood Cladding	Reception	Assumed	NF	G	1,050	SF
			Nurse's Restroom					
			Storage 1					
			North Foyer					
			Men's Restroom					
			Women's Restroom					
			Janitor					
			Library Workroom					
			Server Room					
			Speech					
			Special Ed. 3					
			Test Room					
			Special Ed. 2					
			Special Ed. 1					
			South Boy's Restroom					
			South Girl's Restroom Hall					
			Room 10					
			Room 11					
			Room 12					
			Room 13					
			Room 14					
			Room 15					
			Room 16					
			Room 17					
			Room 18					
			Room 19					
			Room 20					
			Room 21					
			Room 22					
			Room 23					
			Room 24					

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
			Room 25					
			Room 26					
			Room 27					
			Room 28					
			Room 29					
			Room 30					
			Room 31					
			Music					
			Storage 6					
			Multi-Purpose					
			Kitchen Water Heater Closet					
			Storage 4					
			Storage 5					
			Kitchen					
			East Boy's Restroom					
			East Girl's Restroom					
			Corridor 1					
			Corridor 2					
			Corridor 3					
			Corridor 4					
			Corridor 5					
			Corridor 6					
			West Foyer					
			Corridor 7					
			Corridor 8					
			Corridor 9					
			Corridor 10					
			East Foyer					
			Corridor 11					
			Corridor 12					
M-GWT-16	M	Glazed Wall Tile, 6"X6", White, Smooth, Various	Corridor 14	Assumed	NF	G	70	SF
			Corridor 15					
			Corridor 16					



MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
M-GRT-17	M	Grout, Gray, Cementitious	Corridor 14	Assumed	NF	G	7	SF
			Corridor 15					
			Corridor 16					
M-SAC-29	M	Sink Acoustical Coating, White, Rough	North Foyer	Assumed	NF	G	56	SF
			Faculty Lounge					
			Library Workroom					
			Computer					
			Special Ed. 1					
			Special Ed. 2					
			Special Ed. 3					
			Room 12					
			Room 13					
			Room 14					
			Room 15					
			Room 16					
			Room 17					
			Room 18					
			Room 19					
			Room 20					
			Room 21					
			Room 22					
			Room 23					
			Room 24					
			Room 25					
			Room 26					
			Room 27					
			Room 28					
			Room 29					
			Room 30					
			Room 31					

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
			Music					
M-ADH-36	M	Adhesive (FRP), Brown, Brittle	Janitor	Assumed	NF	G	150	SF
			Kitchen					
M-SLT-42	M	Sealant, Black, Tar-Like	Library	Assumed	NF	G	7	SF
			Corridor 5					
			Corridor 13					
			Corridor 15					
M-GWT-43	M	Glazed Wall Tile, 4"X4", Pink, Smooth, Black And White	South Vestibule	Assumed	NF	G	2,000	SF
			South Girl's Restroom					
			West Vestibule					
			West Girl's Restroom					
			East Girl's Restroom					
M-GRT-44	M	Grout, Gray, Cementitious	South Vestibule	Assumed	NF	G	200	SF
			South Girl's Restroom					
			West Vestibule					
			West Girl's Restroom					
			East Girl's Restroom					
M-CMT-45	M	Ceramic Mosaic Tile, 2"X2", Pink, Smooth	South Vestibule	Assumed	NF	G	550	SF
			South Girl's Restroom					
			Room 10 Toilet					
			Room 11 Toilet					
			West Vestibule					
			West Girl's Restroom					
			East Girl's Restroom					
M-GRT-46	M	Grout, Gray, Cementitious	South Vestibule	Assumed	NF	G	55	SF
			South Girl's Restroom					
			Room 10 Toilet					

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
			Room 11 Toilet					
			West Vestibule					
			West Girl's Restroom					
			East Girl's Restroom					
M·GWT·47	M	Glazed Wall Tile, 4"X4", Blue, Smooth, Black And White	South Boy's Restroom	Assumed	NF	G	2,000	SF
			West Boy's Restroom					
			East Boy's Restroom					
M·GRT·48	M	Grout, Gray, Cementitious	South Boy's Restroom	Assumed	NF	G	200	SF
			West Boy's Restroom					
			East Boy's Restroom					
M·CMT·49	M	Ceramic Mosaic Tile, 2"X2", Blue, Smooth	South Boy's Restroom	Assumed	NF	G	550	SF
			West Boy's Restroom					
			East Boy's Restroom					
M·GRT·50	M	Grout, Gray, Cementitious	South Boy's Restroom	Assumed	NF	G	55	SF
			West Boy's Restroom					
			East Boy's Restroom					
M·VST·56	M	Vinyl Stair Tread, 10"X36", Gray, Vinyl-Like, Circle Pattern	North Wing	Assumed	NF	G	30	SF
M·MAS·57	M	Mastic, Yellow, Tacky	North Wing	Assumed	NF	G	30	SF
M·VCT·59	M	Vinyl Composition Tile, 24"X24", Gray, Vinyl-Like, Circle Pattern	Multi-Purpose	Assumed	NF	G	250	SF
M·MAS·60	M	Mastic, Yellow, Tacky	Multi-Purpose	Assumed	NF	G	250	SF
M·ACT·62	M	Acoustical Ceiling Panel, 2'x4', White, Chalky, Vinyl Cover	Kitchen	Assumed	NF	G	500	SF

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
M-GWT-63	M	Glazed Wall Tile, 4"X6", Pink, Smooth	Room 10 Toilet	Assumed	NF	G	10	SF
			Room 11 Toilet					
M-GRT-64	M	Grout, Gray, Cementitious	Room 10 Toilet	Assumed	NF	G	1	SF
			Room 11 Toilet					
M-CON-65	M	Concrete, Gray, Cementitious	Reception	Assumed	NF	G	45,000	SF
			Treatment					
			Nurse's Office					
			Nurse's Restroom					
			Hearing					
			Storage 1					
			Hall 1					
			North Foyer					
			Principal Office					
			Principal's Closet					
			Counselor					
			Psy/Conf.					
			Faculty Work					
			Faculty Lounge					
			Men's Restroom					
			Women's Restroom					
			Storage 2					
			Unisex Restroom					
			Janitor					
			Elec. Closet					
			Library					
			Library Workroom					
			Computer					
			Server Room					
			Speech					
			Storage 3					
			Special Ed. 3					
			Test Room					

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
			Special Ed. 2					
			Special Ed. 1					
			Timeout Room					
			South Boy's Restroom					
			South Vestibule					
			South Girl's Restroom					
			South Water Heater Closet					
			Exterior Electrical Closet					
			South Girl's Restroom Hall					
			Room 10					
			Room 10 Toilet					
			Room 11					
			Room 11 Toilet					
			Room 12					
			Room 13					
			Room 14					
			Room 15					
			West Boy's Restroom					
			West Vestibule					
			West Girl's Restroom					
			West Girl's Restroom Hall					
			West Water Heater Closet					
			Room 16					
			Room 17					
			Room 18					
			Room 19					
			Room 20					
			Room 21					
			Room 22					
			Room 23					
			Room 24					
			Room 25					
			Room 26					
			Room 27					

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
			Room 28					
			Room 29					
			Room 30					
			Room 31					
			Music					
			Storage 6					
			Stage					
			North Wing					
			South Wing					
			Multi-Purpose					
			Kitchen Water Heater Closet					
			Storage 4					
			Storage 5					
			P.E. Office					
			Kitchen					
			East Boy's Restroom					
			East Girl's Restroom					
			Corridor 1					
			Corridor 2					
			Corridor 3					
			Corridor 4					
			Corridor 5					
			Corridor 6					
			West Foyer					
			Corridor 7					
			Corridor 8					
			Corridor 9					
			Corridor 10					
			East Foyer					
			Corridor 11					
			Corridor 12					
			Corridor 13					
			Corridor 14					
			Corridor 15					

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
			Corridor 16					
			Equipment Pad					
			Storage Building					
			Canopy					
M-CON-66	M	Concrete, Gray, Cementitious	Exterior	Assumed	NF	G	18,000	SF
M-STU-67	M	Stucco, Gray, Cementitious	Exterior	Assumed	NF	G	4,000	SF
			Roof					
M-EXJ-68	M	Expansion Joint, Red, Pliable	Library	Assumed	NF	G	100	SF
			Multi-Purpose					
			Corridor 8					
			Corridor 9					
			Corridor 14					
			Corridor 15					
			Corridor 16					
			Equipment Pad					
			Exterior					
			Roof					
M-EXJ-69	M	Expansion Joint, Brown, Fibrous	Exterior <i>sampled 2/4/2021</i>	Assumed	NF	G	500	SF
M-BUR-70	M	Built-Up Roofing, Black, Asphaltic, Gray Mineral Cap	Roof	Assumed	NF	G	42,000	SF
M-MAS-71	M	Mastic (Penetrations And Flashings), Black, Brittle	Roof	Assumed	NF	G	100	SF
M-SLT-72	M	Sealant (Flashing), Gray, Pliable	Roof	Assumed	NF	G	25	SF
M-GAS-73	M	Gasket, 8", White, Paper-Like	Equipment Pad	Assumed	NF	G	5	SF
M-SLT-74	M	Sealant (Equipment), Black, Tar- Like	Equipment Pad	Assumed	NF	G	10	SF

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
M-BUR-75	M	Built-Up Roofing, Black, Asphaltic, White Coating	Canopy	Assumed	NF	G	200	SF
M-APR-76	M	Asphalt Prepared Roofing (Shingles), Black, Asphaltic, Gray Mineral Cap	Storage Building	Assumed	NF	G	300	SF
M-VBF-77	M	Vapor Barrier Felt, Black, Asphaltic	Storage Building	Assumed	NF	G	300	SF
M-BUR-122	M	Built-Up Roofing, Black, Asphaltic, Gray Mineral Cap	Roof	Assumed	NF	G	6,000	SF
M-FDI-132	M	Fire Door Insulation, Metal/Wood Cladding	Classroom 6	Assumed	NF	G	294	SF
			Classroom 7					
			Classroom 8					
			Classroom 9					
			Storage 7					
			Corridor 18					
			Exterior					
M-BUR-222	M	Built-Up Roofing, Back, Asphaltic, Gray Mineral Cap	Roof	Assumed	NF	G	5,000	SF
M-FDI-232	M	Fire Door Insulation, Metal/Wood Cladding	North Boy's Restroom	Assumed	NF	G	252	SF
			North Girl's Restroom					
			Staff Restroom					
			Storage 5					
			Classroom 41					
			Classroom 42					
			Classroom 43					
			Classroom 44					
			Classroom 45					
			Classroom 46					
			Corridor 17					



MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
			Exterior					

**M-ACT-62 Not Found**

# THE ASBESTOS INSTITUTE

*Certifies that*

**Zachary Ridgeway**

has attended and received instruction in the EPA approved course

**AHERA Building Inspector Initial**

on

**March 6-8 2023**


and successfully completed and passed the competency exam.

Certificate:  
4380-15665-030823

Date of Examination:  
08-Mar-2023

Date of Expiration:  
08-Mar-2024

  
William T. Cavness  
Director

  
Approved Instructor

THE ASBESTOS INSTITUTE

20033 N. 19<sup>th</sup> Ave, Building 6, Phoenix, AZ 85027  
602-864-6564 – [www.theasbestosinstitute.com](http://www.theasbestosinstitute.com)

This training meets all requirements for asbestos certification under Basic Substance Control Act Title II.