

May 23, 2023

Mr. Matthew Griffin
Facilities Supervisor
Kyrene School District No. 28
8700 South Kyrene Road
Tempe, AZ 85284-2197

**Subject: 6-Month Surveillance Inspection
Asbestos-Containing Building Materials
Kyrene de la Mariposa Elementary School
50 East Knox Road, Tempe**

Dear Mr. Griffin:

FM GROUP INC has completed the 6-Month Surveillance Inspection of Asbestos-Containing Building Materials (ACBM) at the subject school. The forms detailing the results of this reinspection and reassessment of known ACBM are attached.

The attached tables and forms have been updated to reflect the findings as of the date of this Reinspection and should serve as the Management Plan update.

Items of significance are: None.

If you have any questions regarding this correspondence, please contact us immediately.

Sincerely,

FM GROUP INC



Michael Hall
Environmental Division Manager



Zach Ridgeway
AHERA Building Inspector

*Attachments: 6-Month Surveillance Inspection Forms
6-Month Surveillance Inspection Tables*




6-MONTH SURVEILLANCE INSPECTION ASBESTOS-CONTAINING BUILDING MATERIALS

School/Facility: Kyrene de la Mariposa Elementary School

Inspection Date: 04/12/2023

Building: Main

Inspector: Zach Ridgeway Cert. No.: 4380-15665-030823 Signature: 

| Material Description | Material Code | Material Observed | | Material Condition Status | | Material Condition Description (If Change Noted) | Assessment Classification |
|--|---------------|-------------------|---|---------------------------|---------|--|---------------------------|
| | | | | Same | Changed | | |
| Adhesive (TWP), Brown, Brittle | M-ADH-07 | Y | N | x | | | 1 2 3 4 5 6 7* |
| Fire Door Insulation, Metal Cladding | M-FDI-08 | Y | N | x | | | 1 2 3 4 5 6 7* |
| Fire Door Insulation, Wood Cladding | M-FDI-09 | Y | N | x | | | 1 2 3 4 5 6 7* |
| Sealant, White, Pliable | M-SLT-15 | Y | N | x | | | 1 2 3 4 5 6 7* |
| Mortar (Glass Block), Gray, Cementitious | M-MRT-16 | Y | N | x | | | 1 2 3 4 5 6 7* |
| Pipe End Sealant, White, Pliable | M-PES-23 | Y | N | x | | | 1 2 3 4 5 6 7* |
| Sink Acoustical Coating, White, Rough | M-SAC-26 | Y | N | x | | | 1 2 3 4 5 6 7* |
| Sealant (Duct), Gray, Brittle | M-SLT-30 | Y | N | x | | | 1 2 3 4 5 6 7* |
| Sealant (Fire Stop), Red, Pliable | M-SLT-33 | Y | N | x | | | 1 2 3 4 5 6 7* |
| Glazed Wall Tile, 4"X6", Gray, Smooth | M-GWT-34 | Y | N | x | | | 1 2 3 4 5 6 7* |
| Glazed Wall Tile, 4"X6", Blue, Smooth | M-GWT-35 | Y | N | x | | | 1 2 3 4 5 6 7* |
| Glazed Wall Tile, 4"X6", Pink, Smooth | M-GWT-36 | Y | N | x | | | 1 2 3 4 5 6 7* |
| Grout, Gray, Cementitious | M-GRT-37 | Y | N | x | | | 1 2 3 4 5 6 7* |
| Ceramic Mosaic Tile, 2"X2", Gray, Smooth | M-CMT-38 | Y | N | x | | | 1 2 3 4 5 6 7* |
| Grout, Gray, Cementitious | M-GRT-39 | Y | N | x | | | 1 2 3 4 5 6 7* |
| Sealant, Gray, Pliable | M-SLT-40 | Y | N | x | | | 1 2 3 4 5 6 7* |
| Expansion Joint, Red, Pliable | M-EXJ-43 | Y | N | x | | | 1 2 3 4 5 6 7* |
| Brick, 3"X16", Red, Cementitious | M-BRK-45 | Y | N | x | | | 1 2 3 4 5 6 7* |
| Mortar, Red, Cementitious | M-MRT-46 | Y | N | x | | | 1 2 3 4 5 6 7* |
| Sealant, Brown, Pliable | M-SLT-47 | Y | N | x | | | 1 2 3 4 5 6 7* |
| Sealant, Black, Tar-Like | M-SLT-48 | Y | N | x | | | 1 2 3 4 5 6 7* |
| Vinyl Composition Tile, 2"X24", Black, Smooth, Pattern | M-VCT-50 | Y | N | x | | | 1 2 3 4 5 6 7* |
| Vinyl Composition Tile, 2"X24", Green, Smooth, Pattern | M-VCT-54 | Y | N | x | | | 1 2 3 4 5 6 7* |
| Expansion Joint, Brown, Pliable | M-EXJ-55 | Y | N | x | | | 1 2 3 4 5 6 7* |
| Sink Acoustical Coating, Gray, Rough | M-SAC-63 | Y | N | x | | | 1 2 3 4 5 6 7* |
| Sealant (Flashings), White, Pliable | M-SLT-64 | Y | N | x | | | 1 2 3 4 5 6 7* |
| Mastic (Penetrations And Flashings), Black, Brittle | M-MAS-65 | Y | N | x | | | 1 2 3 4 5 6 7* |
| Asphalt Prepared Roofing (Rolled), Black, Asphaltic, Brown Mineral Cap, Pads | M-APR-66 | Y | N | x | | | 1 2 3 4 5 6 7* |
| Stucco, Gray, Cementitious | S-STU-67 | Y | N | x | | | 1 2 3 4 5 6 7* |



6-MONTH SURVEILLANCE INSPECTION ASBESTOS-CONTAINING BUILDING MATERIALS

| Material Description | Material Code | Material Observed | | Material Condition Status | | Material Condition Description (If Change Noted) | Assessment Classification |
|---|---------------|-------------------|---|---------------------------|---------|---|---------------------------|
| | | | | Same | Changed | | |
| Gypsum Wallboard, White, Chalky | M-GWB-68 | Y | N | x | | | 1 2 3 4 5 6 7* |
| Sealant, Gray, Pliable | M-SLT-69 | Y | N | x | | | 1 2 3 4 5 6 7* |
| Sealant, Black, Pliable | M-SLT-71 | Y | N | x | | | 1 2 3 4 5 6 7* |
| Mastic (Penetrations And Flashing), Black, Tar-Like | M-MAS-72 | Y | N | x | | | 1 2 3 4 5 6 7* |
| Built-Up Roofing, Black, Asphaltic, Metal Cap | M-BUR-73 | Y | N | x | | | 1 2 3 4 5 6 7* |
| Mastic (Penetrations And Flashing), Black, Tar-Like | M-MAS-74 | Y | N | x | | | 1 2 3 4 5 6 7* |
| Sealant (Penetrations And Flashing), White, Pliable | M-SLT-75 | Y | N | x | | | 1 2 3 4 5 6 7* |
| Sealant (Flashings), Gray, Brittle | M-SLT-76 | Y | N | x | | | 1 2 3 4 5 6 7* |
| Sealant (Penetrations), Cream, Tacky | M-SLT-77 | Y | N | x | | | 1 2 3 4 5 6 7* |
| Built-Up Roofing, Black, Asphaltic, Gravel Cap | M-BUR-78 | Y | N | x | | | 1 2 3 4 5 6 7* |
| Sealant, Gray, Pliable | M-SLT-79 | Y | N | x | | | 1 2 3 4 5 6 7* |
| Sealant, Gray, Brittle | M-SLT-80 | Y | N | x | | | 1 2 3 4 5 6 7* |
| Concrete, Gray, Cementitious | M-CON-81 | Y | N | x | | | 1 2 3 4 5 6 7* |
| Concrete Masonry Unit, 8"X16", Gray, Cementitious | M-CMU-82 | Y | N | x | | | 1 2 3 4 5 6 7* |
| Sealant (Mechanical), Black, Tar-Like | M-SLT-83 | Y | N | x | | | 1 2 3 4 5 6 7* |
| Pipe End Sealant, White, Brittle | M-PES-84 | Y | N | x | | | 1 2 3 4 5 6 7* |
| Sealant, White, Pliable | M-SLT-85 | Y | N | x | | | 1 2 3 4 5 6 7* |
| Gasket, 8", Black, Paper-Like | M-GAS-86 | Y | N | x | | | 1 2 3 4 5 6 7* |
| Mortar, Gray, Cementitious | M-MRT-87 | Y | N | x | | | 1 2 3 4 5 6 7* |
| Concrete, Gray, Cementitious | M-CON-88 | Y | N | x | | | 1 2 3 4 5 6 7* |
| Fire Door Insulation, Metal/Wood Cladding | M-FDI-216 | Y | N | x | | | 1 2 3 4 5 6 7* |

*Assessment Classifications

1. Damaged or significantly damaged thermal system insulation ACBM.
2. Damaged friable surfacing ACBM.
3. Significantly damaged friable surfacing ACBM.
4. Damaged or significantly damaged friable miscellaneous ACBM.
5. ACBM with potential for damage.
6. ACBM with potential for significant damage.
7. Any remaining friable ACBM or friable suspected ACBM.




**6-MONTH SURVEILLANCE INSPECTION
ASBESTOS-CONTAINING BUILDING MATERIALS**

School/Facility: Kyrene de la Mariposa Elementary School

Inspection Date: 04/12/2023

Building: Storage Shed

Inspector: Zach Ridgeway Cert. No.: 4380-15665-030823 Signature: 

| Material Description | Material Code | Material Observed | | Material Condition Status | | Material Condition Description (If Change Noted) | Assessment Classification |
|---|---------------|-------------------|---|---------------------------|---------|---|---------------------------|
| | | | | Same | Changed | | |
| Sealant, White, Pliable | M·SLT·01 | Y | N | x | | | 1 2 3 4 5 6 7* |
| Asphalt Prepared Roofing (Shingles), Black, Asphaltic, Gray Mineral Cap | M·APR·02 | Y | N | x | | | 1 2 3 4 5 6 7* |
| Vapor Barrier Felt, Black, Asphaltic | M·VBF·03 | Y | N | x | | | 1 2 3 4 5 6 7* |

***Assessment Classifications**

1. Damaged or significantly damaged thermal system insulation ACBM.
2. Damaged friable surfacing ACBM.
3. Significantly damaged friable surfacing ACBM.
4. Damaged or significantly damaged friable miscellaneous ACBM.
5. ACBM with potential for damage.
6. ACBM with potential for significant damage.
7. Any remaining friable ACBM or friable suspected ACBM.

6-MONTH SURVEILLANCE INSPECTION TABLE

IN-PLACE ASBESTOS-CONTAINING MATERIALS

| MATERIAL SAMPLE CODE | MTL TYPE | MATERIAL DESCRIPTION | MATERIAL LOCATION | ANALYTICAL RESULTS | FRIABILITY | MATERIAL ASSESS. CLASS | MTL QUAN | UNITS |
|----------------------------|-------------|--------------------------------|----------------------|-----------------------|------------|------------------------------|-------------|----------|
| | M/S/T | | | %/ASSUMED | NF/F | G/D/SD | | LF/SF/EA |
| M-ADH-07 | M | Adhesive (TWP), Brown, Brittle | Room 1 | Assumed | NF | G | 740 | SF |
| | | | Room 2 | | | | | |
| | | | Room 3 | | | | | |
| | | | Room 4 | | | | | |
| | | | Room 5 | | | | | |
| | | | Room 6 | | | | | |
| | | | Room 7 | | | | | |
| | | | Room 8 | | | | | |
| | | | Room 9 | | | | | |
| | | | Room 10 | | | | | |
| | | | Room 11 | | | | | |
| | | | Room 12 | | | | | |
| | | | Reception | | | | | |
| | | | School Office | | | | | |
| | | | Conference Room | | | | | |
| | | | Faculty Workroom | | | | | |
| | | | Faculty Lounge | | | | | |
| | | | Room 19 | | | | | |
| | | | Room 20 | | | | | |
| | | | Room 21 | | | | | |
| | | | Room 22 | | | | | |
| | | | Room 23 | | | | | |
| | | | Room 26 | | | | | |
| | | | Room 27 | | | | | |
| | | | Room 28 | | | | | |
| | | | Room 29 | | | | | |
| | | | Room 30 | | | | | |
| | | | Room 31 | | | | | |
| | | | Room 32 | | | | | |

| MATERIAL SAMPLE CODE | MTL TYPE | MATERIAL DESCRIPTION | MATERIAL LOCATION | ANALYTICAL RESULTS | FRIABILITY | MATERIAL ASSESS. CLASS | MTL QUAN | UNITS |
|----------------------------|-------------|---|----------------------|-----------------------|------------|------------------------------|-------------|----------|
| | M/S/T | | | %/ASSUMED | NF/F | G/D/SD | | LF/SF/EA |
| | | | Room 33 | | | | | |
| | | | Room 34 | | | | | |
| | | | Room 38 | | | | | |
| | | | Room 39 | | | | | |
| | | | Music | | | | | |
| M-FDI-08 | M | Fire Door Insulation, Metal Cladding | Room 1 | Assumed | NF | G | 840 | SF |
| | | | Room 2 | | | | | |
| | | | Room 26 | | | | | |
| | | | Girl's West Foyer | | | | | |
| | | | Boy's West Restroom | | | | | |
| | | | Electrical No. 2 | | | | | |
| | | | Reception | | | | | |
| | | | Health Office | | | | | |
| | | | Girl's North Foyer | | | | | |
| | | | Boy's North Restroom | | | | | |
| | | | Ramp | | | | | |
| | | | Multi-Purpose | | | | | |
| | | | Kitchen | | | | | |
| | | | Corridor No. 1 | | | | | |
| | | | Corridor No. 2 | | | | | |
| | | | Corridor No. 3 | | | | | |
| | | | Corridor No. 4 | | | | | |
| | | | Corridor No. 5 | | | | | |
| | | | Corridor No. 7 | | | | | |
| | | | Corridor No. 11 | | | | | |
| M-FDI-09 | M | Fire Door Insulation, Wood Cladding | Room 1 | Assumed | NF | G | 1,554 | SF |
| | | | Room 2 | | | | | |
| | | | Room 3 | | | | | |
| | | | Room 4 | | | | | |
| | | | Room 5 | | | | | |

| MATERIAL SAMPLE CODE | MTL TYPE | MATERIAL DESCRIPTION | MATERIAL LOCATION | ANALYTICAL RESULTS | FRIABILITY | MATERIAL ASSESS. CLASS | MTL QUAN | UNITS |
|----------------------------|-------------|-------------------------|----------------------------|-----------------------|------------|------------------------------|-------------|----------|
| | M/S/T | | | %/ASSUMED | NF/F | G/D/SD | | LF/SF/EA |
| | | | Room 6 | | | | | |
| | | | Girl's West Restroom | | | | | |
| | | | Girl's Restroom West Hall | | | | | |
| | | | Boy's West Restroom | | | | | |
| | | | Water Heater Closet No. 1 | | | | | |
| | | | Room 7 | | | | | |
| | | | Room 8 | | | | | |
| | | | Room 9 | | | | | |
| | | | Room 10 | | | | | |
| | | | Room 11 | | | | | |
| | | | Room 12 | | | | | |
| | | | Reception | | | | | |
| | | | Office Storage No. 2 | | | | | |
| | | | Hall No. 2 | | | | | |
| | | | Faculty Lounge | | | | | |
| | | | Janitor | | | | | |
| | | | Electrical No. 1 | | | | | |
| | | | Library | | | | | |
| | | | Library Workroom | | | | | |
| | | | Audio Visual | | | | | |
| | | | Computer Room | | | | | |
| | | | Room 19 | | | | | |
| | | | Room 20 | | | | | |
| | | | Room 21 | | | | | |
| | | | Room 22 | | | | | |
| | | | Room 23 | | | | | |
| | | | Water Heater Closet No. 2 | | | | | |
| | | | Girl's North Foyer | | | | | |
| | | | Girl's North Restroom | | | | | |
| | | | Girls' North Restroom Hall | | | | | |
| | | | Boy's North Restroom | | | | | |
| | | | Room 26 | | | | | |
| | | | Room 27 | | | | | |

| MATERIAL SAMPLE CODE | MTL TYPE | MATERIAL DESCRIPTION | MATERIAL LOCATION | ANALYTICAL RESULTS | FRIABILITY | MATERIAL ASSESS. CLASS | MTL QUAN | UNITS |
|----------------------------|-------------|-------------------------|---------------------------|-----------------------|------------|------------------------------|-------------|----------|
| | M/S/T | | | %/ASSUMED | NF/F | G/D/SD | | LF/SF/EA |
| | | | Room 28 | | | | | |
| | | | Room 29 | | | | | |
| | | | Room 30 | | | | | |
| | | | Room 31 | | | | | |
| | | | Room 32 | | | | | |
| | | | Room 33 | | | | | |
| | | | Room 34 | | | | | |
| | | | Room 35 | | | | | |
| | | | Room 36 | | | | | |
| | | | Room 37 | | | | | |
| | | | Room 38 | | | | | |
| | | | Room 39 | | | | | |
| | | | Music | | | | | |
| | | | Music Storage | | | | | |
| | | | Multi-Purpose | | | | | |
| | | | Multi-Use Storage | | | | | |
| | | | Water Heater Closet No. 3 | | | | | |
| | | | P.E. Storage | | | | | |
| | | | Kitchen | | | | | |
| | | | Girl's East Restroom | | | | | |
| | | | Boy's East Restroom | | | | | |
| | | | Corridor No. 1 | | | | | |
| | | | Corridor No. 2 | | | | | |
| | | | Corridor No. 3 | | | | | |
| | | | Corridor No. 4 | | | | | |
| | | | Corridor No. 5 | | | | | |
| | | | Corridor No. 6 | | | | | |
| | | | Corridor No. 7 | | | | | |
| | | | Corridor No. 8 | | | | | |
| | | | Corridor No. 9 | | | | | |
| | | | Corridor No. 10 | | | | | |
| | | | Corridor No. 11 | | | | | |
| | | | Corridor No. 12 | | | | | |

| MATERIAL SAMPLE CODE | MTL TYPE | MATERIAL DESCRIPTION | MATERIAL LOCATION | ANALYTICAL RESULTS | FRIABILITY | MATERIAL ASSESS. CLASS | MTL QUAN | UNITS |
|----------------------------|-------------|-------------------------|---------------------------|-----------------------|------------|------------------------------|-------------|----------|
| | M/S/T | | | %/ASSUMED | NF/F | G/D/SD | | LF/SF/EA |
| M-SLT-15 | M | Sealant, White, Pliable | Room 1 | Assumed | NF | G | 130 | SF |
| | | | Room 2 | | | | | |
| | | | Room 2 Restroom | | | | | |
| | | | Room 3 | | | | | |
| | | | Room 4 | | | | | |
| | | | Room 5 | | | | | |
| | | | Room 6 | | | | | |
| | | | Girl's West Foyer | | | | | |
| | | | Girl's West Restroom | | | | | |
| | | | Girl's Restroom West Hall | | | | | |
| | | | Boy's West Restroom | | | | | |
| | | | Water Heater Closet No. 1 | | | | | |
| | | | Room 7 | | | | | |
| | | | Room 8 | | | | | |
| | | | Room 9 | | | | | |
| | | | Room 10 | | | | | |
| | | | Room 11 | | | | | |
| | | | Room 12 | | | | | |
| | | | Electrical No. 2 | | | | | |
| | | | Reception | | | | | |
| | | | School Office | | | | | |
| | | | Health Office | | | | | |
| | | | Treatment | | | | | |
| | | | Hall No. 1 | | | | | |
| | | | Office Storage Room No. 1 | | | | | |
| | | | Fire Riser Room | | | | | |
| | | | Staff Restroom | | | | | |
| | | | Principal | | | | | |
| | | | Hall No. 2 | | | | | |
| | | | Conference Room | | | | | |
| | | | Conference Room Closet | | | | | |
| | | | Staff Women's Restroom | | | | | |

| MATERIAL SAMPLE CODE | MTL TYPE | MATERIAL DESCRIPTION | MATERIAL LOCATION | ANALYTICAL RESULTS | FRIABILITY | MATERIAL ASSESS. CLASS | MTL QUAN | UNITS |
|----------------------------|-------------|-------------------------|----------------------------|-----------------------|------------|------------------------------|-------------|----------|
| | M/S/T | | | %/ASSUMED | NF/F | G/D/SD | | LF/SF/EA |
| | | | Staff Men's Restroom | | | | | |
| | | | Office Storage No. 2 | | | | | |
| | | | Faculty Workroom | | | | | |
| | | | Faculty Lounge | | | | | |
| | | | Phone Room | | | | | |
| | | | Janitor | | | | | |
| | | | Electrical No. 1 | | | | | |
| | | | Library | | | | | |
| | | | Library Work Room | | | | | |
| | | | Audio Visual | | | | | |
| | | | Computer Room | | | | | |
| | | | Room 19 | | | | | |
| | | | Room 20 | | | | | |
| | | | Vestibule | | | | | |
| | | | Speech Office | | | | | |
| | | | Test | | | | | |
| | | | Room 21 | | | | | |
| | | | Timeout | | | | | |
| | | | Room 22 | | | | | |
| | | | Room 23 | | | | | |
| | | | Girl's North Restroom Hall | | | | | |
| | | | Boy's North Restroom | | | | | |
| | | | Room 26 | | | | | |
| | | | Room 27 | | | | | |
| | | | Room 28 | | | | | |
| | | | Room 29 | | | | | |
| | | | Room 30 | | | | | |
| | | | Room 31 | | | | | |
| | | | Room 32 | | | | | |
| | | | Room 33 | | | | | |
| | | | Room 34 | | | | | |
| | | | Room 35 | | | | | |
| | | | Room 36 | | | | | |

| MATERIAL SAMPLE CODE | MTL TYPE | MATERIAL DESCRIPTION | MATERIAL LOCATION | ANALYTICAL RESULTS | FRIABILITY | MATERIAL ASSESS. CLASS | MTL QUAN | UNITS |
|----------------------------|-------------|---|---------------------------|-----------------------|------------|------------------------------|-------------|----------|
| | M/S/T | | | %/ASSUMED | NF/F | G/D/SD | | LF/SF/EA |
| | | | Room 37 | | | | | |
| | | | Room 38 | | | | | |
| | | | Room 39 | | | | | |
| | | | Music | | | | | |
| | | | Music Storage | | | | | |
| | | | Ramp | | | | | |
| | | | Multi-Purpose | | | | | |
| | | | Multi-Use Storage | | | | | |
| | | | Water Heater Closet No. 3 | | | | | |
| | | | P.E. Storage | | | | | |
| | | | Office | | | | | |
| | | | Corridor No. 1 | | | | | |
| | | | Corridor No. 2 | | | | | |
| | | | Corridor No. 3 | | | | | |
| | | | Corridor No. 4 | | | | | |
| | | | Corridor No. 5 | | | | | |
| | | | Corridor No. 7 | | | | | |
| | | | Corridor No. 8 | | | | | |
| | | | Corridor No. 9 | | | | | |
| | | | Corridor No. 10 | | | | | |
| | | | Corridor No. 11 | | | | | |
| | | | Corridor No. 12 | | | | | |
| M-MRT-16 | M | Mortar (Glass Block), Gray, Cementitious | Room 1 | Assumed | NF | G | 200 | SF |
| | | | Room 2 | | | | | |
| | | | Room 3 | | | | | |
| | | | Room 4 | | | | | |
| | | | Room 5 | | | | | |
| | | | Room 6 | | | | | |
| | | | Room 7 | | | | | |
| | | | Room 8 | | | | | |
| | | | Room 9 | | | | | |

| MATERIAL SAMPLE CODE | MTL TYPE | MATERIAL DESCRIPTION | MATERIAL LOCATION | ANALYTICAL RESULTS | FRIABILITY | MATERIAL ASSESS. CLASS | MTL QUAN | UNITS |
|----------------------------|-------------|-------------------------|----------------------|-----------------------|------------|------------------------------|-------------|----------|
| | M/S/T | | | %/ASSUMED | NF/F | G/D/SD | | LF/SF/EA |
| | | | Room 10 | | | | | |
| | | | Room 11 | | | | | |
| | | | Room 12 | | | | | |
| | | | Reception | | | | | |
| | | | Health Office | | | | | |
| | | | Fire Riser Room | | | | | |
| | | | Principal | | | | | |
| | | | Faculty Workroom | | | | | |
| | | | Computer Room | | | | | |
| | | | Room 21 | | | | | |
| | | | Room 22 | | | | | |
| | | | Room 23 | | | | | |
| | | | Room 26 | | | | | |
| | | | Room 27 | | | | | |
| | | | Room 28 | | | | | |
| | | | Room 29 | | | | | |
| | | | Room 30 | | | | | |
| | | | Room 31 | | | | | |
| | | | Room 32 | | | | | |
| | | | Room 33 | | | | | |
| | | | Room 34 | | | | | |
| | | | Room 35 | | | | | |
| | | | Room 36 | | | | | |
| | | | Room 37 | | | | | |
| | | | Room 38 | | | | | |
| | | | Room 39 | | | | | |
| | | | Multi-Purpose Room | | | | | |
| | | | Corridor No. 1 | | | | | |
| | | | Corridor No. 2 | | | | | |
| | | | Corridor No. 3 | | | | | |
| | | | Corridor No. 4 | | | | | |
| | | | Corridor No. 5 | | | | | |
| | | | Corridor No. 7 | | | | | |

| MATERIAL SAMPLE CODE | MTL TYPE | MATERIAL DESCRIPTION | MATERIAL LOCATION | ANALYTICAL RESULTS | FRIABILITY | MATERIAL ASSESS. CLASS | MTL QUAN | UNITS |
|----------------------------|-------------|----------------------------------|---------------------------|-----------------------|------------|------------------------------|-------------|----------|
| | M/S/T | | | %/ASSUMED | NF/F | G/D/SD | | LF/SF/EA |
| | | | Corridor No. 8 | | | | | |
| | | | Corridor No. 9 | | | | | |
| | | | Corridor No. 10 | | | | | |
| | | | Corridor No. 12 | | | | | |
| M-PES-23 | M | Pipe End Sealant, White, Pliable | Room 1 | Assumed | NF | G | 200 | SF |
| | | | Room 1 Restroom | | | | | |
| | | | Room 2 | | | | | |
| | | | Room 2 Restroom | | | | | |
| | | | Room 3 | | | | | |
| | | | Room 4 | | | | | |
| | | | Room 5 | | | | | |
| | | | Room 6 | | | | | |
| | | | Girl's West Foyer | | | | | |
| | | | Girl's West Restroom | | | | | |
| | | | Girl's Restroom West Hall | | | | | |
| | | | Boy's West Restroom | | | | | |
| | | | Water Heater Closet No. 1 | | | | | |
| | | | Room 7 | | | | | |
| | | | Room 8 | | | | | |
| | | | Room 9 | | | | | |
| | | | Room 10 | | | | | |
| | | | Room 11 | | | | | |
| | | | Room 12 | | | | | |
| | | | Electrical No. 2 | | | | | |
| | | | Reception | | | | | |
| | | | School Office | | | | | |
| | | | Health Office | | | | | |
| | | | Treatment | | | | | |
| | | | Hall No. 1 | | | | | |
| | | | Office Storage Room No. 1 | | | | | |
| | | | Fire Riser Room | | | | | |
| | | | Staff Restroom | | | | | |

| MATERIAL SAMPLE CODE | MTL TYPE | MATERIAL DESCRIPTION | MATERIAL LOCATION | ANALYTICAL RESULTS | FRIABILITY | MATERIAL ASSESS. CLASS | MTL QUAN | UNITS |
|----------------------------|-------------|-------------------------|----------------------------|-----------------------|------------|------------------------------|-------------|----------|
| | M/S/T | | | %/ASSUMED | NF/F | G/D/SD | | LF/SF/EA |
| | | | Office No. 1 | | | | | |
| | | | Principal | | | | | |
| | | | Hall No. 2 | | | | | |
| | | | Conference Room | | | | | |
| | | | Conference Room Closet | | | | | |
| | | | Staff Women's Restroom | | | | | |
| | | | Staff Men's Restroom | | | | | |
| | | | Office Storage No. 2 | | | | | |
| | | | Faculty Workroom | | | | | |
| | | | Faculty Lounge | | | | | |
| | | | Phone Room | | | | | |
| | | | Janitor | | | | | |
| | | | Electrical No. 1 | | | | | |
| | | | Library | | | | | |
| | | | Library Workroom | | | | | |
| | | | Audio Visual | | | | | |
| | | | Computer Room | | | | | |
| | | | Room 19 | | | | | |
| | | | Room 20 | | | | | |
| | | | Vestibule | | | | | |
| | | | Speech Office | | | | | |
| | | | Test | | | | | |
| | | | Room 21 | | | | | |
| | | | Timeout | | | | | |
| | | | Room 22 | | | | | |
| | | | Room 23 | | | | | |
| | | | Water Heater Closet No. 2 | | | | | |
| | | | Girl's North Foyer | | | | | |
| | | | Girl's North Restroom | | | | | |
| | | | Girl's North Restroom Hall | | | | | |
| | | | Boy's North Restroom | | | | | |
| | | | Room 26 | | | | | |
| | | | Room 27 | | | | | |

| MATERIAL SAMPLE CODE | MTL TYPE | MATERIAL DESCRIPTION | MATERIAL LOCATION | ANALYTICAL RESULTS | FRIABILITY | MATERIAL ASSESS. CLASS | MTL QUAN | UNITS |
|----------------------------|-------------|-------------------------|---------------------------|-----------------------|------------|------------------------------|-------------|----------|
| | M/S/T | | | %/ASSUMED | NF/F | G/D/SD | | LF/SF/EA |
| | | | Room 28 | | | | | |
| | | | Room 29 | | | | | |
| | | | Room 30 | | | | | |
| | | | Room 31 | | | | | |
| | | | Room 32 | | | | | |
| | | | Room 33 | | | | | |
| | | | Room 34 | | | | | |
| | | | Room 35 | | | | | |
| | | | Room 36 | | | | | |
| | | | Room 37 | | | | | |
| | | | Room 38 | | | | | |
| | | | Room 39 | | | | | |
| | | | Music | | | | | |
| | | | Music Storage | | | | | |
| | | | Stage | | | | | |
| | | | Stage Wing | | | | | |
| | | | Ramp | | | | | |
| | | | Multi-Purpose | | | | | |
| | | | Multi-Use Storage | | | | | |
| | | | Water Heater Closet No. 3 | | | | | |
| | | | P.E. Storage | | | | | |
| | | | Office | | | | | |
| | | | Kitchen | | | | | |
| | | | Girl's East Restroom | | | | | |
| | | | Boy's East Restroom | | | | | |
| | | | Corridor No. 1 | | | | | |
| | | | Corridor No. 2 | | | | | |
| | | | Corridor No. 3 | | | | | |
| | | | Corridor No. 4 | | | | | |
| | | | Corridor No. 5 | | | | | |
| | | | Corridor No. 6 | | | | | |
| | | | Corridor No. 7 | | | | | |
| | | | Corridor No. 8 | | | | | |

| MATERIAL SAMPLE CODE | MTL TYPE | MATERIAL DESCRIPTION | MATERIAL LOCATION | ANALYTICAL RESULTS | FRIABILITY | MATERIAL ASSESS. CLASS | MTL QUAN | UNITS |
|----------------------------|-------------|--|----------------------|-----------------------|------------|------------------------------|-------------|----------|
| | M/S/T | | | %/ASSUMED | NF/F | G/D/SD | | LF/SF/EA |
| | | | Corridor No. 9 | | | | | |
| | | | Corridor No. 10 | | | | | |
| | | | Corridor No. 11 | | | | | |
| | | | Corridor No. 12 | | | | | |
| M-SAC-26 | M | Sink Acoustical Coating, White, Rough | Room 1 | Assumed | NF | G | 165 | SF |
| | | | Room 2 | | | | | |
| | | | Room 3 | | | | | |
| | | | Room 4 | | | | | |
| | | | Room 5 | | | | | |
| | | | Room 6 | | | | | |
| | | | Room 7 | | | | | |
| | | | Room 8 | | | | | |
| | | | Room 9 | | | | | |
| | | | Room 10 | | | | | |
| | | | Room 11 | | | | | |
| | | | Room 12 | | | | | |
| | | | Room 20 | | | | | |
| | | | Room 21 | | | | | |
| | | | Room 22 | | | | | |
| | | | Room 23 | | | | | |
| | | | Room 26 | | | | | |
| | | | Room 27 | | | | | |
| | | | Room 28 | | | | | |
| | | | Room 29 | | | | | |
| | | | Room 30 | | | | | |
| | | | Room 31 | | | | | |
| | | | Room 32 | | | | | |
| | | | Room 33 | | | | | |
| | | | Room 34 | | | | | |
| | | | Room 35 | | | | | |
| | | | Faculty Lounge | | | | | |

| MATERIAL SAMPLE CODE | MTL TYPE | MATERIAL DESCRIPTION | MATERIAL LOCATION | ANALYTICAL RESULTS | FRIABILITY | MATERIAL ASSESS. CLASS | MTL QUAN | UNITS |
|----------------------------|-------------|-------------------------------|---------------------------|-----------------------|------------|------------------------------|-------------|----------|
| | M/S/T | | | %/ASSUMED | NF/F | G/D/SD | | LF/SF/EA |
| | | | Computer Room | | | | | |
| | | | Library Workroom | | | | | |
| | | | Music | | | | | |
| | | | | | | | | |
| M-SLT-30 | M | Sealant (Duct), Gray, Brittle | Room 1 | Assumed | NF | G | 500 | SF |
| | | | Room 1 Restroom | | | | | |
| | | | Room 2 | | | | | |
| | | | Room 2 Restroom | | | | | |
| | | | Room 3 | | | | | |
| | | | Room 4 | | | | | |
| | | | Room 5 | | | | | |
| | | | Room 6 | | | | | |
| | | | Girl's West Foyer | | | | | |
| | | | Girl's West Restroom | | | | | |
| | | | Girl's Restroom West Hall | | | | | |
| | | | Boy's West Restroom | | | | | |
| | | | Water Heater Closet No. 1 | | | | | |
| | | | Room 7 | | | | | |
| | | | Room 8 | | | | | |
| | | | Room 9 | | | | | |
| | | | Room 10 | | | | | |
| | | | Room 11 | | | | | |
| | | | Room 12 | | | | | |
| | | | Electrical No. 2 | | | | | |
| | | | Reception | | | | | |
| | | | School Office | | | | | |
| | | | Health Office | | | | | |
| | | | Treatment | | | | | |
| | | | Hall No. 1 | | | | | |
| | | | Office Storage Room No. 1 | | | | | |
| | | | Fire Riser Room | | | | | |
| | | | Staff Restroom | | | | | |
| | | | Office No. 1 | | | | | |

| MATERIAL SAMPLE CODE | MTL TYPE | MATERIAL DESCRIPTION | MATERIAL LOCATION | ANALYTICAL RESULTS | FRIABILITY | MATERIAL ASSESS. CLASS | MTL QUAN | UNITS |
|----------------------------|-------------|-------------------------|----------------------------|-----------------------|------------|------------------------------|-------------|----------|
| | M/S/T | | | %/ASSUMED | NF/F | G/D/SD | | LF/SF/EA |
| | | | Principal | | | | | |
| | | | Hall No. 2 | | | | | |
| | | | Conference Room | | | | | |
| | | | Conference Room Closet | | | | | |
| | | | Staff Women's Restroom | | | | | |
| | | | Staff Men's Restroom | | | | | |
| | | | Office Storage No. 2 | | | | | |
| | | | Faculty Workroom | | | | | |
| | | | Faculty Lounge | | | | | |
| | | | Phone Room | | | | | |
| | | | Janitor | | | | | |
| | | | Electrical No. 1 | | | | | |
| | | | Library | | | | | |
| | | | Library Workroom | | | | | |
| | | | Audio Visual | | | | | |
| | | | Computer Room | | | | | |
| | | | Room 19 | | | | | |
| | | | Room 20 | | | | | |
| | | | Vestibule | | | | | |
| | | | Speech Office | | | | | |
| | | | Test | | | | | |
| | | | Room 21 | | | | | |
| | | | Timeout | | | | | |
| | | | Room 22 | | | | | |
| | | | Room 23 | | | | | |
| | | | Water Heater Closet No. 2 | | | | | |
| | | | Girl's North Foyer | | | | | |
| | | | Girl's North Restroom | | | | | |
| | | | Girl's North Restroom Hall | | | | | |
| | | | Boy's North Restroom | | | | | |
| | | | Room 26 | | | | | |
| | | | Room 27 | | | | | |
| | | | Room 28 | | | | | |

| MATERIAL SAMPLE CODE | MTL TYPE | MATERIAL DESCRIPTION | MATERIAL LOCATION | ANALYTICAL RESULTS | FRIABILITY | MATERIAL ASSESS. CLASS | MTL QUAN | UNITS |
|----------------------------|-------------|-------------------------|---------------------------|-----------------------|------------|------------------------------|-------------|----------|
| | M/S/T | | | %/ASSUMED | NF/F | G/D/SD | | LF/SF/EA |
| | | | Room 29 | | | | | |
| | | | Room 30 | | | | | |
| | | | Room 31 | | | | | |
| | | | Room 32 | | | | | |
| | | | Room 33 | | | | | |
| | | | Room 34 | | | | | |
| | | | Room 35 | | | | | |
| | | | Room 36 | | | | | |
| | | | Room 37 | | | | | |
| | | | Room 38 | | | | | |
| | | | Room 39 | | | | | |
| | | | Music | | | | | |
| | | | Music Storage | | | | | |
| | | | Stage | | | | | |
| | | | Stage Wing | | | | | |
| | | | Ramp | | | | | |
| | | | Multi-Purpose | | | | | |
| | | | Multi-Use Storage | | | | | |
| | | | Water Heater Closet No. 3 | | | | | |
| | | | P.E. Storage | | | | | |
| | | | Office | | | | | |
| | | | Kitchen | | | | | |
| | | | Girl's East Restroom | | | | | |
| | | | Boy's East Restroom | | | | | |
| | | | Corridor No. 1 | | | | | |
| | | | Corridor No. 2 | | | | | |
| | | | Corridor No. 3 | | | | | |
| | | | Corridor No. 4 | | | | | |
| | | | Corridor No. 5 | | | | | |
| | | | Corridor No. 6 | | | | | |
| | | | Corridor No. 7 | | | | | |
| | | | Corridor No. 8 | | | | | |
| | | | Corridor No. 9 | | | | | |

| MATERIAL SAMPLE CODE | MTL TYPE | MATERIAL DESCRIPTION | MATERIAL LOCATION | ANALYTICAL RESULTS | FRIABILITY | MATERIAL ASSESS. CLASS | MTL QUAN | UNITS |
|----------------------------|-------------|-----------------------------------|---------------------------|-----------------------|------------|------------------------------|-------------|----------|
| | M/S/T | | | %/ASSUMED | NF/F | G/D/SD | | LF/SF/EA |
| | | | Corridor No. 10 | | | | | |
| | | | Corridor No. 11 | | | | | |
| | | | Corridor No. 12 | | | | | |
| M-SLT-33 | M | Sealant (Fire Stop), Red, Pliable | Room 1 | Assumed | NF | G | 5 | SF |
| | | | Room 1 Restroom | | | | | |
| | | | Room 2 | | | | | |
| | | | Room 2 Restroom | | | | | |
| | | | Room 3 | | | | | |
| | | | Room 4 | | | | | |
| | | | Room 5 | | | | | |
| | | | Room 6 | | | | | |
| | | | Girl's West Foyer | | | | | |
| | | | Girl's West Restroom | | | | | |
| | | | Girl's Restroom West Hall | | | | | |
| | | | Boy's West Restroom | | | | | |
| | | | Water Heater Closet No. 1 | | | | | |
| | | | Room 7 | | | | | |
| | | | Room 8 | | | | | |
| | | | Room 9 | | | | | |
| | | | Room 10 | | | | | |
| | | | Room 11 | | | | | |
| | | | Room 12 | | | | | |
| | | | Electrical No. 2 | | | | | |
| | | | Reception | | | | | |
| | | | School Office | | | | | |
| | | | Health Office | | | | | |
| | | | Treatment | | | | | |
| | | | Hall No. 1 | | | | | |
| | | | Office Storage Room No. 1 | | | | | |
| | | | Fire Riser Room | | | | | |
| | | | Staff Restroom | | | | | |
| | | | Office No. 1 | | | | | |

| MATERIAL SAMPLE CODE | MTL TYPE | MATERIAL DESCRIPTION | MATERIAL LOCATION | ANALYTICAL RESULTS | FRIABILITY | MATERIAL ASSESS. CLASS | MTL QUAN | UNITS |
|----------------------------|-------------|-------------------------|----------------------------|-----------------------|------------|------------------------------|-------------|----------|
| | M/S/T | | | %/ASSUMED | NF/F | G/D/SD | | LF/SF/EA |
| | | | Principal | | | | | |
| | | | Hall No. 2 | | | | | |
| | | | Conference Room | | | | | |
| | | | Conference Room Closet | | | | | |
| | | | Staff Women's Restroom | | | | | |
| | | | Staff Men's Restroom | | | | | |
| | | | Office Storage No. 2 | | | | | |
| | | | Faculty Workroom | | | | | |
| | | | Faculty Lounge | | | | | |
| | | | Phone Room | | | | | |
| | | | Janitor | | | | | |
| | | | Electrical No. 1 | | | | | |
| | | | Library | | | | | |
| | | | Library Workroom | | | | | |
| | | | Audio Visual | | | | | |
| | | | Computer Room | | | | | |
| | | | Room 19 | | | | | |
| | | | Room 20 | | | | | |
| | | | Vestibule | | | | | |
| | | | Speech Office | | | | | |
| | | | Test | | | | | |
| | | | Room 21 | | | | | |
| | | | Timeout | | | | | |
| | | | Room 22 | | | | | |
| | | | Room 23 | | | | | |
| | | | Water Heater Closet No. 2 | | | | | |
| | | | Girl's North Foyer | | | | | |
| | | | Girl's North Restroom | | | | | |
| | | | Girl's North Restroom Hall | | | | | |
| | | | Boy's North Restroom | | | | | |
| | | | Room 26 | | | | | |
| | | | Room 27 | | | | | |
| | | | Room 28 | | | | | |

| MATERIAL SAMPLE CODE | MTL TYPE | MATERIAL DESCRIPTION | MATERIAL LOCATION | ANALYTICAL RESULTS | FRIABILITY | MATERIAL ASSESS. CLASS | MTL QUAN | UNITS |
|----------------------------|-------------|-------------------------|---------------------------|-----------------------|------------|------------------------------|-------------|----------|
| | M/S/T | | | %/ASSUMED | NF/F | G/D/SD | | LF/SF/EA |
| | | | Room 29 | | | | | |
| | | | Room 30 | | | | | |
| | | | Room 31 | | | | | |
| | | | Room 32 | | | | | |
| | | | Room 33 | | | | | |
| | | | Room 34 | | | | | |
| | | | Room 35 | | | | | |
| | | | Room 36 | | | | | |
| | | | Room 37 | | | | | |
| | | | Room 38 | | | | | |
| | | | Room 39 | | | | | |
| | | | Music | | | | | |
| | | | Music Storage | | | | | |
| | | | Stage | | | | | |
| | | | Stage Wing | | | | | |
| | | | Ramp | | | | | |
| | | | Multi-Purpose | | | | | |
| | | | Multi-Use Storage | | | | | |
| | | | Water Heater Closet No. 3 | | | | | |
| | | | P.E. Storage | | | | | |
| | | | Office | | | | | |
| | | | Kitchen | | | | | |
| | | | Girl's East Restroom | | | | | |
| | | | Boy's East Restroom | | | | | |
| | | | Corridor No. 1 | | | | | |
| | | | Corridor No. 2 | | | | | |
| | | | Corridor No. 3 | | | | | |
| | | | Corridor No. 4 | | | | | |
| | | | Corridor No. 5 | | | | | |
| | | | Corridor No. 6 | | | | | |
| | | | Corridor No. 7 | | | | | |
| | | | Corridor No. 8 | | | | | |
| | | | Corridor No. 9 | | | | | |

| MATERIAL SAMPLE CODE | MTL TYPE | MATERIAL DESCRIPTION | MATERIAL LOCATION | ANALYTICAL RESULTS | FRIABILITY | MATERIAL ASSESS. CLASS | MTL QUAN | UNITS |
|----------------------------|-------------|--|-----------------------|-----------------------|------------|------------------------------|-------------|----------|
| | M/S/T | | | %/ASSUMED | NF/F | G/D/SD | | LF/SF/EA |
| | | | Corridor No. 10 | | | | | |
| | | | Corridor No. 11 | | | | | |
| | | | Corridor No. 12 | | | | | |
| M-GWT-34 | M | Glazed Wall Tile, 4"X6", Gray, Smooth | Girl's West Foyer | Assumed | NF | G | 2,000 | SF |
| | | | Girl's West Restroom | | | | | |
| | | | Boy's West Restroom | | | | | |
| | | | Girl's North Foyer | | | | | |
| | | | Girl's North Restroom | | | | | |
| | | | Boy's North Restroom | | | | | |
| | | | Girl's East Restroom | | | | | |
| | | | Boy's East Restroom | | | | | |
| M-GWT-35 | M | Glazed Wall Tile, 4"X6", Blue, Smooth | Girl's West Foyer | Assumed | NF | G | 100 | SF |
| | | | Girl's West Restroom | | | | | |
| | | | Boy's West Restroom | | | | | |
| | | | Girl's North Foyer | | | | | |
| | | | Girl's North Restroom | | | | | |
| | | | Boy's North Restroom | | | | | |
| | | | Girl's East Restroom | | | | | |
| | | | Boy's East Restroom | | | | | |
| M-GWT-36 | M | Glazed Wall Tile, 4"X6", Pink, Smooth | Girl's West Foyer | Assumed | NF | G | 100 | SF |
| | | | Girl's West Restroom | | | | | |
| | | | Boy's West Restroom | | | | | |
| | | | Girl's North Foyer | | | | | |
| | | | Girl's North Restroom | | | | | |
| | | | Boy's North Restroom | | | | | |
| | | | Girl's East Restroom | | | | | |
| | | | Boy's East Restroom | | | | | |

| MATERIAL SAMPLE CODE | MTL TYPE | MATERIAL DESCRIPTION | MATERIAL LOCATION | ANALYTICAL RESULTS | FRIABILITY | MATERIAL ASSESS. CLASS | MTL QUAN | UNITS |
|----------------------------|-------------|--|-----------------------|-----------------------|------------|------------------------------|-------------|----------|
| | M/S/T | | | %/ASSUMED | NF/F | G/D/SD | | LF/SF/EA |
| M-GRT-37 | M | Grout, Gray, Cementitious | Girl's West Foyer | Assumed | NF | G | 220 | SF |
| | | | Girl's West Restroom | | | | | |
| | | | Boy's West Restroom | | | | | |
| | | | Girl's North Foyer | | | | | |
| | | | Girl's North Restroom | | | | | |
| | | | Boy's North Restroom | | | | | |
| | | | Girl's East Restroom | | | | | |
| | | | Boy's East Restroom | | | | | |
| M-CMT-38 | M | Ceramic Mosaic Tile, 2"X2", Gray, Smooth | Girl's West Foyer | Assumed | NF | G | 1,500 | SF |
| | | | Girl's West Restroom | | | | | |
| | | | Boy's West Restroom | | | | | |
| | | | Girl's North Foyer | | | | | |
| | | | Girl's North Restroom | | | | | |
| | | | Boy's North Restroom | | | | | |
| | | | Girl's East Restroom | | | | | |
| | | | Boy's East Restroom | | | | | |
| M-GRT-39 | M | Grout, Gray, Cementitious | Girl's West Foyer | Assumed | NF | G | 150 | SF |
| | | | Girl's West Restroom | | | | | |
| | | | Boy's West Restroom | | | | | |
| | | | Girl's North Foyer | | | | | |
| | | | Girl's North Restroom | | | | | |
| | | | Boy's North Restroom | | | | | |
| | | | Girl's East Restroom | | | | | |
| | | | Boy's East Restroom | | | | | |
| M-SLT-40 | M | Sealant, Gray, Pliable | Girl's West Restroom | Assumed | NF | G | 8 | SF |
| | | | Boy's West Restroom | | | | | |
| | | | Girl's North Restroom | | | | | |
| | | | Boy's North Restroom | | | | | |
| | | | Girl's East Restroom | | | | | |

| MATERIAL SAMPLE CODE | MTL TYPE | MATERIAL DESCRIPTION | MATERIAL LOCATION | ANALYTICAL RESULTS | FRIABILITY | MATERIAL ASSESS. CLASS | MTL QUAN | UNITS |
|----------------------------|-------------|---|----------------------|-----------------------|------------|------------------------------|-------------|----------|
| | M/S/T | | | %/ASSUMED | NF/F | G/D/SD | | LF/SF/EA |
| | | | Boy's East Restroom | | | | | |
| M-EXJ-43 | M | Expansion Joint, Red, Pliable <i>Sampled 2/16/2021</i> | Exterior | Assumed | NF | G | 8 | SF |
| M-BRK-45 | M | Brick, 3"X16", Red, Cementitious | Library | Assumed | NF | G | 23,000 | SF |
| | | | Multi-Purpose | | | | | |
| | | | Corridor 7 | | | | | |
| | | | Exterior | | | | | |
| M-MRT-46 | M | Mortar, Red, Cementitious | Library | Assumed | NF | G | 2,300 | SF |
| | | | Multi-Purpose | | | | | |
| | | | Corridor 7 | | | | | |
| | | | Exterior | | | | | |
| M-SLT-47 | M | Sealant, Brown, Pliable | Library | Assumed | NF | G | 5 | SF |
| | | | Room 21 | | | | | |
| | | | Corridor 1 | | | | | |
| | | | Corridor 11 | | | | | |
| M-SLT-48 | M | Sealant, Black, Tar-Like | Library | Assumed | NF | G | 7 | SF |
| | | | Room 20 | | | | | |
| | | | Corridor 5 | | | | | |
| | | | Corridor 8 | | | | | |
| M-VCT-50 | M | Vinyl Composition Tile, 2"X24", Black, Smooth, Pattern | Multi-Purpose | Assumed | NF | G | 200 | SF |
| M-VCT-54 | M | Vinyl Composition Tile, 2"X24", Green, Smooth, Pattern | Multi-Purpose | Assumed | NF | G | 100 | SF |
| M-EXJ-55 | M | Expansion Joint, Brown, Pliable | Multi-Purpose | Assumed | NF | G | 33 | SF |
| | | | Kitchen | | | | | |
| | | | Exterior | | | | | |

| MATERIAL SAMPLE CODE | MTL TYPE | MATERIAL DESCRIPTION | MATERIAL LOCATION | ANALYTICAL RESULTS | FRIABILITY | MATERIAL ASSESS. CLASS | MTL QUAN | UNITS |
|----------------------------|-------------|--|-------------------------|-----------------------|------------|------------------------------|-------------|----------|
| | M/S/T | | | %/ASSUMED | NF/F | G/D/SD | | LF/SF/EA |
| M-SAC-63 | M | Sink Acoustical Coating, Gray, Rough | Room 36 | Assumed | NF | G | 8 | SF |
| | | | Room 37 | | | | | |
| | | | Room 38 | | | | | |
| | | | Room 39 | | | | | |
| M-SLT-64 | M | Sealant (Flashings), White, Pliable | Main Roof | Assumed | NF | G | 50 | SF |
| M-MAS-65 | M | Mastic (Penetrations And Flashings), Black, Brittle | Main Roof | Assumed | NF | G | 1,300 | SF |
| M-APR-66 | M | Asphalt Prepared Roofing (Rolled), Black, Asphaltic, Brown Mineral Cap, Pads | Main Roof | Assumed | NF | G | 850 | SF |
| S-STU-67 | S | Stucco, Gray, Cementitious | Main Roof | Assumed | NF | G | 4,200 | SF |
| | | | Exterior | | | | | |
| M-GWB-68 | M | Gypsum Wallboard, White, Chalky | Main Roof | Assumed | NF | G | 4,200 | SF |
| | | | Exterior | | | | | |
| M-SLT-69 | M | Sealant, Gray, Pliable | Roof-Mounted HVAC Units | Assumed | NF | G | 15 | SF |
| M-SLT-71 | M | Sealant, Black, Pliable | Main Roof | Assumed | NF | G | 10 | SF |
| M-MAS-72 | M | Mastic (Penetrations And Flashing), Black, Tar-Like | Main Roof | Assumed | NF | G | 250 | SF |
| M-BUR-73 | M | Built-Up Roofing, Black, Asphaltic, Metal Cap | Main Roof | Assumed | NF | G | 3,000 | SF |
| M-MAS-74 | M | Mastic (Penetrations And Flashing), Black, Tar-Like | Main Roof | Assumed | NF | G | 300 | SF |
| M-SLT-75 | M | Sealant (Penetrations And Flashing), White, Pliable | Main Roof | Assumed | NF | G | 50 | SF |

| MATERIAL SAMPLE CODE | MTL TYPE | MATERIAL DESCRIPTION | MATERIAL LOCATION | ANALYTICAL RESULTS | FRIABILITY | MATERIAL ASSESS. CLASS | MTL QUAN | UNITS |
|----------------------------|-------------|---|------------------------|-----------------------|------------|------------------------------|-------------|----------|
| | M/S/T | | | %/ASSUMED | NF/F | G/D/SD | | LF/SF/EA |
| M-SLT-76 | M | Sealant (Flashings), Gray, Brittle | Entry Roofs Throughout | Assumed | NF | G | 20 | SF |
| M-SLT-77 | M | Sealant (Penetrations), Cream, Tacky | Main Roof | Assumed | NF | G | 5 | SF |
| M-BUR-78 | M | Built-Up Roofing, Black, Asphaltic, Gravel Cap | Main Roof | Assumed | NF | G | 41,300 | SF |
| M-SLT-79 | M | Sealant, Gray, Pliable | Exterior | Assumed | NF | G | 10 | SF |
| M-SLT-80 | M | Sealant, Gray, Brittle | Exterior | Assumed | NF | G | 5 | SF |
| M-CON-81 | M | Concrete, Gray, Cementitious <i>Sampled 2/16/2021</i> | Exterior | Assumed | NF | G | 26,100 | SF |
| M-CMU-82 | M | Concrete Masonry Unit, 8"X16", Gray, Cementitious <i>Sampled 2/16/2021</i> | Exterior | Assumed | NF | G | 20 | SF |
| M-SLT-83 | M | Sealant (Mechanical), Black, Tar-Like | Equipment Well | Assumed | NF | G | 15 | SF |
| M-PES-84 | M | Pipe End Sealant, White, Brittle | Equipment Well | Assumed | NF | G | 2 | SF |
| M-SLT-85 | M | Sealant, White, Pliable | Equipment Well | Assumed | NF | G | 4 | SF |
| M-GAS-86 | M | Gasket, 8", Black, Paper-Like | Equipment Well | Assumed | NF | G | 4 | SF |
| M-MRT-87 | M | Mortar, Gray, Cementitious <i>Sampled 2/16/2021</i> | Exterior | Assumed | NF | G | 2 | SF |
| M-CON-88 | M | Concrete, Gray, Cementitious | Room 1 | Assumed | NF | G | 55,000 | SF |
| | | | Room 1 Restroom | | | | | |
| | | | Room 2 | | | | | |
| | | | Room 2 Restroom | | | | | |

| MATERIAL SAMPLE CODE | MTL TYPE | MATERIAL DESCRIPTION | MATERIAL LOCATION | ANALYTICAL RESULTS | FRIABILITY | MATERIAL ASSESS. CLASS | MTL QUAN | UNITS |
|----------------------------|-------------|-------------------------|---------------------------|-----------------------|------------|------------------------------|-------------|----------|
| | M/S/T | | | %/ASSUMED | NF/F | G/D/SD | | LF/SF/EA |
| | | | Room 3 | | | | | |
| | | | Room 4 | | | | | |
| | | | Room 5 | | | | | |
| | | | Room 6 | | | | | |
| | | | Girl's West Foyer | | | | | |
| | | | Girl's West Restroom | | | | | |
| | | | Girl's Restroom West Hall | | | | | |
| | | | Boy's West Foyer | | | | | |
| | | | Water Heater Closet No. 1 | | | | | |
| | | | Room 7 | | | | | |
| | | | Room 8 | | | | | |
| | | | Room 9 | | | | | |
| | | | Room 10 | | | | | |
| | | | Room 11 | | | | | |
| | | | Room 12 | | | | | |
| | | | Electrical No. 2 | | | | | |
| | | | Reception | | | | | |
| | | | School Office | | | | | |
| | | | Health Office | | | | | |
| | | | Treatment | | | | | |
| | | | Hall No. 1 | | | | | |
| | | | Office Storage Room No. 1 | | | | | |
| | | | Fire Riser Room | | | | | |
| | | | Staff Restroom | | | | | |
| | | | Office No. 1 | | | | | |
| | | | Principal | | | | | |
| | | | Hall No. 2 | | | | | |
| | | | Conference Room | | | | | |
| | | | Conference Room Closet | | | | | |
| | | | Staff Women's Restroom | | | | | |
| | | | Staff Men's Restroom | | | | | |
| | | | Office Storage No. 2 | | | | | |
| | | | Faculty Workroom | | | | | |

| MATERIAL SAMPLE CODE | MTL TYPE | MATERIAL DESCRIPTION | MATERIAL LOCATION | ANALYTICAL RESULTS | FRIABILITY | MATERIAL ASSESS. CLASS | MTL QUAN | UNITS |
|----------------------------|-------------|-------------------------|----------------------------|-----------------------|------------|------------------------------|-------------|----------|
| | M/S/T | | | %/ASSUMED | NF/F | G/D/SD | | LF/SF/EA |
| | | | Faculty Lounge | | | | | |
| | | | Phone Room | | | | | |
| | | | Janitor | | | | | |
| | | | Electrical No. 1 | | | | | |
| | | | Library | | | | | |
| | | | Library Workroom | | | | | |
| | | | Audio Visual | | | | | |
| | | | Computer Room | | | | | |
| | | | Room 19 | | | | | |
| | | | Room 20 | | | | | |
| | | | Vestibule | | | | | |
| | | | Speech Office | | | | | |
| | | | Test | | | | | |
| | | | Room 21 | | | | | |
| | | | Timeout | | | | | |
| | | | Room 22 | | | | | |
| | | | Room 23 | | | | | |
| | | | Water Heater Closet No. 2 | | | | | |
| | | | Girl's North Foyer | | | | | |
| | | | Girl's North Restroom | | | | | |
| | | | Girl's North Restroom Hall | | | | | |
| | | | Boy's North Restroom | | | | | |
| | | | Room 26 | | | | | |
| | | | Room 27 | | | | | |
| | | | Room 28 | | | | | |
| | | | Room 29 | | | | | |
| | | | Room 30 | | | | | |
| | | | Room 31 | | | | | |
| | | | Room 32 | | | | | |
| | | | Room 33 | | | | | |
| | | | Room 34 | | | | | |
| | | | Room 35 | | | | | |
| | | | Room 36 | | | | | |

| MATERIAL SAMPLE CODE | MTL TYPE | MATERIAL DESCRIPTION | MATERIAL LOCATION | ANALYTICAL RESULTS | FRIABILITY | MATERIAL ASSESS. CLASS | MTL QUAN | UNITS |
|----------------------------|-------------|---|---------------------------|-----------------------|------------|------------------------------|-------------|----------|
| | M/S/T | | | %/ASSUMED | NF/F | G/D/SD | | LF/SF/EA |
| | | | Room 37 | | | | | |
| | | | Room 38 | | | | | |
| | | | Room 39 | | | | | |
| | | | Music | | | | | |
| | | | Music Storage | | | | | |
| | | | Stage | | | | | |
| | | | Stage Wing | | | | | |
| | | | Ramp | | | | | |
| | | | Multi-Purpose | | | | | |
| | | | Multi-Use Storage | | | | | |
| | | | Water Heater Closet No. 3 | | | | | |
| | | | P.E. Storage | | | | | |
| | | | Office | | | | | |
| | | | Kitchen | | | | | |
| | | | Girl's East Restroom | | | | | |
| | | | Boy's East Restroom | | | | | |
| | | | Corridor No. 1 | | | | | |
| | | | Corridor No. 2 | | | | | |
| | | | Corridor No. 3 | | | | | |
| | | | Corridor No. 4 | | | | | |
| | | | Corridor No. 5 | | | | | |
| | | | Corridor No. 6 | | | | | |
| | | | Corridor No. 7 | | | | | |
| | | | Corridor No. 8 | | | | | |
| | | | Corridor No. 9 | | | | | |
| | | | Corridor No. 10 | | | | | |
| | | | Corridor No. 11 | | | | | |
| | | | Corridor No. 12 | | | | | |
| M-FDI-216 | M | Fire Door Insulation, Metal/Wood Cladding | Room 42 | Assumed | NF | G | 147 | SF |
| | | | Boy's Restroom | | | | | |
| | | | Girl's Restroom | | | | | |

| MATERIAL SAMPLE CODE | MTL TYPE | MATERIAL DESCRIPTION | MATERIAL LOCATION | ANALYTICAL RESULTS | FRIABILITY | MATERIAL ASSESS. CLASS | MTL QUAN | UNITS |
|----------------------------|-------------|-------------------------|----------------------|-----------------------|------------|------------------------------|-------------|----------|
| | M/S/T | | | %/ASSUMED | NF/F | G/D/SD | | LF/SF/EA |
| | | | Room 43 | | | | | |
| | | | Room 44 | | | | | |
| | | | Corridor 13 | | | | | |
| | | | Corridor 14 | | | | | |

6-MONTH SURVEILLANCE INSPECTION TABLE
IN-PLACE ASBESTOS-CONTAINING MATERIALS

| MATERIAL SAMPLE CODE | MTL TYPE | MATERIAL DESCRIPTION | MATERIAL LOCATION | ANALYTICAL RESULTS | FRIABILITY | MATERIAL ASSESS. CLASS | MTL QUAN | UNITS |
|----------------------------|-------------|---|----------------------|-----------------------|------------|------------------------------|-------------|----------|
| | M/S/T | | | %/ASSUMED | NF/F | G/D/SD | | LF/SF/EA |
| M-SLT-01 | M | Sealant, White, Pliable | Exterior | Assumed | NF | G | 1 | SF |
| | | | | | | | | |
| M-APR-02 | M | Asphalt Prepared Roofing (Shingles), Black, Asphaltic, Gray Mineral Cap | Roof | Assumed | NF | G | 200 | SF |
| | | | | | | | | |
| M-VBF-03 | M | Vapor Barrier Felt, Black, Asphaltic | Roof | Assumed | NF | G | 200 | SF |
| | | | | | | | | |

THE ASBESTOS INSTITUTE

Certifies that

Zachary Ridgeway

has attended and received instruction in the EPA approved course

AHERA Building Inspector Initial

on

March 6-8 2023


and successfully completed and passed the competency exam.

Certificate:
4380-15665-030823

Date of Examination:
08-Mar-2023

Date of Expiration:
08-Mar-2024


William T. Caviness
Director


Approved Instructor

THE ASBESTOS INSTITUTE

20033 N. 19th Ave, Building 6, Phoenix, AZ 85027
602-864-6564 – www.theasbestosinstitute.com

This training meets all requirements for asbestos certification under Basic Substance Control Act Title II.