

May 23, 2023

Mr. Matthew Griffin  
Facilities Supervisor  
Kyrene School District No. 28  
8700 South Kyrene Road  
Tempe, AZ 85284-2197

**Subject: 6-Month Surveillance Inspection  
Asbestos-Containing Building Materials  
Kyrene del Pueblo Middle School  
360 South Twelve Oaks Boulevard, Chandler**

Dear Mr. Griffin:

FM GROUP INC has completed the 6-Month Surveillance Inspection of Asbestos-Containing Building Materials (ACBM) at the subject school. The forms detailing the results of this reinspection and reassessment of known ACBM are attached.

The attached tables and forms have been updated to reflect the findings as of the date of this Reinspection and should serve as the Management Plan update.

**Items of significance are: None.**

If you have any questions regarding this correspondence, please contact us immediately.

Sincerely,

**FM GROUP INC**



Michael Hall  
Environmental Division Manager



Zach Ridgeway  
AHERA Building Inspector

*Attachments: 6-Month Surveillance Inspection Forms  
6-Month Surveillance Inspection Tables*



## 6-MONTH SURVEILLANCE INSPECTION ASBESTOS-CONTAINING BUILDING MATERIALS

School/Facility: Kyrene del Pueblo Middle School

Inspection Date: 04/07/2023

Building: Building 100

Inspector: Zach Ridgeway Cert. No.: 4380-15665-030823

Signature: 

Material Description	Material Code	Material Observed		Material Condition Status		Material Condition Description (If Change Noted)	Assessment Classification
				Same	Changed		
Plaster, Gray, Cementitious	M-PLA-01	Y	N	x			1 2 3 4 5 6 7*
Spray-Applied Texture, White, Chalky	S-SAT-02	Y	N	x			1 2 3 4 5 6 7*
Gypsum Wallboard, White, Chalky	M-GWB-03	Y	N	x			1 2 3 4 5 6 7*
Joint Compound, White, Chalky	S-JTC-04	Y	N	x			1 2 3 4 5 6 7*
Brick, 4"X16", Tan, Cementitious	M-BRK-05	Y	N	x			1 2 3 4 5 6 7*
Brick, 4"X16", Red, Cementitious	M-BRK-06	Y	N	x			1 2 3 4 5 6 7*
Mortar, Gray, Cementitious	M-MRT-07	Y	N	x			1 2 3 4 5 6 7*
Expansion Joint, Brown, Pliable	M-EXJ-08	Y	N	x			1 2 3 4 5 6 7*
Quarry/Paver Tile, 6"X6", Gray, Smooth	M-QPT-09	Y	N	x			1 2 3 4 5 6 7*
Grout, Gray, Cementitious	M-GRT-10	Y	N	x			1 2 3 4 5 6 7*
Fire Door Insulation, Metal/Wood Cladding	M-FDI-11	Y	N	x			1 2 3 4 5 6 7*
Sealant (Doors, Millwork, Fixtures), White, Pliable	M-SLT-12	Y	N	x			1 2 3 4 5 6 7*
Pipe Sealant (Fire Sprinklers), White, Pliable	M-PSL-13	Y	N	x			1 2 3 4 5 6 7*
Glazed Wall Tile, 4"X4", Tan, Smooth	M-GWT-14	Y	N	x			1 2 3 4 5 6 7*
Glazed Wall Tile, 4"X4", Brown, Smooth	M-GWT-15	Y	N	x			1 2 3 4 5 6 7*
Grout, Gray, Cementitious	M-GRT-16	Y	N	x			1 2 3 4 5 6 7*
Ceramic Mosaic Tile, 2"X2", Tan, Smooth, White Specks	M-CMT-17	Y	N	x			1 2 3 4 5 6 7*
Grout, Gray, Cementitious	M-GRT-18	Y	N	x			1 2 3 4 5 6 7*
Sealant (Windows), Brown, Pliable	M-SLT-24	Y	N	x			1 2 3 4 5 6 7*
Sink Acoustical Coating, Black, Rough	M-SAC-25	Y	N	x			1 2 3 4 5 6 7*
Vinyl Composition Tile, 12"X12", Tan, Smooth, Brown Mottles	M-VCT-31	Y	N	x			1 2 3 4 5 6 7*
Mastic, Black, Brittle	M-MAS-32	Y	N	x			1 2 3 4 5 6 7*
Wallbase (Coved), 4", Black, Vinyl-Like	M-WAB-33	Y	N	x			1 2 3 4 5 6 7*
Adhesive, Brown, Brittle	M-ADH-34	Y	N	x			1 2 3 4 5 6 7*
Sealant (Windows), Black, Gummy	M-SLT-35	Y	N	x			1 2 3 4 5 6 7*
Gypsum Wallboard, White, Chalky	M-GWB-38	Y	N	x			1 2 3 4 5 6 7*
Joint Compound, White, Chalky	S-JTC-39	Y	N	x			1 2 3 4 5 6 7*
Glazed Wall Tile, 4"X6", Brown, Smooth	M-GWT-40	Y	N	x			1 2 3 4 5 6 7*
Grout, Gray, Cementitious	M-GRT-41	Y	N	x			1 2 3 4 5 6 7*



## 6-MONTH SURVEILLANCE INSPECTION ASBESTOS-CONTAINING BUILDING MATERIALS

Material Description	Material Code	Material Observed		Material Condition Status		Material Condition Description (If Change Noted)	Assessment Classification
				Same	Changed		
Concrete (Entries), Gray, Cementitious	M·CON·42	Y	N	x			1 2 3 4 5 6 7*
Sealant (Doors), Tan, Pliable	M·SLT·43	Y	N	x			1 2 3 4 5 6 7*
Sealant (Windows), Brown, Pliable	M·SLT·44	Y	N	x			1 2 3 4 5 6 7*
Sealant (Windows), Black, Gummy	M·SLT·45	Y	N	x			1 2 3 4 5 6 7*
Stucco, Gray, Cementitious	S·STU·46	Y	N	x			1 2 3 4 5 6 7*
Concrete (Courtyard), Gray, Cementitious	M·CON·47	Y	N	x			1 2 3 4 5 6 7*
Brick (Planters), 4"X16", Red, Cementitious	M·BRK·48	Y	N	x			1 2 3 4 5 6 7*
Mortar, Gray, Cementitious	M·MRT·49	Y	N	x			1 2 3 4 5 6 7*
Built-Up Roofing, Black, Asphaltic, Gravel Cap	M·BUR·50	Y	N	x			1 2 3 4 5 6 7*
Mastic (Penetrations And Flashings), Black, Tar-Like	M·MAS·51	Y	N	x			1 2 3 4 5 6 7*
Asphalt Prepared Roofing (Rolled), Black, Asphaltic, Tan Mineral Cap	M·APR·52	Y	N	x			1 2 3 4 5 6 7*
Sealant (Equipment), White, Pliable	M·SLT·53	Y	N	x			1 2 3 4 5 6 7*
Sealant (Flashings), Gray, Pliable, Silver	M·SLT·54	Y	N	x			1 2 3 4 5 6 7*

**\*Assessment Classifications**

1. Damaged or significantly damaged thermal system insulation ACBM.
2. Damaged friable surfacing ACBM.
3. Significantly damaged friable surfacing ACBM.
4. Damaged or significantly damaged friable miscellaneous ACBM.
5. ACBM with potential for damage.
6. ACBM with potential for significant damage.
7. Any remaining friable ACBM or friable suspected ACBM.



## 6-MONTH SURVEILLANCE INSPECTION ASBESTOS-CONTAINING BUILDING MATERIALS

School/Facility: Kyrene del Pueblo Middle School

Inspection Date: 04/07/2023

Building: Building 200

Inspector: Zach Ridgeway Cert. No.: 4380-15665-030823

Signature: 

Material Description	Material Code	Material Observed		Material Condition Status		Material Condition Description (If Change Noted)	Assessment Classification
				Same	Changed		
Sealant (Doors, Windows, Millwork, Fixtures), White, Pliable	M·SLT·10	Y	N	x			1 2 3 4 5 6 7*
Sink Acoustical Coating, Black, Rough	M·SAC·11	Y	N	x			1 2 3 4 5 6 7*
Fire Door Insulation, Metal/Wood Cladding	M·FDI·12	Y	N	x			1 2 3 4 5 6 7*
Pipe Sealant (Fire Sprinklers), White, Pliable	M·PSL·13	Y	N	x			1 2 3 4 5 6 7*
Plaster, Gray, Cementitious	S·PLA·15	Y	N	x			1 2 3 4 5 6 7*
Brick, 4"X16", Tan, Cementitious	M·BRK·16	Y	N	x			1 2 3 4 5 6 7*
Brick, 4"X16", Red, Cementitious	M·BRK·17	Y	N	x			1 2 3 4 5 6 7*
Mortar, Gray, Cementitious	M·MRT·18	Y	N	x			1 2 3 4 5 6 7*
Expansion Joint, Brown, Pliable	M·EXJ·19	Y	N	x			1 2 3 4 5 6 7*
Sealant (Doors), Tan, Pliable	M·SLT·20	Y	N	x			1 2 3 4 5 6 7*
Concrete (Equipment Pad), Gray, Cementitious	M·CON·21	Y	N	x			1 2 3 4 5 6 7*
Vinyl Composition Tile, 12"X12", Tan, Smooth, Brown Mottles	M·VCT·23	Y	N	x			1 2 3 4 5 6 7*
Mastic, Black, Brittle	M·MAS·24	Y	N	x			1 2 3 4 5 6 7*
Spray-Applied Texture, White, Chalky	S·SAT·25	Y	N	x			1 2 3 4 5 6 7*
Gypsum Wallboard, White, Chalky	M·GWB·26	Y	N	x			1 2 3 4 5 6 7*
Joint Compound, White, Chalky	S·JTC·27	Y	N	x			1 2 3 4 5 6 7*
Adhesive (FRP), Brown, Brittle	M·ADH·28	Y	N	x			1 2 3 4 5 6 7*
Concrete (Foundation), Gray, Cementitious	M·CON·29	Y	N	x			1 2 3 4 5 6 7*
Wallbase (Coved), 4", Black, Vinyl-Like	M·WAB·30	Y	N	x			1 2 3 4 5 6 7*
Adhesive, Brown, Brittle	M·ADH·31	Y	N	x			1 2 3 4 5 6 7*
Glazed Wall Tile, 4"X4", Tan, Smooth	M·GWT·32	Y	N	x			1 2 3 4 5 6 7*
Glazed Wall Tile, 4"X4", Brown, Smooth	M·GWT·33	Y	N	x			1 2 3 4 5 6 7*
Grout, Gray, Cementitious	M·GRT·34	Y	N	x			1 2 3 4 5 6 7*
Ceramic Mosaic Tile, 2"X2", Tan, Smooth, White Specks	M·CMT·35	Y	N	x			1 2 3 4 5 6 7*
Grout, Gray, Cementitious	M·GRT·36	Y	N	x			1 2 3 4 5 6 7*
Sealant (Windows), Black, Gummy	M·SLT·37	Y	N	x			1 2 3 4 5 6 7*
Quarry/Paver Tile, 6"X6", Gray, Textured	M·QPT·38	Y	N	x			1 2 3 4 5 6 7*
Grout, Gray, Cementitious	M·GRT·39	Y	N	x			1 2 3 4 5 6 7*
Vinyl Composition Tile, 12"X12", White, Smooth, Multi-Colored Mottles	M·VCT·40	Y	N	x			1 2 3 4 5 6 7*



## 6-MONTH SURVEILLANCE INSPECTION ASBESTOS-CONTAINING BUILDING MATERIALS

Material Description	Material Code	Material Observed		Material Condition Status		Material Condition Description (If Change Noted)	Assessment Classification
				Same	Changed		
Mastic, Black, Brittle	M·MAS·41	Y	N	x			1 2 3 4 5 6 7*
Sealant (Windows), Brown, Pliable	M·SLT·42	Y	N	x			1 2 3 4 5 6 7*
Concrete (Entries), Gray, Cementitious	M·CON·43	Y	N	x			1 2 3 4 5 6 7*
Concrete (Courtyards), Gray, Cementitious, Gravel Finish	M·CON·44	Y	N	x			1 2 3 4 5 6 7*
Brick (Planters), 4"X16", Red, Cementitious, White	M·BRK·45	Y	N	x			1 2 3 4 5 6 7*
Mortar, Gray, Cementitious	M·MRT·46	Y	N	x			1 2 3 4 5 6 7*
Stucco, Gray, Cementitious	S·STU·47	Y	N	x			1 2 3 4 5 6 7*
Sealant (Walls), Gray, Pliable	M·SLT·48	Y	N	x			1 2 3 4 5 6 7*
Built-Up Roofing, Black, Asphaltic, Gravel Cap	M·BUR·49	Y	N	x			1 2 3 4 5 6 7*
Mastic (Penetrations And Flashings), Black, Tar-Like	M·MAS·50	Y	N	x			1 2 3 4 5 6 7*
Asphalt Prepared Roofing (Rolled), Black, Asphaltic, Tan Mineral Cap	M·APR·51	Y	N	x			1 2 3 4 5 6 7*
Sealant (Equipment), White, Pliable	M·SLT·52	Y	N	x			1 2 3 4 5 6 7*
Sealant (Flashings), Gray, Pliable, Silver	M·SLT·53	Y	N	x			1 2 3 4 5 6 7*

### \*Assessment Classifications

1. Damaged or significantly damaged thermal system insulation ACBM.
2. Damaged friable surfacing ACBM.
3. Significantly damaged friable surfacing ACBM.
4. Damaged or significantly damaged friable miscellaneous ACBM.
5. ACBM with potential for damage.
6. ACBM with potential for significant damage.
7. Any remaining friable ACBM or friable suspected ACBM.




## 6-MONTH SURVEILLANCE INSPECTION ASBESTOS-CONTAINING BUILDING MATERIALS

School/Facility: Kyrene del Pueblo Middle School

Inspection Date: 04/07/2023

Building: Building 300

Inspector: Zach Ridgeway Cert. No.: 4380-15665-030823

Signature: 

Material Description	Material Code	Material Observed		Material Condition Status		Material Condition Description (If Change Noted)	Assessment Classification
				Same	Changed		
Sealant (Doors, Windows, Millwork, Fixtures), White, Pliable	M·SLT·10	Y	N	x			1 2 3 4 5 6 7*
Sealant (Windows), Black, Gummy	M·SLT·11	Y	N	x			1 2 3 4 5 6 7*
Fire Door Insulation, Metal/Wood Cladding	M·FDI·12	Y	N	x			1 2 3 4 5 6 7*
Mortar (Glass Block), Gray, Cementitious	M·MRT·13	Y	N	x			1 2 3 4 5 6 7*
Pipe Sealant (Fire Sprinklers), White, Pliable	M·PSL·15	Y	N	x			1 2 3 4 5 6 7*
Gypsum Wallboard, White, Chalky	M·GWB·16	Y	N	x			1 2 3 4 5 6 7*
Joint Compound, White, Chalky	S·JTC·17	Y	N	x			1 2 3 4 5 6 7*
Sink Acoustical Coating, Black, Rough	M·SAC·18	Y	N	x			1 2 3 4 5 6 7*
Brick, 4"x16", Tan, Cementitious	M·BRK·19	Y	N	x			1 2 3 4 5 6 7*
Brick, 4"x16", Red, Cementitious	M·BRK·20	Y	N	x			1 2 3 4 5 6 7*
Mortar, Gray, Cementitious	M·MRT·21	Y	N	x			1 2 3 4 5 6 7*
Expansion Joint, Brown, Pliable	M·EXJ·22	Y	N	x			1 2 3 4 5 6 7*
Vinyl Composition Tile, 12"x2", Tan, Smooth, Brown Mottles	M·VCT·23	Y	N	x			1 2 3 4 5 6 7*
Mastic, Black, Brittle	M·MAS·24	Y	N	x			1 2 3 4 5 6 7*
Wallbase (Coved), 4", Black, Vinyl-Like	M·WAB·25	Y	N	x			1 2 3 4 5 6 7*
Adhesive, Brown, Brittle	M·ADH·26	Y	N	x			1 2 3 4 5 6 7*
Spray-Applied Texture, White, Chalky	S·SAT·27	Y	N	x			1 2 3 4 5 6 7*
Gypsum Wallboard, White, Chalky	M·GWB·28	Y	N	x			1 2 3 4 5 6 7*
Joint Compound, White, Chalky	S·JTC·29	Y	N	x			1 2 3 4 5 6 7*
Gypsum Wallboard, White, Chalky	M·GWB·30	Y	N	x			1 2 3 4 5 6 7*
Joint Compound, White, Chalky	S·JTC·31	Y	N	x			1 2 3 4 5 6 7*
Adhesive (FRP), Brown, Brittle	M·ADH·32	Y	N	x			1 2 3 4 5 6 7*
Gasket, 8", Black, Vinyl-Like	M·GAS·33	Y	N	x			1 2 3 4 5 6 7*
Vinyl Composition Tile, 12"x12", White, Smooth, Gray Mottles	M·VCT·34	Y	N	x			1 2 3 4 5 6 7*
Mastic, Black, Brittle	M·MAS·35	Y	N	x			1 2 3 4 5 6 7*
Concrete (Foundation), Gray, Cementitious	M·CON·36	Y	N	x			1 2 3 4 5 6 7*
Concrete (Entries), Gray, Cementitious	M·CON·37	Y	N	x			1 2 3 4 5 6 7*
Sealant (Doors), Tan, Pliable	M·SLT·38	Y	N	x			1 2 3 4 5 6 7*
Sealant (Windows), Brown, Pliable	M·SLT·39	Y	N	x			1 2 3 4 5 6 7*
Stucco, Gray, Cementitious	S·STU·40	Y	N	x			1 2 3 4 5 6 7*



## 6-MONTH SURVEILLANCE INSPECTION ASBESTOS-CONTAINING BUILDING MATERIALS

Material Description	Material Code	Material Observed		Material Condition Status		Material Condition Description (If Change Noted)	Assessment Classification
				Same	Changed		
Built-Up Roofing, Black, Asphaltic, Gravel Cap	M·BUR·41	Y	N	x			1 2 3 4 5 6 7*
Mastic (Penetrations And Flashings), Black, Tar-Like, Silver	M·MAS·42	Y	N	x			1 2 3 4 5 6 7*
Asphalt Prepared Roofing (Rolled), Black, Asphaltic, Tan Mineral Cap	M·APR·43	Y	N	x			1 2 3 4 5 6 7*
Sealant (Equipment), White, Pliable	M·SLT·44	Y	N	x			1 2 3 4 5 6 7*
Sealant (Flashing), Gray, Pliable, Silver	M·SLT·45	Y	N	x			1 2 3 4 5 6 7*

### \*Assessment Classifications

1. Damaged or significantly damaged thermal system insulation ACBM.
2. Damaged friable surfacing ACBM.
3. Significantly damaged friable surfacing ACBM.
4. Damaged or significantly damaged friable miscellaneous ACBM.
5. ACBM with potential for damage.
6. ACBM with potential for significant damage.
7. Any remaining friable ACBM or friable suspected ACBM.



## 6-MONTH SURVEILLANCE INSPECTION ASBESTOS-CONTAINING BUILDING MATERIALS

School/Facility: Kyrene del Pueblo Middle School

Inspection Date: 04/07/2023

Building: Building 400

Inspector: Zach Ridgeway Cert. No.: 4380-15665-030823

Signature: 

Material Description	Material Code	Material Observed		Material Condition Status		Material Condition Description (If Change Noted)	Assessment Classification
				Same	Changed		
Sealant (Doors, Windows, Millwork, Fixtures), White, Pliable	M·SLT·10	Y	N	x			1 2 3 4 5 6 7*
Sealant (Windows), Black, Gummy	M·SLT·11	Y	N	x			1 2 3 4 5 6 7*
Fire Door Insulation, Metal/Wood Cladding	M·FDI·12	Y	N	x			1 2 3 4 5 6 7*
Pipe Sealant (Fire Sprinklers), White, Pliable	M·PSL·14	Y	N	x			1 2 3 4 5 6 7*
Spray-Applied Texture, White, Chalky	S·SAT·15	Y	N	x			1 2 3 4 5 6 7*
Gypsum Wallboard, White, Chalky	W·GWB·16	Y	N	x			1 2 3 4 5 6 7*
Joint Compound, White, Chalky	S·JTC·17	Y	N	x			1 2 3 4 5 6 7*
Adhesive (WAB), Cream, Pliable	M·ADH·19	Y	N	x			1 2 3 4 5 6 7*
Vinyl Composition Tile, 12"X12", Tan, Smooth, Brown Mottles	M·VCT·20	Y	N	x			1 2 3 4 5 6 7*
Mastic, Black, Brittle	M·MAS·21	Y	N	x			1 2 3 4 5 6 7*
Sink Acoustical Coating, Black, Rough	M·SAC·23	Y	N	x			1 2 3 4 5 6 7*
Vinyl Composition Tile, 12"X12", White, Smooth, Gray Mottles	M·VCT·24	Y	N	x			1 2 3 4 5 6 7*
Mastic, Black, Brittle	M·MAS·25	Y	N	x			1 2 3 4 5 6 7*
Wallbase (Coved), 4", Dark Gray, Vinyl-Like	M·WAB·26	Y	N	x			1 2 3 4 5 6 7*
Adhesive, Brown, Brittle	M·ADH·27	Y	N	x			1 2 3 4 5 6 7*
Gypsum Wallboard, White, Chalky	M·GWB·28	Y	N	x			1 2 3 4 5 6 7*
Joint Compound, White, Chalky	S·JTC·29	Y	N	x			1 2 3 4 5 6 7*
Concrete (Foundation), Gray, Cementitious	M·CON·30	Y	N	x			1 2 3 4 5 6 7*
Concrete (Entries), Gray, Cementitious	M·CON·31	Y	N	x			1 2 3 4 5 6 7*
Brick, 4"X16", Tan, Cementitious	M·BRK·32	Y	N	x			1 2 3 4 5 6 7*
Brick, 4"X16", Red, Cementitious	M·BRK·33	Y	N	x			1 2 3 4 5 6 7*
Mortar, Gray, Cementitious	M·MRT·34	Y	N	x			1 2 3 4 5 6 7*
Expansion Joint, Tan, Pliable	M·EXJ·35	Y	N	x			1 2 3 4 5 6 7*
Sealant (Doors), Brown, Brittle	M·SLT·36	Y	N	x			1 2 3 4 5 6 7*
Sealant (Windows), Black, Pliable	M·SLT·37	Y	N	x			1 2 3 4 5 6 7*
Gasket, 8", Black, Vinyl-Like	M·GAS·39	Y	N	x			1 2 3 4 5 6 7*
Built-Up Roofing, Black, Asphaltic, Gravel Cap	M·BUR·40	Y	N	x			1 2 3 4 5 6 7*
Mastic (Penetrations And Flashings), Black, Tar-Like, Silver	M·MAS·41	Y	N	x			1 2 3 4 5 6 7*





## 6-MONTH SURVEILLANCE INSPECTION ASBESTOS-CONTAINING BUILDING MATERIALS

Material Description	Material Code	Material Observed		Material Condition Status		Material Condition Description (If Change Noted)	Assessment Classification
				Same	Changed		
Asphalt Prepared Roofing (Rolled), Black, Asphaltic, Tan Mineral Cap	M-APR-42	Y	N	x			1 2 3 4 5 6 7*
Sealant (Equipment), White, Pliable	M-SLT-43	Y	N	x			1 2 3 4 5 6 7*
Sealant (Flashing), Gray, Pliable, Silver	M-SLT-44	Y	N	x			1 2 3 4 5 6 7*
Stucco, Gray, Cementitious	S-STU-45	Y	N	x			1 2 3 4 5 6 7*
Sealant (Windows), Brown, Pliable	M-SLT-46	Y	N	x			1 2 3 4 5 6 7*

### \*Assessment Classifications

1. Damaged or significantly damaged thermal system insulation ACBM.
2. Damaged friable surfacing ACBM.
3. Significantly damaged friable surfacing ACBM.
4. Damaged or significantly damaged friable miscellaneous ACBM.
5. ACBM with potential for damage.
6. ACBM with potential for significant damage.
7. Any remaining friable ACBM or friable suspected ACBM.




## 6-MONTH SURVEILLANCE INSPECTION ASBESTOS-CONTAINING BUILDING MATERIALS

School/Facility: Kyrene del Pueblo Middle School

Inspection Date: 04/07/2023

Building: Building 500

Inspector: Zach Ridgeway Cert. No.: 4380-15665-030823 Signature: 

Material Description	Material Code	Material Observed		Material Condition Status		Material Condition Description (If Change Noted)	Assessment Classification
				Same	Changed		
Fire Door Insulation, Metal/Wood Cladding	M-FDI-10	Y	N	x			1 2 3 4 5 6 7*
Sealant (Doors, Windows, Millwork, Fixtures), White, Pliable	M-SLT-11	Y	N	x			1 2 3 4 5 6 7*
Sink Acoustical Coating, Black, Rough	M-SAC-12	Y	N	x			1 2 3 4 5 6 7*
Sealant (Duct), Gray, Pliable	M-SLT-14	Y	N	x			1 2 3 4 5 6 7*
Pipe Sealant (Fire Sprinklers), White, Pliable	M-PSL-15	Y	N	x			1 2 3 4 5 6 7*
Vinyl Composition Tile, 12"X12", Tan, Smooth, Brown Mottles	M-VCT-16	Y	N	x			1 2 3 4 5 6 7*
Mastic, Black, Brittle	M-MAS-17	Y	N	x			1 2 3 4 5 6 7*
Concrete (Foundation), Gray, Cementitious	M-CON-18	Y	N	x			1 2 3 4 5 6 7*
Sealant (Windows), Black, Gummy	M-SLT-19	Y	N	x			1 2 3 4 5 6 7*
Sink Acoustical Coating, Gray, Rough	M-SAC-22	Y	N	x			1 2 3 4 5 6 7*
Carpet, Brown, Fibrous	M-CPT-23	Y	N	x			1 2 3 4 5 6 7*
Mastic, Tan, Brittle	M-MAS-24	Y	N	x			1 2 3 4 5 6 7*
Vinyl Composition Tile, 12"X12", White, Smooth, Blue Mottles	M-VCT-25	Y	N	x			1 2 3 4 5 6 7*
Vinyl Composition Tile, 12"X12", Blue, Smooth, Light Blue Mottles	M-VCT-26	Y	N	x			1 2 3 4 5 6 7*
Mastic, Black, Brittle	M-MAS-27	Y	N	x			1 2 3 4 5 6 7*
Wallbase (Coved), 4", Blue, Vinyl-Like	M-WAB-28	Y	N	x			1 2 3 4 5 6 7*
Adhesive, Brown, Brittle	M-ADH-29	Y	N	x			1 2 3 4 5 6 7*
Spray-Applied Texture, White, Chalky	S-SAT-30	Y	N	x			1 2 3 4 5 6 7*
Gypsum Wallboard, White, Chalky	M-GWB-31	Y	N	x			1 2 3 4 5 6 7*
Joint Compound, White, Chalky	S-JTC-32	Y	N	x			1 2 3 4 5 6 7*
Gasket, 6", Black, Vinyl-Like	M-GAS-35	Y	N	x			1 2 3 4 5 6 7*
Gypsum Wallboard, White, Chalky	M-GWB-36	Y	N	x			1 2 3 4 5 6 7*
Joint Compound, White, Chalky	S-JTC-37	Y	N	x			1 2 3 4 5 6 7*
Concrete (Entries), Gray, Cementitious	M-CON-38	Y	N	x			1 2 3 4 5 6 7*
Brick, 4"X16", Tan, Cementitious	M-BRK-39	Y	N	x			1 2 3 4 5 6 7*
Brick, 4"X16", Red, Cementitious	M-BRK-40	Y	N	x			1 2 3 4 5 6 7*
Mortar, Gray, Cementitious	M-MRT-41	Y	N	x			1 2 3 4 5 6 7*
Expansion Joint, Brown, Pliable	M-EXJ-42	Y	N	x			1 2 3 4 5 6 7*
Sealant (Doors), Tan, Brittle	M-SLT-43	Y	N	x			1 2 3 4 5 6 7*



## 6-MONTH SURVEILLANCE INSPECTION ASBESTOS-CONTAINING BUILDING MATERIALS

Material Description	Material Code	Material Observed		Material Condition Status		Material Condition Description (If Change Noted)	Assessment Classification
				Same	Changed		
Sealant (Windows), Brown, Pliable	M·SLT·44	Y	N	x			1 2 3 4 5 6 7*
Concrete (Equipment Pad), Gray, Cementitious	M·CON·45	Y	N	x			1 2 3 4 5 6 7*
Sealant (Duct), Gray, Brittle	M·SLT·46	Y	N	x			1 2 3 4 5 6 7*
Woven Duct Boot, 4", Black, Vinyl-Like	M·WDB·47	Y	N	x			1 2 3 4 5 6 7*
Built-Up Roofing, Black, Asphaltic, Gravel Cap	M·BUR·48	Y	N	x			1 2 3 4 5 6 7*
Mastic (Penetrations And Flashings), Black, Tar-Like, Silver	M·MAS·49	Y	N	x			1 2 3 4 5 6 7*
Asphalt Prepared Roofing (Rolled), Black, Asphaltic, Tan Mineral Cap	M·APR·50	Y	N	x			1 2 3 4 5 6 7*
Sealant (Equipment), White, Pliable	M·SLT·51	Y	N	x			1 2 3 4 5 6 7*
Sealant (Flashings), Gray, Pliable, Silver	M·SLT·52	Y	N	x			1 2 3 4 5 6 7*

### \*Assessment Classifications

1. Damaged or significantly damaged thermal system insulation ACBM.
2. Damaged friable surfacing ACBM.
3. Significantly damaged friable surfacing ACBM.
4. Damaged or significantly damaged friable miscellaneous ACBM.
5. ACBM with potential for damage.
6. ACBM with potential for significant damage.
7. Any remaining friable ACBM or friable suspected ACBM.



## 6-MONTH SURVEILLANCE INSPECTION ASBESTOS-CONTAINING BUILDING MATERIALS

School/Facility: Kyrene del Pueblo Middle School

Inspection Date: 04/07/2023

Building: Building 600

Inspector: Zach Ridgeway Cert. No.: 4380-15665-030823

Signature: 

Material Description	Material Code	Material Observed		Material Condition Status		Material Condition Description (If Change Noted)	Assessment Classification
				Same	Changed		
Brick, 4"X16", Tan, Cementitious	M-BRK-06	Y	N	x			1 2 3 4 5 6 7*
Brick, 4"X16", Red, Cementitious	M-BRK-07	Y	N	x			1 2 3 4 5 6 7*
Mortar, Gray, Cementitious	M-MRT-08	Y	N	x			1 2 3 4 5 6 7*
Expansion Joint, Brown, Pliable	M-EXJ-09	Y	N	x			1 2 3 4 5 6 7*
Sealant (Doors, Windows, Millwork, Fixtures), White, Pliable	M-SLT-10	Y	N	x			1 2 3 4 5 6 7*
Sink Acoustical Coating, Black, Rough	M-SAC-11	Y	N	x			1 2 3 4 5 6 7*
Sealant (Windows), Black, Gummy	M-SLT-12	Y	N	x			1 2 3 4 5 6 7*
Fire Door Insulation, Metal/Wood Cladding	M-FDI-17	Y	N	x			1 2 3 4 5 6 7*
Pipe Sealant (Fire Sprinklers), White, Pliable	M-PSL-19	Y	N	x			1 2 3 4 5 6 7*
Wallbase (Coved), 4", Black, Vinyl-Like	M-WAB-22	Y	N	x			1 2 3 4 5 6 7*
Adhesive, Brown, Brittle	M-ADH-23	Y	N	x			1 2 3 4 5 6 7*
Vinyl Stair Tread, 12"X36", Tan, Textured, Diamond Pattern	M-VST-24	Y	N	x			1 2 3 4 5 6 7*
Mastic, Yellow, Tacky	M-MAS-25	Y	N	x			1 2 3 4 5 6 7*
Vinyl Composition Tile, 12"X12", White, Smooth, Gray Mottles	M-VCT-26	Y	N	x			1 2 3 4 5 6 7*
Mastic, Black, Brittle	M-MAS-27	Y	N	x			1 2 3 4 5 6 7*
Vinyl Composition Tile (Pattern), 12"X12", Brown, Smooth, White Mottles	M-VCT-28	Y	N	x			1 2 3 4 5 6 7*
Quarry/Paver Tile, 6"X6", Red, Smooth	M-QPT-32	Y	N	x			1 2 3 4 5 6 7*
Grout, Gray, Cementitious	M-GRT-33	Y	N	x			1 2 3 4 5 6 7*
Vinyl Composition Tile, 12"X12", Tan, Smooth, Brown Mottles	M-VCT-34	Y	N	x			1 2 3 4 5 6 7*
Mastic, Black, Brittle	M-MAS-35	Y	N	x			1 2 3 4 5 6 7*
Spray-Applied Texture, White, Chalky	S-SAT-37	Y	N	x			1 2 3 4 5 6 7*
Gypsum Wallboard, White, Chalky	M-GWB-38	Y	N	x			1 2 3 4 5 6 7*
Joint Compound, White, Chalky	S-JTC-39	Y	N	x			1 2 3 4 5 6 7*
Gypsum Wallboard, White, Chalky	M-GWB-40	Y	N	x			1 2 3 4 5 6 7*
Joint Compound, White, Chalky	S-JTC-41	Y	N	x			1 2 3 4 5 6 7*
Carpet, Brown, Fibrous	M-CPT-43	Y	N	x			1 2 3 4 5 6 7*
Mastic, Yellow, Brittle	M-MAS-44	Y	N	x			1 2 3 4 5 6 7*
Gasket, 8", Black, Vinyl-Like	M-GAS-45	Y	N	x			1 2 3 4 5 6 7*
Glazed Wall Tile, 4"X4", Tan, Smooth	M-GWT-46	Y	N	x			1 2 3 4 5 6 7*



## 6-MONTH SURVEILLANCE INSPECTION ASBESTOS-CONTAINING BUILDING MATERIALS

Material Description	Material Code	Material Observed		Material Condition Status		Material Condition Description (If Change Noted)	Assessment Classification
				Same	Changed		
Glazed Wall Tile, 4"X4", Brown, Smooth	M-GWT-47	Y	N	x			1 2 3 4 5 6 7*
Grout, Gray, Cementitious	M-GRT-48	Y	N	x			1 2 3 4 5 6 7*
Ceramic Mosaic Tile, 2"X2", Tan, Smooth, White Specks	M-CMT-49	Y	N	x			1 2 3 4 5 6 7*
Grout, Gray, Cementitious	M-GRT-50	Y	N	x			1 2 3 4 5 6 7*
Mortar (Glass Block), Gray, Cementitious,	M-MRT-51	Y	N	x			1 2 3 4 5 6 7*
Sealant (Doors), Tan, Pliable	M-SLT-52	Y	N	x			1 2 3 4 5 6 7*
Gypsum Wallboard, White, Chalky, Vinyl Cover	M-GWB-53	Y	N	x			1 2 3 4 5 6 7*
Joint Compound, White, Chalky	S-JTC-54	Y	N	x			1 2 3 4 5 6 7*
Gypsum Wallboard, White, Chalky	M-GWB-57	Y	N	x			1 2 3 4 5 6 7*
Joint Compound, White, Chalky	S-JTC-58	Y	N	x			1 2 3 4 5 6 7*
Plaster, Gray, Cementitious	M-PLA-59	Y	N	x			1 2 3 4 5 6 7*
Concrete (Foundation), Gray, Cementitious	M-CON-60	Y	N	x			1 2 3 4 5 6 7*
Expansion Joint, Gray, Pliable	M-EXJ-61	Y	N	x			1 2 3 4 5 6 7*
Concrete (Entries), Gray, Cementitious	M-CON-62	Y	N	x			1 2 3 4 5 6 7*
Quarry/Paver Tile, 4"X16", Red, Cementitious	M-QPT-63	Y	N	x			1 2 3 4 5 6 7*
Grout, Gray, Cementitious	M-GRT-64	Y	N	x			1 2 3 4 5 6 7*
Quarry/Paver Tile, 4"X8", Red, Smooth	M-QPT-65	Y	N	x			1 2 3 4 5 6 7*
Stucco, Gray, Cementitious	S-STU-66	Y	N	x			1 2 3 4 5 6 7*
Built-Up Roofing, Black, Asphaltic, Gravel Cap	M-BUR-67	Y	N	x			1 2 3 4 5 6 7*
Mastic (Penetrations And Flashings), Black, Tar-Like, Silver	M-MAS-68	Y	N	x			1 2 3 4 5 6 7*
Asphalt Prepared Roofing (Rolled), Black, Asphaltic, Tan Mineral Cap	M-APR-69	Y	N	x			1 2 3 4 5 6 7*
Sealant (Equipment), White, Pliable	M-SLT-70	Y	N	x			1 2 3 4 5 6 7*
Sealant (Flashings), Gray, Pliable, Silver	M-SLT-71	Y	N	x			1 2 3 4 5 6 7*

### \*Assessment Classifications

1. Damaged or significantly damaged thermal system insulation ACBM.
2. Damaged friable surfacing ACBM.
3. Significantly damaged friable surfacing ACBM.
4. Damaged or significantly damaged friable miscellaneous ACBM.
5. ACBM with potential for damage.
6. ACBM with potential for significant damage.
7. Any remaining friable ACBM or friable suspected ACBM.



## 6-MONTH SURVEILLANCE INSPECTION ASBESTOS-CONTAINING BUILDING MATERIALS

School/Facility: Kyrene del Pueblo Middle School

Inspection Date: 04/07/2023

Building: Building 700

Inspector: Zach Ridgeway Cert. No.: 4380-15665-030823

Signature: 

Material Description	Material Code	Material Observed		Material Condition Status		Material Condition Description (If Change Noted)	Assessment Classification
				Same	Changed		
Sealant (Doors, Windows, Millwork, Fixtures), White, Pliable	M·SLT·10	Y	N	x			1 2 3 4 5 6 7*
Fire Door Insulation, Metal/Wood Cladding	M·FDI·11	Y	N	x			1 2 3 4 5 6 7*
Pipe Sealant (Fire Sprinklers), White, Pliable	M·PSL·12	Y	N	x			1 2 3 4 5 6 7*
Vinyl Composition Tile, 12"X12", White, Smooth, Gray Streaks	M·VCT·14	Y	N	x			1 2 3 4 5 6 7*
Mastic, Black, Brittle	M·MAS·15	Y	N	x			1 2 3 4 5 6 7*
Sealant (Windows), Black, Gummy	M·SLT·16	Y	N	x			1 2 3 4 5 6 7*
Spray-Applied Texture, White, Chalky	S·SAT·17	Y	N	x			1 2 3 4 5 6 7*
Gypsum Wallboard, White, Chalky	M·GWB·18	Y	N	x			1 2 3 4 5 6 7*
Joint Compound, White, Chalky	S·JTC·19	Y	N	x			1 2 3 4 5 6 7*
Glazed Wall Tile, 4"X4", White, Smooth, Peppered	M·GWT·20	Y	N	x			1 2 3 4 5 6 7*
Glazed Wall Tile (Pattern), 2"X2", Black, Smooth	M·GWT·21	Y	N	x			1 2 3 4 5 6 7*
Grout, Gray, Cementitious	M·GRT·22	Y	N	x			1 2 3 4 5 6 7*
Ceramic Mosaic Tile, 2"X2", White, Smooth, Peppered	M·CMT·23	Y	N	x			1 2 3 4 5 6 7*
Grout, Gray, Cementitious	M·GRT·24	Y	N	x			1 2 3 4 5 6 7*
Sink Acoustical Coating, Black, Rough	M·SAC·25	Y	N	x			1 2 3 4 5 6 7*
Gasket, 8", Black, Vinyl-Like	M·GAS·28	Y	N	x			1 2 3 4 5 6 7*
Troweled-On Texture, White, Chalky	S·TOT·29	Y	N	x			1 2 3 4 5 6 7*
Gypsum Wallboard, White, Chalky	M·GWB·30	Y	N	x			1 2 3 4 5 6 7*
Joint Compound, White, Chalky	S·JTC·31	Y	N	x			1 2 3 4 5 6 7*
Adhesive (Frp), Brown, Brittle	M·ADH·32	Y	N	x			1 2 3 4 5 6 7*
Gypsum Wallboard, White, Chalky	M·GWB·33	Y	N	x			1 2 3 4 5 6 7*
Joint Compound, White, Chalky	S·JTC·34	Y	N	x			1 2 3 4 5 6 7*
Brick, 4"X16", Tan, Cementitious	M·BRK·35	Y	N	x			1 2 3 4 5 6 7*
Brick, 4"X16", Red, Cementitious	M·BRK·36	Y	N	x			1 2 3 4 5 6 7*
Mortar, Gray, Cementitious	M·MRT·37	Y	N	x			1 2 3 4 5 6 7*
Expansion Joint, Brown, Pliable	M·EXJ·38	Y	N	x			1 2 3 4 5 6 7*
Sealant (Doors), Tan, Pliable	M·SLT·39	Y	N	x			1 2 3 4 5 6 7*
Concrete (Entries), Gray, Cementitious	M·CON·40	Y	N	x			1 2 3 4 5 6 7*
Concrete (Courtyards), Gray, Cementitious, Gravel Finish	M·CON·41	Y	N	x			1 2 3 4 5 6 7*



## 6-MONTH SURVEILLANCE INSPECTION ASBESTOS-CONTAINING BUILDING MATERIALS

Material Description	Material Code	Material Observed		Material Condition Status		Material Condition Description (If Change Noted)	Assessment Classification
				Same	Changed		
Brick (Planters), 4"X16", Red, Cementitious, White	M-BRK-42	Y	N	x			1 2 3 4 5 6 7*
Mortar, Gray, Cementitious	M-MRT-43	Y	N	x			1 2 3 4 5 6 7*
Concrete Masonry Unit, 8"X16", Gray, Cementitious	M-CMU-44	Y	N	x			1 2 3 4 5 6 7*
Concrete Masonry Unit, 2"X16", Gray, Smooth	M-CMU-45	Y	N	x			1 2 3 4 5 6 7*
Mortar, Gray, Cementitious	M-MRT-46	Y	N	x			1 2 3 4 5 6 7*
Quarry/Paver Tile, 8"X8", Gray, Smooth	M-QPT-47	Y	N	x			1 2 3 4 5 6 7*
Grout, Gray, Cementitious	M-GRT-48	Y	N	x			1 2 3 4 5 6 7*
Built-Up Roofing, Black, Asphaltic, Gray Mineral Cap	M-BUR-49	Y	N	x			1 2 3 4 5 6 7*
Mastic (Penetrations And Flashings), Black, Tar-Like, Silver	M-MAS-50	Y	N	x			1 2 3 4 5 6 7*
Sealant (Equipment), White, Pliable	M-SLT-51	Y	N	x			1 2 3 4 5 6 7*
Sealant (Flashings), Gray, Pliable, Silver	M-SLT-52	Y	N	x			1 2 3 4 5 6 7*

### \*Assessment Classifications

1. Damaged or significantly damaged thermal system insulation ACBM.
2. Damaged friable surfacing ACBM.
3. Significantly damaged friable surfacing ACBM.
4. Damaged or significantly damaged friable miscellaneous ACBM.
5. ACBM with potential for damage.
6. ACBM with potential for significant damage.
7. Any remaining friable ACBM or friable suspected ACBM.




**6-MONTH SURVEILLANCE INSPECTION  
ASBESTOS-CONTAINING BUILDING MATERIALS**

School/Facility: Kyrene del Pueblo Middle School

Inspection Date: 04/07/2023

Building: Canopy

Inspector: Zach Ridgeway Cert. No.: 4380-15665-030823 Signature: 

Material Description	Material Code	Material Observed		Material Condition Status		Material Condition Description (If Change Noted)	Assessment Classification
				Same	Changed		
Stucco, Gray, Cementitious	M-STU-01	Y	N	x			1 2 3 4 5 6 7*
Sealant, Gray, Pliable	M-SLT-02	Y	N	x			1 2 3 4 5 6 7*

**\*Assessment Classifications**

1. Damaged or significantly damaged thermal system insulation ACBM.
2. Damaged friable surfacing ACBM.
3. Significantly damaged friable surfacing ACBM.
4. Damaged or significantly damaged friable miscellaneous ACBM.
5. ACBM with potential for damage.
6. ACBM with potential for significant damage.
7. Any remaining friable ACBM or friable suspected ACBM.






**6-MONTH SURVEILLANCE INSPECTION  
ASBESTOS-CONTAINING BUILDING MATERIALS**

School/Facility: Kyrene del Pueblo Middle School

Inspection Date: 04/07/2023

Building: Storage Building

Inspector: Zach Ridgeway Cert. No.: 4380-15665-030823 Signature: 

Material Description	Material Code	Material Observed		Material Condition Status		Material Condition Description (If Change Noted)	Assessment Classification
				Same	Changed		
Asphalt Prepared Roofing (Shingles), Black, Asphaltic, Tan Mineral Cap	M-APR-01	Y	N	x			1 2 3 4 5 6 7*
Vapor Barrier Felt, Black, Asphaltic	M-VBF-02	Y	N	x			1 2 3 4 5 6 7*
Concrete Masonry Unit, 8"X16", Gray, Cementitious	M-CMU-03	Y	N	x			1 2 3 4 5 6 7*
Mortar, Gray, Cementitious	M-MRT-04	Y	N	x			1 2 3 4 5 6 7*
Concrete (Foundation), Gray, Cementitious	M-CON-05	Y	N	x			1 2 3 4 5 6 7*
Concrete (Entries), Gray, Cementitious	M-CON-06	Y	N	x			1 2 3 4 5 6 7*

**\*Assessment Classifications**

1. Damaged or significantly damaged thermal system insulation ACBM.
2. Damaged friable surfacing ACBM.
3. Significantly damaged friable surfacing ACBM.
4. Damaged or significantly damaged friable miscellaneous ACBM.
5. ACBM with potential for damage.
6. ACBM with potential for significant damage.
7. Any remaining friable ACBM or friable suspected ACBM.

## 6-MONTH SURVEILLANCE INSPECTION TABLE

### IN-PLACE ASBESTOS-CONTAINING MATERIALS

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
S-PLA-01	S	Plaster, Gray, Cementitious	Lockers 2	Assumed	NF	G	700	SF
			Lockers 1					
			Lockers 4					
S-SAT-02	S	Spray-Applied Texture, White, Chalky	Men's Restroom 1	Assumed	NF	G	1,500	SF
			Women's Restroom 1					
			Girl's Restroom 2					
			Boy's Restroom 2					
			Lockers 1					
			Girl's Restroom					
			Boy's Restroom					
M-GWB-03	M	Gypsum Wallboard, White, Chalky	Men's Restroom 1	Assumed	NF	G	1,500	SF
			Women's Restroom 1					
			Girl's Restroom 2					
			Boy's Restroom 2					
			Lockers 1					
			Girl's Restroom					
			Boy's Restroom					
S-JTC-04	S	Joint Compound, White, Chalky	Men's Restroom 1	Assumed	NF	G	150	SF
			Women's Restroom 1					
			Girl's Restroom 2					
			Boy's Restroom 2					
			Lockers 1					
			Girl's Restroom					
			Boy's Restroom					

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
M-BRK-05	M	Brick, 4"X16", Tan, Cementitious	Lockers 2	Assumed	NF	G	15,000	SF
			Lockers 1					
			Lockers 4					
			Courtyard 1					
			Courtyard 2					
			Exterior					
M-BRK-06	M	Brick, 4"X16", Red, Cementitious	Lockers 2	Assumed	NF	G	15,000	SF
			Lockers 1					
			Lockers 4					
			Courtyard 1					
			Courtyard 2					
			Exterior					
M-MRT-07	M	Mortar, Gray, Cementitious	Lockers 2	Assumed	NF	G	3,000	SF
			Lockers 1					
			Lockers 4					
			Courtyard 1					
			Courtyard 2					
			Exterior					
M-EXJ-08	M	Expansion Joint, Brown, Pliable	Lockers 2	Assumed	NF	G	50	SF
			Lockers 1					
			Lockers 4					
			Courtyard 1					
			Courtyard 2					
			Exterior					
M-QPT-09	M	Quarry/Paver Tile, 6"X6", Gray, Smooth	Lockers 1	Assumed	NF	G	200	SF
M-GRT-10	M	Grout, Gray, Cementitious	Lockers 1	Assumed	NF	G	20	SF

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
M-FDI-11	M	Fire Door Insulation, Metal/Wood Cladding	Men's Restroom 1	Assumed	NF	G	903	SF
			Women's Restroom 1					
			Work Room 1					
			Work Room 2					
			Storage 1					
			Storage 2					
			Classroom A-2					
			Classroom A-3					
			Classroom A-4					
			Special Ed A-5					
			Girl's Restroom 2					
			Boy's Restroom 2					
			Lockers 2					
			Classroom A-7					
			Classroom A-8					
			Classroom A-9					
			Storage 3					
			Hall 1					
			Storage 4					
			Classroom A-10					
			Storage 7					
			Classroom B-2					
			Classroom B-3					
			Classroom B-4					
			Classroom B-5					
			Classroom B-6					
			Boy's Restroom 1					
			Girl's Restroom 1					
			Lockers 1					
			Classroom B-8					
			Classroom B-9					
			Storage 5					

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
			Hall 2					
			Storage 6					
			Classroom B-10					
			Utility					
			Janitor					
			Courtyard 1					
			Courtyard 2					
			Exterior					
M-SLT-12	M	Sealant (Doors, Millwork, Fixtures), White, Pliable	Men's Restroom 1	Assumed	NF	G	25	SF
			Women's Restroom 1					
			Work Room 1					
			Work Room 2					
			Storage 1					
			Storage 2					
			Classroom A-2					
			Classroom A-3					
			Classroom A-4					
			Special Ed A-5					
			Special Ed To					
			Special Ed Office					
			Girl's Restroom 2					
			Boy's Restroom 2					
			Classroom A-7					
			Classroom A-8					
			Classroom A-9					
			Storage 3					
			Hall 1					
			Storage 4					
			Classroom A-10					
			Classroom B-2					
			Classroom B-3					

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
			Classroom B-4					
			Classroom B-5					
			Classroom B-6					
			Boy's Restroom 1					
			Girl's Restroom 1					
			Lockers 1					
			Classroom B-8					
			Classroom B-9					
			Storage 5					
			Hall 2					
			Storage 6					
			Classroom B-10					
			Utility					
			Janitor					
M-PSL-13	M	Pipe Sealant (Fire Sprinklers), White, Pliable	Men's Restroom 1	Assumed	NF	G	50	SF
			Women's Restroom 1					
			Work Room 1					
			Work Room 2					
			Storage 1					
			Storage 2					
			Classroom A-2					
			Classroom A-3					
			Classroom A-4					
			Special Ed A-5					
			Special Ed To					
			Special Ed Office					
			Girl's Restroom 2					
			Boy's Restroom 2					
			Lockers 2					
			Classroom A-7					
			Classroom A-8					

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
			Classroom A-9					
			Storage 3					
			Hall 1					
			Storage 4					
			Classroom A-10					
			Storage 7					
			Lockers 3					
			Classroom B-2					
			Classroom B-3					
			Classroom B-4					
			Classroom B-5					
			Classroom B-6					
			Boy's Restroom 1					
			Girl's Restroom 1					
			Lockers 1					
			Lockers 4					
			Classroom B-8					
			Classroom B-9					
			Storage 5					
			Hall 2					
			Storage 6					
			Classroom B-10					
			Utility					
			Janitor					
M-GWT-14	M	Glazed Wall Tile, 4"X4", Tan, Smooth	Girl's Restroom 2	Assumed	NF	G	900	SF
			Boy's Restroom 2					
			Boy's Restroom 1					
			Girl's Restroom 1					
M-GWT-15	M	Glazed Wall Tile, 4"X4", Brown, Smooth	Girl's Restroom 2	Assumed	NF	G	900	SF
			Boy's Restroom 2					

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
			Boy's Restroom 1					
			Girl's Restroom 1					
M-GRT-16	M	Grout, Gray, Cementitious	Girl's Restroom 2	Assumed	NF	G	200	SF
			Boy's Restroom 2					
			Boy's Restroom 1					
			Girl's Restroom 1					
M-CMT-17	M	Ceramic Mosaic Tile, 2"X2", Tan, Smooth, White Specks	Girl's Restroom 2	Assumed	NF	G	800	SF
			Boy's Restroom 2					
			Boy's Restroom 1					
			Girl's Restroom 1					
M-GRT-18	M	Grout, Gray, Cementitious	Girl's Restroom 2	Assumed	NF	G	80	SF
			Boy's Restroom 2					
			Boy's Restroom 1					
			Girl's Restroom 1					
M-SLT-24	M	Sealant (Windows), Brown, Pliable	Classroom A-2	Assumed	NF	G	25	SF
			Classroom A-3					
			Special Ed A-5					
			Special Ed Office					
			Classroom A-7					
			Classroom A-8					
			Classroom A-9					
			Classroom A-10					
			Classroom B-2					
			Classroom B-3					
			Classroom B-5					
			Classroom B-6					
			Classroom B-8					
			Classroom B-9					



MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
			Classroom B-10					
M-SAC-25	M	Sink Acoustical Coating, Black, Rough	Work Room 1	Assumed	NF	G	32	SF
			Work Room 2					
			Classroom A-2					
			Classroom A-3					
			Classroom A-4					
			Special Ed A-5					
			Classroom A-7					
			Classroom A-8					
			Classroom A-10					
			Classroom B-2					
			Classroom B-3					
			Classroom B-4					
			Classroom B-5					
			Classroom B-6					
			Classroom B-8					
			Classroom B-10					
M-VCT-31	M	Vinyl Composition Tile, 12"X12", Tan, Smooth, Brown Mottles	Men's Restroom 1	Assumed	NF	G	1,500	SF
			Women's Restroom 1					
			Work Room 1					
			Work Room 2					
			Storage 1					
			Storage 2					
			Storage 3					
			Hall 1					
			Storage 4					
			Storage 5					
			Hall 2					
			Storage 6					
			Utility					

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
M-MAS-32	M	Mastic, Black, Brittle	Men's Restroom 1	Assumed	NF	G	1,500	SF
			Women's Restroom 1					
			Work Room 1					
			Work Room 2					
			Storage 1					
			Storage 2					
			Storage 3					
			Hall 1					
			Storage 4					
			Storage 5					
			Hall 2					
			Storage 6					
			Utility					
M-WAB-33	M	Wallbase (Coved), 4", Black, Vinyl-Like	Men's Restroom 1	Assumed	NF	G	125	SF
			Women's Restroom 1					
			Storage 1					
			Storage 2					
			Storage 3					
			Hall 1					
			Storage 4					
			Storage 7					
			Storage 5					
			Hall 2					
			Storage 6					
			Utility					
			Janitor					
M-ADH-34	M	Adhesive, Brown, Brittle	Men's Restroom 1	Assumed	NF	G	125	SF
			Women's Restroom 1					
			Storage 1					

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
			Storage 2					
			Storage 3					
			Hall 1					
			Storage 4					
			Storage 7					
			Storage 5					
			Hall 2					
			Storage 6					
			Utility					
			Janitor					
M-SLT-35	M	Sealant (Windows), Black, Gummy	Special Ed A-5	Assumed	NF	G	5	SF
			Special Ed To					
			Special Ed Office					
M-GWB-38	M	Gypsum Wallboard, White, Chalky	Storage 7	Assumed	NF	G	1,400	SF
			Lockers 3					
			Utility					
			Janitor					
S-JTC-39	S	Joint Compound, White, Chalky	Storage 7	Assumed	NF	G	140	SF
			Lockers 3					
			Utility					
			Janitor					
M-GWT-40	M	Glazed Wall Tile, 4"X6", Brown, Smooth	Utility	Assumed	NF	G	10	SF
M-GRT-41	M	Grout, Gray, Cementitious	Utility	Assumed	NF	G	1	SF
M-CON-42	M	Concrete (Entries), Gray, Cementitious	Courtyard 1	Assumed	NF	G	5,000	SF
			Courtyard 2					
			Exterior					

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
M-SLT-43	M	Sealant (Doors), Tan, Pliable	Courtyard 1	Assumed	NF	G	25	SF
			Courtyard 2					
			Exterior					
M-SLT-44	M	Sealant (Windows), Brown, Pliable	Courtyard 1	Assumed	NF	G	25	SF
			Courtyard 2					
M-SLT-45	M	Sealant (Windows), Black, Gummy	Courtyard 1	Assumed	NF	G	25	SF
			Courtyard 2					
S-STU-46	S	Stucco, Gray, Cementitious	Courtyard 1	Assumed	NF	G	3,500	SF
			Courtyard 2					
			Exterior					
M-CON-47	M	Concrete (Courtyard), Gray, Cementitious	Courtyard 1	Assumed	NF	G	2,000	SF
			Courtyard 2					
M-BRK-48	M	Brick (Planters), 4"X16", Red, Cementitious	Courtyard 1	Assumed	NF	G	900	SF
			Courtyard 2					
M-MRT-49	M	Mortar, Gray, Cementitious	Courtyard 1	Assumed	NF	G	90	SF
			Courtyard 2					
M-BUR-50	M	Built-Up Roofing, Black, Asphaltic, Gravel Cap	Roof	Assumed	NF	G	13,000	SF
M-MAS-51	M	Mastic (Penetrations And Flashings), Black, Tar-Like	Roof	Assumed	NF	G	1,300	SF
M-APR-52	M	Asphalt Prepared Roofing (Rolled), Black, Asphaltic, Tan Mineral Cap	Roof	Assumed	NF	G	600	SF

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
M-SLT-53	M	Sealant (Equipment), White, Pliable	Roof	Assumed	NF	G	20	SF
M-SLT-54	M	Sealant (Flashings), Gray, Pliable, Silver	Roof	Assumed	NF	G	25	SF

## 6-MONTH SURVEILLANCE INSPECTION TABLE

### IN-PLACE ASBESTOS-CONTAINING MATERIALS

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
M-SLT-10	M	Sealant (Doors, Windows, Millwork, Fixtures), White, Pliable	Men's Restroom 1	Assumed	NF	G	50	SF
			Women's Restroom 1					
			Work Room 1					
			Work Room 2					
			Storage 4					
			Storage 5					
			Classroom G-2					
			Classroom G-3					
			Classroom G-4					
			Classroom G-5					
			Classroom G-6					
			Room G-6 To					
			G-6 Office					
			Boy's Restroom 2					
			Girl's Restroom 2					
			Classroom G-7					
			Classroom G-8					
			Storage 6					
			Hall 2					
			Storage 7					
			Classroom G-9					
			Janitor					
			Classroom H-2					
			Classroom H-3					
			Classroom H-4					
			Special Ed H-5					
			Boy's Restroom 1					
			Girl's Restroom 1					

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
			Classroom H-6					
			Classroom H-7					
			Classroom H-8					
			Storage 2					
			Hall 1					
			Storage 1					
			Classroom H-9					
			Storage 3					
M-SAC-11	M	Sink Acoustical Coating, Black, Rough	Work Room 1	Assumed	NF	G	32	SF
			Work Room 2					
			Classroom G-2					
			Classroom G-3					
			Classroom G-4					
			Classroom G-5					
			Classroom G-6					
			Classroom G-9					
			Classroom H-2					
			Classroom H-3					
			Classroom H-4					
			Classroom H-5					
			Special Ed H-6					
			Classroom H-7					
			Classroom H-9					
M-FDI-12	M	Fire Door Insulation, Metal/Wood Cladding	Men's Restroom 1	Assumed	NF	G	882	SF
			Women's Restroom 1					
			Work Room 1					
			Work Room 2					
			Storage 4					
			Storage 5					

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
			Classroom G-2					
			Classroom G-3					
			Classroom G-4					
			Classroom G-5					
			Classroom G-6					
			Boy's Restroom 2					
			Girl's Restroom 2					
			Lockers 3					
			Classroom G-7					
			Classroom G-8					
			Storage 6					
			Hall 2					
			Storage 7					
			Classroom G-9					
			Janitor					
			Utility					
			Classroom H-2					
			Classroom H-3					
			Classroom H-4					
			Special Ed H-5					
			Boy's Restroom 1					
			Girl's Restroom 1					
			Lockers 1					
			Classroom H-6					
			Classroom H-7					
			Classroom H-8					
			Storage 2					
			Hall 1					
			Storage 1					
			Classroom H-9					
			Storage 3					
			Courtyard 1					
			Courtyard 2					



MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
			Exterior					
M-PSL-13	M	Pipe Sealant (Fire Sprinklers), White, Pliable	Men's Restroom 1	Assumed	NF	G	50	SF
			Women's Restroom 1					
			Work Room 1					
			Work Room 2					
			Storage 4					
			Storage 5					
			Classroom G-2					
			Classroom G-3					
			Classroom G-4					
			Classroom G-5					
			Classroom G-6					
			Room G-6 To					
			G-6 Office					
			Boy's Restroom 2					
			Girl's Restroom 2					
			Lockers 3					
			Classroom G-7					
			Classroom G-8					
			Storage 6					
			Hall 2					
			Storage 7					
			Classroom G-9					
			Janitor					
			Utility					
			Classroom H-2					
			Classroom H-3					
			Classroom H-4					
			Special Ed H-5					
			Boy's Restroom 1					
			Girl's Restroom 1					

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
			Lockers 1					
			Classroom H-6					
			Classroom H-7					
			Classroom H-8					
			Storage 2					
			Hall 1					
			Storage 1					
			Classroom H-9					
			Lockers 2					
			Storage 3					
S-PLA-15	S	Plaster, Gray, Cementitious	Lockers 3	Assumed	NF	G	700	SF
			Lockers 1					
			Lockers 2					
M-BRK-16	M	Brick, 4"X16", Tan, Cementitious	Lockers 3	Assumed	NF	G	15,000	SF
			Lockers 1					
			Lockers 2					
			Courtyard 1					
			Courtyard 2					
			Exterior					
M-BRK-17	M	Brick, 4"X16", Red, Cementitious	Lockers 3	Assumed	NF	G	15,000	SF
			Lockers 1					
			Lockers 2					
			Courtyard 1					
			Courtyard 2					
			Exterior					
M-MRT-18	M	Mortar, Gray, Cementitious	Lockers 3	Assumed	NF	G	3,000	SF

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
			Lockers 1					
			Lockers 2					
			Courtyard 1					
			Courtyard 2					
			Exterior					
M-EXJ-19	M	Expansion Joint, Brown, Pliable	Lockers 3	Assumed	NF	G	50	SF
			Lockers 1					
			Lockers 2					
			Courtyard 1					
			Courtyard 2					
			Exterior					
M-SLT-20	M	Sealant (Doors), Tan, Pliable	Lockers 3	Assumed	NF	G	32	SF
			Utility					
			Lockers 1					
			Courtyard 1					
			Courtyard 2					
			Exterior					
M-CON-21	M	Concrete (Equipment Pad), Gray, Cementitious	Lockers 1	Assumed	NF	G	25	SF
M-VCT-23	M	Vinyl Composition Tile, 12"X12", Tan, Smooth, Brown Mottles	Men's Restroom 1	Assumed	NF	G	1,200	SF
			Women's Restroom 1					
			Work Room 1					
			Work Room 2					
			Storage 4					
			Storage 5					
			Storage 6					
			Storage 7					

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
			Utility					
			Storage 2					
			Storage 1					
M-MAS-24	M	Mastic, Black, Brittle	Men's Restroom 1	Assumed	NF	G	1,200	SF
			Women's Restroom 1					
			Work Room 1					
			Work Room 2					
			Storage 4					
			Storage 5					
			Storage 6					
			Storage 7					
			Utility					
			Storage 2					
			Storage 1					
S-SAT-25	S	Spray-Applied Texture, White, Chalky	Men's Restroom 1	Assumed	NF	G	1,500	SF
			Women's Restroom 1					
			Boy's Restroom 2					
			Girl's Restroom 2					
			Janitor					
			Boy's Restroom 1					
			Girl's Restroom 1					
M-GWB-26	M	Gypsum Wallboard, White, Chalky	Men's Restroom 1	Assumed	NF	G	1,500	SF
			Women's Restroom 1					
			Boy's Restroom 2					
			Girl's Restroom 2					
			Janitor					
			Boy's Restroom 1					
			Girl's Restroom 1					

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
S-JTC-27	S	Joint Compound, White, Chalky	Men's Restroom 1	Assumed	NF	G	150	SF
			Women's Restroom 1					
			Boy's Restroom 2					
			Girl's Restroom 2					
			Janitor					
			Boy's Restroom 1					
			Girl's Restroom 1					
M-ADH-28	M	Adhesive (FRP), Brown, Brittle	Janitor	Assumed	NF	G	10	SF
M-CON-29	M	Concrete (Foundation), Gray, Cementitious	Men's Restroom 1	Assumed	NF	G	12,000	SF
			Women's Restroom 1					
			Work Room 1					
			Work Room 2					
			Storage 4					
			Storage 5					
			Classroom G-2					
			Classroom G-3					
			Classroom G-4					
			Classroom G-5					
			Classroom G-6					
			Room G-6 To					
			G-6 Office					
			Boy's Restroom 2					
			Girl's Restroom 2					
			Lockers 3					
			Classroom G-7					
			Classroom G-8					
			Storage 6					
			Hall 2					
			Storage 7					

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
			Classroom G-9					
			Janitor					
			Utility					
			Classroom H-2					
			Classroom H-3					
			Classroom H-4					
			Special Ed H-5					
			Boy's Restroom 1					
			Girl's Restroom 1					
			Lockers 1					
			Classroom H-6					
			Classroom H-7					
			Classroom H-8					
			Storage 2					
			Hall 1					
			Storage 1					
			Classroom H-9					
			Lockers 2					
			Storage 3					
			Exterior					
M-WAB-30	M	Wallbase (Coved), 4", Black, Vinyl-Like	Janitor	Assumed	NF	G	50	SF
			Utility					
			Storage 3					
M-ADH-31	M	Adhesive, Brown, Brittle	Janitor	Assumed	NF	G	50	SF
			Utility					
			Storage 3					
M-GWT-32	M	Glazed Wall Tile, 4"X6", Tan, Smooth	Boy's Restroom 2	Assumed	NF	G	900	SF
			Girl's Restroom 2					
			Boy's Restroom 1					

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
			Girl's Restroom 1					
M-GWT-33	M	Glazed Wall Tile, 4"X6", Brown, Smooth	Boy's Restroom 2	Assumed	NF	G	900	SF
			Girl's Restroom 2					
			Boy's Restroom 1					
			Girl's Restroom 1					
M-GRT-34	M	Grout, Gray, Cementitious	Boy's Restroom 2	Assumed	NF	G	200	SF
			Girl's Restroom 2					
			Boy's Restroom 1					
			Girl's Restroom 1					
M-CMT-35	M	Ceramic Mosaic Tile, 2"X2", Tan, Smooth, White Specks	Boy's Restroom 2	Assumed	NF	G	800	SF
			Girl's Restroom 2					
			Boy's Restroom 1					
			Girl's Restroom 1					
M-GRT-36	M	Grout, Gray, Cementitious	Boy's Restroom 2	Assumed	NF	G	80	SF
			Girl's Restroom 2					
			Boy's Restroom 1					
			Girl's Restroom 1					
M-SLT-37	M	Sealant (Windows), Black, Gummy	Classroom G-6	Assumed	NF	G	25	SF
			Room G-6 To					
			G-6 Office					
			Courtyard 1					
			Courtyard 2					
M-QPT-38	M	Quarry/Paver Tile, 6"X6", Gray, Textured	Lockers 3	Assumed	NF	G	200	SF
M-GRT-39	M	Grout, Gray, Cementitious	Lockers 3	Assumed	NF	G	20	SF

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
M-SLT-42	M	Sealant (Windows), Brown, Pliable	Courtyard 1	Assumed	NF	G	30	SF
			Courtyard 2					
M-CON-43	M	Concrete (Entries), Gray, Cementitious	Courtyard 1	Assumed	NF	G	6,000	SF
			Courtyard 2					
			Exterior					
M-CON-44	M	Concrete (Courtyards), Gray, Cementitious, Gravel Finish	Courtyard 1	Assumed	NF	G	2,000	SF
			Courtyard 2					
M-BRK-45	M	Brick (Planters), 4"X16", Red, Cementitious, White	Courtyard 1	Assumed	NF	G	900	SF
			Courtyard 2					
M-MRT-46	M	Mortar, Gray, Cementitious	Courtyard 1	Assumed	NF	G	90	SF
			Courtyard 2					
S-STU-47	S	Stucco, Gray, Cementitious	Courtyard 1	Assumed	NF	G	3,500	SF
			Courtyard 2					
M-SLT-48	M	Sealant (Walls), Gray, Pliable	Exterior	Assumed	NF	G	15	SF
M-BUR-49	M	Built-Up Roofing, Black, Asphaltic, Gravel Cap	Roof	Assumed	NF	G	13,000	SF
M-MAS-50	M	Mastic (Penetrations And Flashings), Black, Tar-Like	Roof	Assumed	NF	G	400	SF
M-APR-51	M	Asphalt Prepared Roofing (Rolled), Black, Asphaltic, Tan Mineral Cap	Roof	Assumed	NF	G	600	SF
M-SLT-52	M	Sealant (Equipment), White, Pliable	Roof	Assumed	NF	G	20	SF



MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
M-SLT-53	M	Sealant (Flashings), Gray, Pliable, Silver	Roof	Assumed	NF	G	50	SF

## 6-MONTH SURVEILLANCE INSPECTION TABLE

### IN-PLACE ASBESTOS-CONTAINING MATERIALS

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
M-SLT-10	M	Sealant (Doors, Windows, Millwork, Fixtures), White, Pliable	School Office	Assumed	NF	G	50	SF
			Waiting					
			Office F-4					
			Principal					
			Assistant Principal					
			Counselor F-1					
			Janitor					
			Health Waiting					
			Health Office					
			Health Storage					
			Test					
			Health Restroom					
			Health					
			Electrical					
			Boy's Restroom					
			Girl's Restroom					
			Isolated Classroom					
			Staff Lounge					
			Tele Room					
			Mail					
			Receiving					
			Student Advisor 2					
			Student Advisor 1					
			Counselor F-5					
			Storage 1					
			Counselor F-7					
			Women's Restroom					
			Men's Restroom					

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
			Corridor 1					
			Corridor 2					
			Corridor 3					
M·SLT·11	M	Sealant (Windows), Black, Gummy	School Office	Assumed	NF	G	30	SF
			Office F-4					
			Principal					
			Assistant Principal					
			Counselor F-1					
			Health Office					
			Health					
			Student Advisor 2					
			Student Advisor 1					
			Counselor F-5					
			Counselor F-7					
			Corridor 1					
			Corridor 2					
M·FDI·12	M	Fire Door Insulation, Metal/Wood Cladding	School Office	Assumed	NF	G	483	SF
			Waiting					
			Principal					
			Assistant Principal					
			Health Waiting					
			Health Storage					
			Health Office					
			Health					
			Electrical					
			Isolated Classroom					
			Staff Lounge					
			Receiving					
			Counselor F-5					
			Storage 1					

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
			Women's Restroom					
			Men's Restroom					
			Corridor 1					
			Corridor 2					
			Corridor 3					
			Exterior					
M-MRT-13	M	Mortar (Glass Block), Gray, Cementitious	School Office	Assumed	NF	G	75	SF
			Staff Lounge					
			Mail					
			Receiving					
			Student Advisor 2					
M-PSL-15	M	Pipe Sealant (Fire Sprinklers), White, Pliable	School Office	Assumed	NF	G	50	SF
			Waiting					
			Office F-4					
			Principal					
			Assistant Principal					
			Counselor F-1					
			Janitor					
			Health Waiting					
			Health Office					
			Health Storage					
			Test					
			Health Restroom					
			Health					
			Electrical					
			Boy's Restroom					
			Girl's Restroom					
			Isolated Classroom					
			Staff Lounge					
			Tele Room					

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
			Mail					
			Receiving					
			Student Advisor 2					
			Student Advisor 1					
			Counselor F-5					
			Storage 1					
			Counselor F-7					
			Women's Restroom					
			Men's Restroom					
			Corridor 1					
			Corridor 2					
			Corridor 3					
M·GWB·16	M	Gypsum Wallboard, White, Chalky	School Office	Assumed	NF	G	3,500	SF
			Corridor 1					
			Corridor 2					
			Corridor 3					
S·JTC·17	S	Joint Compound, White, Chalky	School Office	Assumed	NF	G	350	SF
			Corridor 1					
			Corridor 2					
			Corridor 3					
M·SAC·18	M	Sink Acoustical Coating, Black, Rough	Health Office	Assumed	NF	G	10	SF
			Health					
			Isolated Classroom					
			Staff Lounge					
			Mail					
M·BRK·19	M	Brick, 4"X16", Tan, Cementitious	Receiving	Assumed	NF	G	6,000	SF
			Exterior					

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
M-BRK-20	M	Brick, 4"X16", Red, Cementitious	Receiving	Assumed	NF	G	6,000	SF
			Exterior					
M-MRT-21	M	Mortar, Gray, Cementitious	Receiving	Assumed	NF	G	1,200	SF
			Exterior					
M-EXJ-22	M	Expansion Joint, Brown, Pliable	Receiving	Assumed	NF	G	50	SF
			Exterior					
M-VCT-23	M	Vinyl Composition Tile, 12"X2", Tan, Smooth, Brown Mottles	Janitor	Assumed	NF	G	600	SF
			Health Restroom					
			Boy's Restroom					
			Girl's Restroom					
			Women's Restroom					
			Men's Restroom					
M-MAS-24	M	Mastic, Black, Brittle	Janitor	Assumed	NF	G	600	SF
			Health Restroom					
			Boy's Restroom					
			Girl's Restroom					
			Women's Restroom					
			Men's Restroom					
M-WAB-25	M	Wallbase (Coved), 4", Black, Vinyl- Like	Janitor	Assumed	NF	G	125	SF
			Electrical					
			Boy's Restroom					
			Girl's Restroom					
			Women's Restroom					
			Men's Restroom					
M-ADH-26	M	Adhesive, Brown, Brittle	Janitor	Assumed	NF	G	125	SF
			Health Restroom					

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
			Electrical					
			Boy's Restroom					
			Girl's Restroom					
			Women's Restroom					
			Men's Restroom					
S·SAT·27	S	Spray-Applied Texture, White, Chalky	Health Restroom	Assumed	NF	G	2,500	SF
			Boy's Restroom					
			Girl's Restroom					
			Women's Restroom					
			Men's Restroom					
M·GWB·28	M	Gypsum Wallboard, White, Chalky	Health Restroom	Assumed	NF	G	2,500	SF
			Boy's Restroom					
			Girl's Restroom					
			Women's Restroom					
			Men's Restroom					
S·JTC·29	S	Joint Compound, White, Chalky	Health Restroom	Assumed	NF	G	250	SF
			Boy's Restroom					
			Girl's Restroom					
			Women's Restroom					
			Men's Restroom					
M·GWB·30	M	Gypsum Wallboard, White, Chalky	Janitor	Assumed	NF	G	750	SF
			Electrical					
S·JTC·31	S	Joint Compound, White, Chalky	Janitor	Assumed	NF	G	75	SF
			Electrical					
M·ADH·32	M	Adhesive (FRP), Brown, Brittle	Janitor	Assumed	NF	G	10	SF

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
M-GAS-33	M	Gasket, 8", Black, Vinyl-Like	Janitor	Assumed	NF	G	1	SF
M-VCT-34	M	Vinyl Composition Tile, 12"X12", White, Smooth, Gray Mottles	Electrical	Assumed	NF	G	50	SF
M-MAS-35	M	Mastic, Black, Brittle	Electrical	Assumed	NF	G	50	SF
M-CON-36	M	Concrete (Foundation), Gray, Cementitious	School Office	Assumed	NF	G	9,500	SF
			Waiting					
			Office F-4					
			Principal					
			Assistant Principal					
			Counselor F-1					
			Janitor					
			Health Waiting					
			Health Office					
			Health Storage					
			Test					
			Health Restroom					
			Health					
			Electrical					
			Boy's Restroom					
			Girl's Restroom					
			Isolated Classroom					
			Staff Lounge					
			Tele Room					
			Mail					
			Receiving					
			Student Advisor 2					
			Student Advisor 1					
			Counselor F-5					
			Storage 1					
			Counselor F-7					



MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
			Women's Restroom					
			Men's Restroom					
			Corridor 1					
			Corridor 2					
			Corridor 3					
			Exterior					
M-CON-37	M	Concrete (Entries), Gray, Cementitious	Exterior	Assumed	NF	G	4,000	SF
M-SLT-38	M	Sealant (Doors), Tan, Pliable	Exterior	Assumed	NF	G	15	SF
M-SLT-39	M	Sealant (Windows), Brown, Pliable	Exterior	Assumed	NF	G	10	SF
S-STU-40	S	Stucco, Gray, Cementitious	Exterior	Assumed	NF	G	250	SF
M-BUR-41	M	Built-Up Roofing, Black, Asphaltic, Gravel Cap	Roof	Assumed	NF	G	9,500	SF
M-MAS-42	M	Mastic (Penetrations And Flashings), Black, Tar-Like, Silver	Roof	Assumed	NF	G	500	SF
M-APR-43	M	Asphalt Prepared Roofing (Rolled), Black, Asphaltic, Tan Mineral Cap	Roof	Assumed	NF	G	200	SF
M-SLT-44	M	Sealant (Equipment), White, Pliable	Roof	Assumed	NF	G	10	SF
M-SLT-45	M	Sealant (Flashing), Gray, Pliable, Silver	Roof	Assumed	NF	G	50	SF

## 6-MONTH SURVEILLANCE INSPECTION TABLE

### IN-PLACE ASBESTOS-CONTAINING MATERIALS

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
M-SLT-10	M	Sealant (Doors, Windows, Millwork, Fixtures), White, Pliable	Speech	Assumed	NF	G	25	SF
			Speech T.O.					
			Computer Classroom 1					
			Office					
			Janitor					
			A/V Storage					
			Storage 1					
			Media Workshop					
			Media Center					
			Boy's Restroom					
			Girl's Restroom					
			Media Classroom					
			Computer Classroom 2					
			Special Education					
			Special Ed Office					
			Hall					
			Special Ed Restroom					
			Storage 2					
			Electrical					
M-SLT-11	M	Sealant (Windows), Black, Gummy	Computer Classroom 1	Assumed	NF	G	25	SF
			Office					
			Media Workshop					
			Media Center					
			Media Classroom					
			Computer Classroom 2					
			Special Education					
			Special Ed Office					

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
			Exterior					
M-FDI-12	M	Fire Door Insulation, Metal/Wood Cladding	Speech	Assumed	NF	G	357	SF
			Computer Classroom 1					
			Storage 1					
			Janitor					
			A/V Storage					
			Media Workshop					
			Media Center					
			Media Classroom					
			Computer Classroom 2					
			Special Education					
			Electrical					
			Exterior					
M-PSL-14	M	Pipe Sealant (Fire Sprinklers), White, Pliable	Speech	Assumed	NF	G	25	SF
			Speech T.O.					
			Computer Classroom 1					
			Office					
			Storage 1					
			Janitor					
			A/V Storage					
			Media Workshop					
			Media Center					
			Boy's Restroom					
			Girl's Restroom					
			Media Classroom					
			Computer Classroom 2					
			Special Education					
			Special Ed Office					
			Hall					
			Special Ed Restroom					

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
			Storage 2					
			Electrical					
S·SAT·15	S	Spray-Applied Texture, White, Chalky	Boy's Restroom	Assumed	NF	G	1,200	SF
			Girl's Restroom					
			Special Ed Restroom					
M·GWB·16	M	Gypsum Wallboard, White, Chalky	Boy's Restroom	Assumed	NF	G	1,200	SF
			Girl's Restroom					
			Special Ed Restroom					
S·JTC·17	S	Joint Compound, White, Chalky	Boy's Restroom	Assumed	NF	G	120	SF
			Girl's Restroom					
			Special Ed Restroom					
M·ADH·19	M	Adhesive (WAB), Cream, Pliable	Boy's Restroom	Assumed	NF	G	40	SF
			Girl's Restroom					
			Electrical					
M·VCT·20	M	Vinyl Composition Tile, 12"X12", Tan, Smooth, Brown Mottles	Boy's Restroom	Assumed	NF	G	100	SF
			Girl's Restroom					
M·MAS·21	M	Mastic, Black, Brittle	Boy's Restroom	Assumed	NF	G	100	SF
			Girl's Restroom					
M·SAC·23	M	Sink Acoustical Coating, Black, Rough	Speech	Assumed	NF	G	12	SF
			Computer Classroom 1					
			Media Workshop					
			Media Classroom					
			Computer Classroom 2					

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
			Special Education					
M-VCT-24	M	Vinyl Composition Tile, 12"X12", White, Smooth, Gray Mottles	Janitor	Assumed	NF	G	500	SF
			Special Ed Restroom					
			Storage 2					
			Electrical					
M-MAS-25	M	Mastic, Black, Brittle	Janitor	Assumed	NF	G	500	SF
			Special Ed Restroom					
			Storage 2					
			Electrical					
M-WAB-26	M	Wallbase (Coved), 4", Dark Gray, Vinyl-Like	Janitor	Assumed	NF	G	40	SF
			Special Ed Restroom					
			Storage 2					
M-ADH-27	M	Adhesive, Brown, Brittle	Janitor	Assumed	NF	G	40	SF
			Special Ed Restroom					
			Storage 2					
M-GWB-28	M	Gypsum Wallboard, White, Chalky	Janitor	Assumed	NF	G	1,000	SF
			Electrical					
S-JTC-29	S	Joint Compound, White, Chalky	Janitor	Assumed	NF	G	100	SF
			Electrical					
M-CON-30	M	Concrete (Foundation), Gray, Cementitious	Speech	Assumed	NF	G	15,000	SF
			Speech T.O.					
			Computer Classroom 1					
			Office					
			Storage 1					

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
			Janitor					
			A/V Storage					
			Media Workshop					
			Media Center					
			Boy's Restroom					
			Girl's Restroom					
			Media Classroom					
			Computer Classroom 2					
			Special Education					
			Special Ed Office					
			Hall					
			Special Ed Restroom					
			Storage 2					
			Electrical					
			Exterior					
M-CON-31	M	Concrete (Entries), Gray, Cementitious	Exterior	Assumed	NF	G	4,000	SF
M-BRK-32	M	Brick, 4"X16", Tan, Cementitious	Exterior	Assumed	NF	G	8,000	SF
M-BRK-33	M	Brick, 4"X16", Red, Cementitious	Exterior	Assumed	NF	G	8,000	SF
M-MRT-34	M	Mortar, Gray, Cementitious	Exterior	Assumed	NF	G	1,600	SF
M-EXJ-35	M	Expansion Joint, Tan, Pliable	Exterior	Assumed	NF	G	25	SF
M-SLT-36	M	Sealant (Doors), Brown, Brittle	Exterior	Assumed	NF	G	15	SF
M-SLT-37	M	Sealant (Windows), Black, Pliable	Exterior	Assumed	NF	G	20	SF
M-GAS-39	M	Gasket, 8", Black, Vinyl-Like	Janitor	Assumed	NF	G	1	SF

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
M-BUR-40	M	Built-Up Roofing, Black, Asphaltic, Gravel Cap	Roof	Assumed	NF	G	15,000	SF
M-MAS-41	M	Mastic (Penetrations And Flashings), Black, Tar-Like, Silver	Roof	Assumed	NF	G	500	SF
M-APR-42	M	Asphalt Prepared Roofing (Rolled), Black, Asphaltic, Tan Mineral Cap	Roof	Assumed	NF	G	200	SF
M-SLT-43	M	Sealant (Equipment), White, Pliable	Roof	Assumed	NF	G	10	SF
M-SLT-44	M	Sealant (Flashing), Gray, Pliable, Silver	Roof	Assumed	NF	G	25	SF
S-STU-45	S	Stucco, Gray, Cementitious	Roof	Assumed	NF	G	250	SF
M-SLT-46	M	Sealant (Windows), Brown, Pliable	Roof	Assumed	NF	G	10	SF

## 6-MONTH SURVEILLANCE INSPECTION TABLE

### IN-PLACE ASBESTOS-CONTAINING MATERIALS

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
M-FDI-10	M	Fire Door Insulation, Metal/Wood Cladding	Drama	Assumed	NF	G	651	SF
			Maintenance					
			Janitor					
			Home Economics					
			Home Economics Restroom					
			Storage 5					
			Art					
			Storage 4					
			Storage 3					
			Weight Room					
			Wood Shop					
			Classroom D5					
			Storage 1					
			Storage 2					
			Classroom D6					
			Music					
			Play Yard					
			Maintenance Yard					
			Home Economics Patio					
			Art Patio					
			Industrial Arts Yard					
			Exterior					
M-SLT-11	M	Sealant (Doors, Windows, Millwork, Fixtures), White, Pliable	Drama	Assumed	NF	G	50	SF
			Laundry					
			Maintenance					
			Office 2					
			Janitor					



MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
			Home Economics					
			Home Economics Restroom					
			Storage 5					
			Office 1					
			Art					
			Storage 4					
			Storage 3					
			Weight Room					
			Wood Shop					
			Classroom D5					
			Storage 1					
			Storage 2					
			Classroom D6					
			Music					
M-SAC-12	M	Sink Acoustical Coating, Black, Rough	Home Economics	Assumed	NF	G	20	SF
			Classroom D5					
			Classroom D6					
			Music					
M-SLT-14	M	Sealant (Duct), Gray, Pliable	Drama	Assumed	NF	G	50	SF
			Laundry					
			Maintenance					
			Office 2					
			Janitor					
			Home Economics					
			Home Economics Restroom					
			Storage 5					
			Office 1					
			Art					
			Storage 4					
			Storage 3					

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
			Classroom D5					
			Storage 1					
			Storage 2					
			Classroom D6					
			Music					
M-PSL-15	M	Pipe Sealant (Fire Sprinklers), White, Pliable	Drama	Assumed	NF	G	50	SF
			Laundry					
			Maintenance					
			Office 2					
			Janitor					
			Home Economics					
			Home Economics Restroom					
			Storage 5					
			Office 1					
			Art					
			Storage 4					
			Storage 3					
			Weight Room					
			Wood Shop					
			Classroom D5					
			Storage 1					
			Storage 2					
			Classroom D6					
			Music					
M-VCT-16	M	Vinyl Composition Tile, 12"X12", Tan, Smooth, Brown Mottles	Laundry	Assumed	NF	G	3,000	SF
			Maintenance					
			Janitor					
			Home Economics Restroom					
			Storage 5					
			Art					

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
			Storage 4					
			Storage 3					
M-MAS-17	M	Mastic, Black, Brittle	Laundry	Assumed	NF	G	3,000	SF
			Maintenance					
			Janitor					
			Home Economics Restroom					
			Storage 5					
			Art					
			Storage 4					
			Storage 3					
M-CON-18	M	Concrete (Foundation), Gray, Cementitious	Drama	Assumed	NF	G	6,500	SF
			Drama Restroom					
			Drama Storage					
			Storage 6					
			Laundry					
			Maintenance					
			Office 2					
			Janitor					
			Home Economics					
			Home Economics Restroom					
			Storage 5					
			Office 1					
			Art					
			Storage 4					
			Storage 3					
			Weight Room					
			Wood Shop					
			Classroom D5					
			Storage 1					
			Storage 2					

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
			Classroom D6					
			Music					
			Exterior					
M-SLT-19	M	Sealant (Windows), Black, Gummy	Drama	Assumed	NF	G	20	SF
			Office 2					
			Home Economics					
			Office 1					
			Art					
			Weight Room					
			Wood Shop					
			Classroom D5					
			Storage 2					
			Art Patio					
			Exterior					
M-SAC-22	M	Sink Acoustical Coating, Gray, Rough	Art	Assumed	NF	G	6	SF
M-CPT-23	M	Carpet, Brown, Fibrous	Office 1	Assumed	NF	G	100	SF
M-MAS-24	M	Mastic, Tan, Brittle	Office 1	Assumed	NF	G	100	SF
M-VCT-25	M	Vinyl Composition Tile, 12"X12", White, Smooth, Blue Mottles	Home Economics	Assumed	NF	G	1,500	SF
M-VCT-26	M	Vinyl Composition Tile, 12"X12", Blue, Smooth, Light Blue Mottles	Home Economics	Assumed	NF	G	300	SF
M-MAS-27	M	Mastic, Black, Brittle	Home Economics	Assumed	NF	G	1,800	SF
M-WAB-28	M	Wallbase (Coved), 4", Blue, Vinyl-Like	Office 2	Assumed	NF	G	65	SF
			Home Economics					

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
M-ADH-29	M	Adhesive, Brown, Brittle	Office 2	Assumed	NF	G	65	SF
			Home Economics					
S-SAT-30	S	Spray-Applied Texture, White, Chalky	Laundry	Assumed	NF	G	1,500	SF
			Janitor					
			Home Economics Restroom					
M-GWB-31	M	Gypsum Wallboard, White, Chalky	Laundry	Assumed	NF	G	1,500	SF
			Janitor					
			Home Economics Restroom					
S-JTC-32	S	Joint Compound, White, Chalky	Laundry	Assumed	NF	G	150	SF
			Janitor					
			Home Economics Restroom					
M-GAS-35	M	Gasket, 6", Black, Vinyl-Like	Maintenance	Assumed	NF	G	1	SF
M-GWB-36	M	Gypsum Wallboard, White, Chalky	Maintenance	Assumed	NF	G	750	SF
S-JTC-37	S	Joint Compound, White, Chalky	Maintenance	Assumed	NF	G	75	SF
M-CON-38	M	Concrete (Entries), Gray, Cementitious	Play Yard	Assumed	NF	G	6,000	SF
			Maintenance Yard					
			Home Ec Patio					
			Art Patio					
			Industrial Arts Yard					
			Exterior					
M-BRK-39	M	Brick, 4"X16", Tan, Cementitious	Play Yard	Assumed	NF	G	13,500	SF
			Maintenance Yard					
			Home Ec Patio					
			Art Patio					

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
			Industrial Arts Yard					
			Exterior					
M-BRK-40	M	Brick, 4"X16", Red, Cementitious	Play Yard	Assumed	NF	G	13,500	SF
			Maintenance Yard					
			Home Ec Patio					
			Art Patio					
			Industrial Arts Yard					
			Exterior					
M-MRT-41	M	Mortar, Gray, Cementitious	Play Yard	Assumed	NF	G	2,700	SF
			Maintenance Yard					
			Home Ec Patio					
			Art Patio					
			Industrial Arts Yard					
			Exterior					
M-EXJ-42	M	Expansion Joint, Brown, Pliable	Play Yard	Assumed	NF	G	50	SF
			Maintenance Yard					
			Home Ec Patio					
			Art Patio					
			Industrial Arts Yard					
			Exterior					
M-SLT-43	M	Sealant (Doors), Tan, Brittle	Play Yard	Assumed	NF	G	20	SF
			Maintenance Yard					
			Home Ec Patio					
			Art Patio					
			Industrial Arts Yard					
			Exterior					
M-SLT-44	M	Sealant (Windows), Brown, Pliable	Art Patio	Assumed	NF	G	20	SF
			Exterior					

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
M·CON·45	M	Concrete (Equipment Pad), Gray, Cementitious	Exterior	Assumed	NF	G	20	SF
M·SLT·46	M	Sealant (Duct), Gray, Brittle	Industrial Arts Yard	Assumed	NF	G	5	SF
M·WDB·47	M	Woven Duct Boot, 4", Black, Vinyl-Like	Industrial Arts Yard	Assumed	NF	G	2	SF
M·BUR·48	M	Built-Up Roofing, Black, Asphaltic, Gravel Cap	Roof	Assumed	NF	G	6,500	SF
M·MAS·49	M	Mastic (Penetrations And Flashings), Black, Tar-Like, Silver	Roof	Assumed	NF	G	400	SF
M·APR·50	M	Asphalt Prepared Roofing (Rolled), Black, Asphaltic, Tan Mineral Cap	Roof	Assumed	NF	G	200	SF
M·SLT·51	M	Sealant (Equipment), White, Pliable	Roof	Assumed	NF	G	10	SF
M·SLT·52	M	Sealant (Flashings), Gray, Pliable, Silver	Roof	Assumed	NF	G	50	SF

## 6-MONTH SURVEILLANCE INSPECTION TABLE

### IN-PLACE ASBESTOS-CONTAINING MATERIALS

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
M-BRK-06	M	Brick, 4"X16", Tan, Cementitious	Lobby	Assumed	NF	G	22,000	SF
			Hall 3					
			East Wing					
			Music					
			Guitar Lab					
			Storage 3					
			Cafeteria					
			Gym					
			Hall 1					
			Girl's Locker Room					
			P.E. Storage					
			P.E. Office 1					
			P.E. Office 2					
			Boy's Locker Room					
			Hall 2					
M-BRK-07	M	Brick, 4"X16", Red, Cementitious	Lobby	Assumed	NF	G	22,000	SF
			Hall 3					
			East Wing					
			Music					
			Guitar Lab					
			Storage 3					
			Cafeteria					
			Gym					
			Hall 1					
			Girl's Locker Room					
			P.E. Storage					
			P.E. Office 1					
			P.E. Office 2					



MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
			Boy's Locker Room					
			Hall 2					
M-MRT-08	M	Mortar, Gray, Cementitious	Lobby	Assumed	NF	G	4,400	SF
			Hall 3					
			East Wing					
			Music					
			Guitar Lab					
			Storage 3					
			Cafeteria					
			Gym					
			Hall 1					
			Girl's Locker Room					
			P.E. Storage					
			P.E. Office 1					
			P.E. Office 2					
			Boy's Locker Room					
			Hall 2					
M-EXJ-09	M	Expansion Joint, Brown, Pliable	Lobby	Assumed	NF	G	200	SF
			Hall 3					
			East Wing					
			Music					
			Guitar Lab					
			Storage 3					
			Cafeteria					
			Gym					
			Hall 1					
			Girl's Locker Room					
			P.E. Storage					
			P.E. Office 1					
			P.E. Office 2					
			Boy's Locker Room					

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
			Hall 2					
M-SLT-10	M	Sealant (Doors, Windows, Millwork, Fixtures), White, Pliable	Lobby	Assumed	NF	G	50	SF
			Girl's Restroom 1					
			Boy's Restroom 1					
			Kitchen					
			Kitchen Office					
			Kitchen Restroom					
			Kitchen Lockers					
			Storage 1					
			Electrical 1					
			Storage 2					
			Hall 3					
			East Wing					
			Music					
			Guitar Lab					
			Listening					
			Keyboard Lab					
			Storage 3					
			Cafeteria					
			Hall 1					
			Girl's Locker Room					
			P.E. Storage					
			P.E. Office 1					
			P.E. Restroom 1					
			P.E. Restroom 2					
			P.E. Office 2					
			Storage 5					
			Boy's Locker Room					
			Hall 2					
M-SAC-11	M	Sink Acoustical Coating, Black, Rough	Music	Assumed	NF	G	2	SF

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
M-SLT-12	M	Sealant (Windows), Black, Gummy	Kitchen	Assumed	NF	G	15	SF
			Kitchen Office					
			Music					
			Guitar Lab					
			Listening					
			Girl's Locker Room					
			P.E. Office 1					
			P.E. Office 2					
			Boy's Locker Room					
M-FDI-17	M	Fire Door Insulation, Metal/Wood Cladding	Lobby	Assumed	NF	G	1,386	SF
			Girl's Restroom 1					
			Boy's Restroom 1					
			Kitchen					
			Kitchen Lockers					
			Storage 1					
			Electrical 1					
			Hall 3					
			Stage					
			East Wing					
			Music					
			Cafeteria					
			Gym					
			Storage 4					
			Hall 1					
			Girl's Locker Room					
			P.E. Storage					
			P.E. Office 1					
			P.E. Office 2					
			Storage 5					
			Boy's Locker Room					

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
			Hall 2					
			Exterior					
M-PSL-19	M	Pipe Sealant (Fire Sprinklers), White, Pliable	Lobby	Assumed	NF	G	50	SF
			Girl's Restroom 1					
			Boy's Restroom 1					
			Kitchen					
			Kitchen Office					
			Kitchen Restroom					
			Kitchen Lockers					
			Storage 1					
			Electrical 1					
			Storage 2					
			Hall 3					
			Stage					
			East Wing					
			Music					
			Guitar Lab					
			Listening					
			Keyboard Lab					
			Storage 3					
			Cafeteria					
			Gym					
			Storage 4					
			Hall 1					
			Girl's Locker Room					
			P.E. Storage					
			P.E. Office 1					
			P.E. Restroom 1					
			P.E. Restroom 2					
			P.E. Office 2					
			Storage 5					

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
			Boy's Locker Room					
			Hall 2					
M-WAB-22	M	Wallbase (Coved), 4", Black, Vinyl-Like	Kitchen Office	Assumed	NF	G	75	SF
			Electrical 1					
			East Wing					
			Storage 4					
			Hall 1					
			Hall 2					
M-ADH-23	M	Adhesive, Brown, Brittle	Kitchen Office	Assumed	NF	G	75	SF
			Electrical 1					
			East Wing					
			Storage 4					
			Hall 1					
			Hall 2					
M-VST-24	M	Vinyl Stair Tread, 12"X36", Tan, Textured, Diamond Pattern	Hall 3	Assumed	NF	G	75	SF
			Cafeteria					
M-MAS-25	M	Mastic, Yellow, Tacky	Hall 3	Assumed	NF	G	75	SF
			Cafeteria					
M-VCT-26	M	Vinyl Composition Tile, 12"X12", White, Smooth, Gray Mottles	Electrical 1	Assumed	NF	G	5,000	SF
			Hall 3					
			Cafeteria					
M-MAS-27	M	Mastic, Black, Brittle	Electrical 1	Assumed	NF	G	5,000	SF
			Hall 3					
			Cafeteria					

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
M-VCT-28	M	Vinyl Composition Tile (Pattern), 12"X12", Brown, Smooth, White Mottles	Cafeteria	Assumed	NF	G	50	SF
M-QPT-32	M	Quarry/Paver Tile, 6"X6", Red, Smooth	Kitchen	Assumed	NF	G	2,200	SF
			Kitchen Restroom					
			Kitchen Lockers					
			Storage 1					
			Cafeteria					
M-GRT-33	M	Grout, Gray, Cementitious	Kitchen	Assumed	NF	G	220	SF
			Kitchen Restroom					
			Kitchen Lockers					
			Storage 1					
			Cafeteria					
M-VCT-34	M	Vinyl Composition Tile, 12"X12", Tan, Smooth, Brown Mottles	Kitchen Office	Assumed	NF	G	750	SF
			Storage 2					
			Storage 4					
			Hall 1					
			Hall 2					
M-MAS-35	M	Mastic, Black, Brittle	Kitchen Office	Assumed	NF	G	750	SF
			Storage 2					
			Storage 4					
			Hall 1					
			Hall 2					
S-SAT-37	S	Spray-Applied Texture, White, Chalky	Girl's Restroom 1	Assumed	NF	G	2,000	SF
			Boy's Restroom 1					
			Kitchen Restroom					
			Kitchen Lockers					

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
			P.E. Restroom 1					
			P.E. Restroom 2					
M-GWB-38	M	Gypsum Wallboard, White, Chalky	Girl's Restroom 1	Assumed	NF	G	2,000	SF
			Boy's Restroom 1					
			Kitchen Restroom					
			Kitchen Lockers					
			P.E. Restroom 1					
			P.E. Restroom 2					
S-JTC-39	S	Joint Compound, White, Chalky	Girl's Restroom 1	Assumed	NF	G	200	SF
			Boy's Restroom 1					
			Kitchen Restroom					
			Kitchen Lockers					
			P.E. Restroom 1					
			P.E. Restroom 2					
M-GWB-40	M	Gypsum Wallboard, White, Chalky	Electrical 1	Assumed	NF	G	450	SF
S-JTC-41	S	Joint Compound, White, Chalky	Electrical 1	Assumed	NF	G	45	SF
M-CPT-43	M	Carpet, Brown, Fibrous	Storage 3	Assumed	NF	G	550	SF
M-MAS-44	M	Mastic, Yellow, Brittle	Storage 3	Assumed	NF	G	550	SF
M-GAS-45	M	Gasket, 8", Black, Vinyl-Like	Storage 3	Assumed	NF	G	1	SF
M-GWT-46	M	Glazed Wall Tile, 4"X4", Tan, Smooth	Lobby	Assumed	NF	G	1,800	SF
			Girl's Restroom 1					
			Boy's Restroom 1					
			Girl's Locker Room					
			Boy's Locker Room					

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
M-GWT-47	M	Glazed Wall Tile, 4"X4", Brown, Smooth	Lobby	Assumed	NF	G	1,800	SF
			Girl's Restroom 1					
			Boy's Restroom 1					
			Girl's Locker Room					
			Boy's Locker Room					
M-GRT-48	M	Grout, Gray, Cementitious	Lobby	Assumed	NF	G	360	SF
			Girl's Restroom 1					
			Boy's Restroom 1					
			Girl's Locker Room					
			Boy's Locker Room					
M-CMT-49	M	Ceramic Mosaic Tile, 2"X2", Tan, Smooth, White Specks	Girl's Locker Room	Assumed	NF	G	2,000	SF
			Boy's Locker Room					
M-GRT-50	M	Grout, Gray, Cementitious	Girl's Locker Room	Assumed	NF	G	200	SF
			Boy's Locker Room					
M-MRT-51	M	Mortar (Glass Block), Gray, Cementitious,	Exterior	Assumed	NF	G	40	SF
M-SLT-52	M	Sealant (Doors), Tan, Pliable	Lobby	Assumed	NF	G	25	SF
			Gym					
			Storage 4					
			Hall 1					
			Girl's Locker Room					
			Boy's Locker Room					
			Hall 2					
			Exterior					
M-GWB-53	M	Gypsum Wallboard, White, Chalky, Vinyl Cover	Lobby	Assumed	NF	G	500	SF



MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
S-JTC-54	S	Joint Compound, White, Chalky	Lobby	Assumed	NF	G	50	SF
M-GWB-57	M	Gypsum Wallboard, White, Chalky	Storage 4	Assumed	NF	G	400	SF
S-JTC-58	S	Joint Compound, White, Chalky	Storage 4	Assumed	NF	G	40	SF
M-PLA-59	M	Plaster, Gray, Cementitious	Girl's Locker Room	Assumed	NF	G	5,000	SF
			Boy's Locker Room					
M-CON-60	M	Concrete (Foundation), Gray, Cementitious	Lobby	Assumed	NF	G	27,800	SF
			Girl's Restroom 1					
			Boy's Restroom 1					
			Kitchen					
			Kitchen Office					
			Kitchen Restroom					
			Kitchen Lockers					
			Storage 1					
			Electrical 1					
			Storage 2					
			Hall 3					
			Stage					
			East Wing					
			Music					
			Guitar Lab					
			Listening					
			Keyboard Lab					
			Storage 3					
			Cafeteria					
			Gym					
			Storage 4					
			Hall 1					

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
			Girl's Locker Room					
			P.E. Storage					
			P.E. Office 1					
			P.E. Restroom 1					
			P.E. Restroom 2					
			P.E. Office 2					
			Storage 5					
			Boy's Locker Room					
			Hall 2					
			Exterior					
M-EXJ-61	M	Expansion Joint, Gray, Pliable	Exterior	Assumed	NF	G	150	SF
M-CON-62	M	Concrete (Entries), Gray, Cementitious	Exterior	Assumed	NF	G	8,000	SF
M-QPT-63	M	Quarry/Paver Tile, 4"X16", Red, Cementitious	Exterior	Assumed	NF	G	250	SF
M-GRT-64	M	Grout, Gray, Cementitious	Exterior	Assumed	NF	G	25	SF
M-QPT-65	M	Quarry/Paver Tile, 4"X8", Red, Smooth	Exterior	Assumed	NF	G	250	SF
S-STU-66	S	Stucco, Gray, Cementitious	Exterior	Assumed	NF	G	100	SF
M-BUR-67	M	Built-Up Roofing, Black, Asphaltic, Gravel Cap	Roof	Assumed	NF	G	28,000	SF
M-MAS-68	M	Mastic (Penetrations And Flashings), Black, Tar-Like, Silver	Roof	Assumed	NF	G	1,500	SF
M-APR-69	M	Asphalt Prepared Roofing (Rolled), Black, Asphaltic, Tan Mineral Cap	Roof	Assumed	NF	G	400	SF

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	<b>M/S/T</b>			<b>%/ASSUMED</b>	<b>NF/F</b>	<b>G/D/SD</b>		<b>LF/SF/EA</b>
M-SLT-70	M	Sealant (Equipment), White, Pliable	Roof	Assumed	NF	G	20	SF
M-SLT-71	M	Sealant (Flashings), Gray, Pliable, Silver	Roof	Assumed	NF	G	75	SF

## 6-MONTH SURVEILLANCE INSPECTION TABLE

### IN-PLACE ASBESTOS-CONTAINING MATERIALS

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
M-SLT-10	M	Sealant (Doors, Windows, Millwork, Fixtures), White, Pliable	Classroom I-2	Assumed	NF	G	100	SF
			Classroom I-3					
			Classroom I-4					
			Classroom I-5					
			Classroom I-6					
			Classroom I-7					
			Resource I-8					
			Classroom I-9					
			Storage 3					
			Storage 4					
			Workroom					
			Office 2					
			Storage 6					
			Boy's Restroom 2					
			Storage 7					
			Girl's Restroom 2					
			Storage 8					
			Janitor					
			Boy's Restroom 1					
			Girl's Restroom 1					
			Girl's Restroom 3					
			Boy's Restroom 3					
			Storage 5					
			Music Office					
			Electrical					
			Music					
			Classroom J-2					
			Classroom J-3					

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
			Classroom J-4					
			Classroom J-5					
			Classroom J-6					
			Classroom J-7					
			Classroom J-7 TO					
			Classroom J-7 Shower					
			Classroom J-7 Restroom					
			Classroom J-9					
			Storage 1					
			Office 1					
			Storage 2					
M-FDI-11	M	Fire Door Insulation, Metal/Wood Cladding	Classroom I-2	Assumed	NF	G	1,134	SF
			Classroom I-3					
			Classroom I-4					
			Classroom I-5					
			Classroom I-6					
			Classroom I-7					
			Resource I-8					
			Classroom I-9					
			Storage 3					
			Storage 4					
			Workroom					
			Office 2					
			Storage 6					
			Boy's Restroom 2					
			Storage 7					
			Girl's Restroom 2					
			Storage 8					
			Boy's Restroom 1					
			Girl's Restroom 1					
			Girl's Restroom 3					

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
			Boy's Restroom 3					
			Storage 5					
			Music Office					
			Electrical					
			Music					
			Classroom J-2					
			Classroom J-3					
			Classroom J-4					
			Classroom J-5					
			Classroom J-6					
			Classroom J-7					
			Classroom J-9					
			Office 1					
			Storage 2					
			Courtyard 1					
			Courtyard 2					
			Exterior					
M·PSL·12	M	Pipe Sealant (Fire Sprinklers), White, Pliable	Classroom I-2	Assumed	NF	G	75	SF
			Classroom I-3					
			Classroom I-4					
			Classroom I-5					
			Classroom I-6					
			Classroom I-7					
			Resource I-8					
			Classroom I-9					
			Storage 3					
			Storage 4					
			Workroom					
			Office 2					
			Storage 6					
			Boy's Restroom 2					

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
			Storage 7					
			Girl's Restroom 2					
			Storage 8					
			Janitor					
			Boy's Restroom 1					
			Girl's Restroom 1					
			Girl's Restroom 3					
			Boy's Restroom 3					
			Storage 5					
			Practice Room					
			Music Office					
			Electrical					
			Music					
			Classroom J-2					
			Classroom J-3					
			Classroom J-4					
			Classroom J-5					
			Classroom J-6					
			Classroom J-7					
			Classroom J-7 TO					
			Classroom J-7 Shower					
			Classroom J-7 Restroom					
			Classroom J-9					
			Storage 1					
			Office 1					
			Storage 2					
M-VCT-14	M	Vinyl Composition Tile, 12"X12", White, Smooth, Gray Streaks	Storage 3	Assumed	NF	G	2,200	SF
			Storage 4					
			Storage 6					
			Storage 7					
			Storage 8					

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
			Janitor					
			Storage 5					
			Music Office					
			Electrical					
			Classroom J-7					
			Storage 1					
			Office 1					
M-MAS-15	M	Mastic, Black, Brittle	Storage 3	Assumed	NF	G	2,200	SF
			Storage 4					
			Storage 6					
			Storage 7					
			Storage 8					
			Janitor					
			Storage 5					
			Music Office					
			Electrical					
			Classroom J-7					
			Storage 1					
			Office 1					
M-SLT-16	M	Sealant (Windows), Black, Gummy	Office 2	Assumed	NF	G	6	SF
			Music Office					
			Music					
			Classroom J-7					
			Room J-7 TO					
			Exterior					
S-SAT-17	S	Spray-Applied Texture, White, Chalky	Boy's Restroom 2	Assumed	NF	G	2,500	SF
			Girl's Restroom 2					
			Boy's Restroom 1					
			Girl's Restroom 1					



MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
			Girl's Restroom 3					
			Boy's Restroom 3					
			Room J-7 Shower					
			Room J-7 Restroom					
M·GWB·18	M	Gypsum Wallboard, White, Chalky	Boy's Restroom 2	Assumed	NF	G	2,500	SF
			Girl's Restroom 2					
			Boy's Restroom 1					
			Girl's Restroom 1					
			Girl's Restroom 3					
			Boy's Restroom 3					
			Room J-7 Shower					
			Room J-7 Restroom					
S·JTC·19	S	Joint Compound, White, Chalky	Boy's Restroom 2	Assumed	NF	G	250	SF
			Girl's Restroom 2					
			Boy's Restroom 1					
			Girl's Restroom 1					
			Girl's Restroom 3					
			Boy's Restroom 3					
			Room J-7 Shower					
			Room J-7 Restroom					
M·GWT·20	M	Glazed Wall Tile, 4"X4", White, Smooth, Peppered	Boy's Restroom 2	Assumed	NF	G	3,000	SF
			Girl's Restroom 2					
			Boy's Restroom 1					
			Girl's Restroom 1					
			Girl's Restroom 3					
			Boy's Restroom 3					
			Room J-7 Shower					
			Room J-7 Restroom					

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
M-GWT-21	M	Glazed Wall Tile (Pattern), 2"X2", Black, Smooth	Boy's Restroom 2	Assumed	NF	G	100	SF
			Girl's Restroom 2					
			Boy's Restroom 1					
			Girl's Restroom 1					
			Girl's Restroom 3					
			Boy's Restroom 3					
			Room J-7 Shower					
			Room J-7 Restroom					
M-GRT-22	M	Grout, Gray, Cementitious	Boy's Restroom 2	Assumed	NF	G	300	SF
			Girl's Restroom 2					
			Boy's Restroom 1					
			Girl's Restroom 1					
			Girl's Restroom 3					
			Boy's Restroom 3					
			Room J-7 Shower					
			Room J-7 Restroom					
M-CMT-23	M	Ceramic Mosaic Tile, 2"X2", White, Smooth, Peppered	Boy's Restroom 2	Assumed	NF	G	2,200	SF
			Girl's Restroom 2					
			Boy's Restroom 1					
			Girl's Restroom 1					
			Girl's Restroom 3					
			Boy's Restroom 3					
			Room J-7 Shower					
			Room J-7 Restroom					
M-GRT-24	M	Grout, Gray, Cementitious	Boy's Restroom 2	Assumed	NF	G	220	SF
			Girl's Restroom 2					
			Boy's Restroom 1					
			Girl's Restroom 1					
			Girl's Restroom 3					

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
			Boy's Restroom 3					
			Room J-7 Shower					
			Room J-7 Restroom					
M·SAC·25	M	Sink Acoustical Coating, Black, Rough	Classroom I-2	Assumed	NF	G	26	SF
			Classroom I-3					
			Classroom I-4					
			Classroom I-5					
			Classroom I-6					
			Resource I-8					
			Workroom					
			Music					
			Classroom J-2					
			Classroom J-3					
			Classroom J-4					
			Classroom J-5					
			Classroom J-6					
M·GAS·28	M	Gasket, 8", Black, Vinyl-Like	Storage 5	Assumed	NF	G	1	SF
S·TOT·29	S	Troweled-On Texture, White, Chalky	Janitor	Assumed	NF	G	500	SF
			Electrical					
M·GWB·30	M	Gypsum Wallboard, White, Chalky	Janitor	Assumed	NF	G	500	SF
			Electrical					
S·JTC·31	S	Joint Compound, White, Chalky	Janitor	Assumed	NF	G	50	SF
			Electrical					
M·ADH·32	M	Adhesive (FRP), Brown, Brittle	Janitor	Assumed	NF	G	10	SF
M·GWB·33	M	Gypsum Wallboard, White, Chalky	Storage 6	Assumed	NF	G	200	SF

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
			Storage 8					
S-JTC-34	S	Joint Compound, White, Chalky	Storage 6	Assumed	NF	G	20	SF
			Storage 8					
M-BRK-35	M	Brick, 4"X16", Tan, Cementitious	Courtyard 1	Assumed	NF	G	22,000	SF
			Courtyard 2					
			Exterior					
M-BRK-36	M	Brick, 4"X16", Red, Cementitious	Courtyard 1	Assumed	NF	G	22,000	SF
			Courtyard 2					
			Exterior					
M-MRT-37	M	Mortar, Gray, Cementitious	Courtyard 1	Assumed	NF	G	4,400	SF
			Courtyard 2					
			Exterior					
M-EXJ-38	M	Expansion Joint, Brown, Pliable	Courtyard 1	Assumed	NF	G	100	SF
			Courtyard 2					
			Exterior					
M-SLT-39	M	Sealant (Doors), Tan, Pliable	Courtyard 1	Assumed	NF	G	50	SF
			Courtyard 2					
			Exterior					
M-CON-40	M	Concrete (Entries), Gray, Cementitious	Courtyard 1	Assumed	NF	G	6,000	SF
			Courtyard 2					
			Exterior					
M-CON-41	M	Concrete (Courtyards), Gray, Cementitious, Gravel Finish	Courtyard 1	Assumed	NF	G	1,500	SF
			Courtyard 2					

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
M-BRK-42	M	Brick (Planters), 4"X16", Red, Cementitious, White	Courtyard 1	Assumed	NF	G	1,000	SF
			Courtyard 2					
M-MRT-43	M	Mortar, Gray, Cementitious	Courtyard 1	Assumed	NF	G	100	SF
			Courtyard 2					
M-CMU-44	M	Concrete Masonry Unit, 8"X16", Gray, Cementitious	Exterior	Assumed	NF	G	500	SF
M-CMU-45	M	Concrete Masonry Unit, 2"X16", Gray, Smooth	Exterior	Assumed	NF	G	10	SF
M-MRT-46	M	Mortar, Gray, Cementitious	Exterior	Assumed	NF	G	50	SF
M-QPT-47	M	Quarry/Paver Tile, 8"X8", Gray, Smooth	Exterior	Assumed	NF	G	1,500	SF
M-GRT-48	M	Grout, Gray, Cementitious	Exterior	Assumed	NF	G	150	SF
M-BUR-49	M	Built-Up Roofing, Black, Asphaltic, Gray Mineral Cap	Roof	Assumed	NF	G	25,000	SF
M-MAS-50	M	Mastic (Penetrations And Flashings), Black, Tar-Like, Silver	Roof	Assumed	NF	G	1,500	SF
M-SLT-51	M	Sealant (Equipment), White, Pliable	Roof	Assumed	NF	G	10	SF
M-SLT-52	M	Sealant (Flashings), Gray, Pliable, Silver	Roof	Assumed	NF	G	50	SF

**6-MONTH SURVEILLANCE INSPECTION TABLE**  
**IN-PLACE ASBESTOS-CONTAINING MATERIALS**

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	<b>M/S/T</b>			<b>%/ASSUMED</b>	<b>NF/F</b>	<b>G/D/SD</b>		<b>LF/SF/EA</b>
S-STU-01	S	Stucco, Gray, Cementitious	Canopy	Assumed	NF	G	40,000	SF
M-SLT-02	M	Sealant, Gray, Pliable	Canopy	Assumed	NF	G	250	SF

## 6-MONTH SURVEILLANCE INSPECTION TABLE

### IN-PLACE ASBESTOS-CONTAINING MATERIALS

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
M-APR-01	M	Asphalt Prepared Roofing (Shingles), Black, Asphaltic, Tan Mineral Cap	Roof	Assumed	NF	G	400	SF
M-VBF-02	M	Vapor Barrier Felt, Black, Asphaltic	Roof	Assumed	NF	G	400	SF
M-CMU-03	M	Concrete Masonry Unit, 8"X16", Gray, Cementitious	Storage	Assumed	NF	G	1,200	SF
			Exterior					
M-MRT-04	M	Mortar, Gray, Cementitious	Storage	Assumed	NF	G	120	SF
			Exterior					
M-CON-05	M	Concrete (Foundation), Gray, Cementitious	Storage	Assumed	NF	G	400	SF
			Exterior					
M-CON-06	M	Concrete (Entries), Gray, Cementitious	Exterior	Assumed	NF	G	200	SF

# THE ASBESTOS INSTITUTE

*Certifies that*

**Zachary Ridgeway**

has attended and received instruction in the EPA approved course

**AHERA Building Inspector Initial**

on

**March 6-8 2023**


and successfully completed and passed the competency exam.

Certificate:  
4380-15665-030823

Date of Examination:  
08-Mar-2023

Date of Expiration:  
08-Mar-2024

  
William T. Caviness  
Director

  
Approved Instructor

THE ASBESTOS INSTITUTE

20033 N. 19<sup>th</sup> Ave, Building 6, Phoenix, AZ 85027  
602-864-6564 – [www.theasbestosinstitute.com](http://www.theasbestosinstitute.com)

This training meets all requirements for asbestos certification under Basic Substance Control Act Title II.